

Ministry of the Environment,
Conservation and Parks

Ministère de l'Environnement, de la
Protection de la nature et des Parks

Southwestern Region

Direction régionale du Sud-Ouest

620 – 4510 Rhodes Drive
Windsor ON N8W 5K5

Tel.: 519 948-1464

Fax.: 519 948-2396

TTY: 416 456-1234

620 – 4510, chemin Rhodes
Windsor ON N8W 5K5

Tél. : 519 948-1464

Télec. : 519 948-2396

ATS : 416 456-1234

File# SI-ES-TE-540

January 14, 2021

Town of Tecumseh
917 Lesperance Road
Tecumseh, ON
N8N 1W9

Attention: Margaret Misk-Evans, CAO
mevans@tecumseh.ca

Dear Ms. Misk-Evans;

Re: Tecumseh Water Distribution System
Inspection Report

Please find enclosed the Drinking Water System Inspection Report for the Tecumseh Distribution System (DWS#260004969). This year's unannounced inspection was conducted remotely and the telephone interview/questionnaire was held on December 7, 2020. There was no physical inspection conducted at your drinking water system this year.

Section 19 of the Safe Drinking Water Act (Standard of Care) creates a number of obligations for individuals who exercise decision-making authority over municipal drinking water systems. Please be aware that the Ministry has encouraged such individuals, particularly municipal councillors, to take steps to be better informed about the drinking water systems over which they have decision-making authority. These steps could include asking for a copy of this inspection report and a review of its findings. Further information about Section 19 can be found in *"Taking Care of Your Drinking Water: A guide for members of municipal council"* found on the Drinking Water Ontario website at www.ontario.ca/drinkingwater.

In order to measure individual inspection results, the Ministry has established an inspection compliance risk framework based on the principles of the Inspection, Investigation & Enforcement (II&E) Secretariat and advice of internal/external risk experts. The Inspection Summary Rating Record (IRR), included as Appendix B of the inspection report, provides the Ministry, the system

owner and the local Public Health Units with a summarized quantitative measure of the drinking water system's annual inspection and regulated water quality testing performance.

IRR ratings are published (for the previous inspection year) in the Ministry's Chief Drinking Water Inspectors' Annual Report. If you have any questions or concerns regarding the rating, please contact Marc Bechard, Water Compliance Supervisor, at (519) 490-0761.

Likewise, if you have any questions or concerns regarding this report, please call me at (226) 280-1556.

Yours truly,



Neil Gilbert, P.Eng.
Provincial Officer – Water Inspector
Southwestern Region
Ministry of the Environment, Conservation and Parks
Sarnia District – Windsor Area Office

Encl.

cc: Dr. Wajid Ahmed, Medical Officer of Health, Windsor-Essex County HU, wahmed@wechu.org
Theresa Marentette, CEO and Chief Nursing Officer, Windsor-Essex County HU, tmarentette@wechu.org
Kristy McBeth, Director of Health Protection, Windsor-Essex County HU, kmcbeth@wechu.org
Phil Wong, Manager, Environmental Health, Windsor-Essex County HU, pwong@wechu.org
Victoria Peczulis, Manager, Environmental Health, Windsor-Essex County HU, vpeczulis@wechu.org
Phil Bartnik, Director of Public Works & Env. Services, Town of Tecumseh, pbartnik@tecumseh.ca
Brad Dupuis, Water & Wastewater Manager, Town of Tecumseh, bdupuis@tecumseh.ca
Marc Bechard, Water Compliance Supervisor, MECP Sarnia District, marc.bechard@ontario.ca



Ministry of the Environment, Conservation and Parks

TECUMSEH DISTRIBUTION SYSTEM
Inspection Report

Site Number:	260004969
Inspection Number:	1-NX84L
Date of Inspection:	Dec 07, 2020
Inspected By:	Neil Gilbert

Table of Contents

Owner Information	2
Inspection Details	2
Inspection Summary	4
Introduction	4
Treatment Processes	4
Treatment Process Monitoring	4
Distribution System	5
Operations Manuals	5
Logbooks	6
Contingency/Emergency Planning	6
Security	6
Consumer Relations	6
Certification and Training	7
Water Quality Monitoring	7
Water Quality Assessment	8
Reporting & Corrective Actions	8
Non-Compliance with Regulatory Requirements and Actions Required	9
Summary of Recommendations and Best Practice Issues	10
Signatures	11

Appendix A: Stakeholder Appendix

Appendix B: Inspection Rating Record

OWNER INFORMATION:

Company Name:	TECUMSEH, THE CORPORATION OF THE TOWN OF		
Street Number:	917	Unit Identifier:	
Street Name:	LESPERANCE Rd		
City:	TECUMSEH		
Province:	ON	Postal Code:	N8N 1W9

CONTACT INFORMATION

Type:	Main Contact	Name:	Brad Dupuis
Phone:	(519) 735-2184 x145	Fax:	(519) 735-1895
Email:	bdupuis@tecumseh.ca		
Title:	Water & Wastewater Manager		

INSPECTION DETAILS:

Site Name:	TECUMSEH DISTRIBUTION SYSTEM
Site Address:	TECUMSEH
County/District:	TECUMSEH
MECP District/Area Office:	Windsor Area Office
Health Unit:	WINDSOR-ESSEX COUNTY HEALTH UNIT
Conservation Authority:	Essex Region Conservation Authority
MNR Office:	Chatham Regional Office
Category:	Large Municipal Residential
Site Number:	260004969
Inspection Type:	Special Unannounced
Inspection Number:	1-NX84L
Date of Inspection:	Dec 07, 2020
Date of Previous Inspection:	Jan 16, 2020

COMPONENTS DESCRIPTION**Site (Name):** Distribution System**Type:** **Sub Type:****Comments:**

The Tecumseh Distribution System is a standalone distribution system which supplies water to the area of the Town of Tecumseh in two discrete service zones. The zone north of Highway 401 is bounded by the Tecumseh municipal boundaries, south to Baseline Road. The zone south of Highway 401 is bounded by the Tecumseh municipal boundaries generally south of Essex County Road 46. Source water is from the City of Windsor water supply via the Windsor municipal distribution system. One currently unused connection from Windsor is through a short section of transmission main within the Lasalle municipal distribution system. The City of Windsor water supply draws its source water from the Detroit River in the vicinity of Belle Isle. According to the drinking water system profile, a population of approximately 24,000 residents is served by the Tecumseh Distribution System. It therefore falls into the "large municipal residential" category under O. Regulation 170/03.

Water mains take treated water from the City of Windsor to the service area through 10 of 12 currently used boundary metered connections points with Tecumseh. The water tower in the Town of Tecumseh maintains distribution system

pressure and is controlled by the Town. The water tower is monitored by the Windsor Utilities Commission (WUC) and the Town through SCADA. Secondary disinfection is provided by the A.H. Weeks water treatment plant in Windsor.

The Tecumseh Distribution System 2018 annual report, prepared by the Town of Tecumseh, states that:

- Town of Tecumseh, City of Windsor and Windsor Utilities Commission (WUC) entered into a 50-year service agreement in November 2004 (By-law 2004-71). The service agreement was implemented on March 31, 2006.
- Prior to August 1, 2008, WUC provided water to 2400 residents in the former Township of Sandwich South, south of Highway 401 ("South Water Area"). The Town of Tecumseh assumed the responsibility for the operations and maintenance of the water distribution system from WUC in this South Water Area effective August 1, 2008.

INSPECTION SUMMARY:

Introduction

- The primary focus of this inspection is to confirm compliance with Ministry of the Environment, Conservation and Parks (MECP) legislation as well as evaluating conformance with ministry drinking water policies and guidelines during the inspection period.

This drinking water system is subject to the legislative requirements of the Safe Drinking Water Act, 2002 (SDWA) and regulations made therein, including Ontario Regulation 170/03, "Drinking Water Systems" (O. Reg. 170/03). This inspection has been conducted pursuant to Section 81 of the SDWA.

This report is based on an inspection of a "stand alone connected distribution system" and was conducted remotely. This type of system receives treated water from a separately owned "donor" system. This report contains elements required to assess key compliance and conformance issues associated with a "receiver" system. This report does not contain items associated with the inspection of the donor system, such as source waters, intakes/wells and treatment facilities.

This inspection report does not suggest that all applicable legislation and regulations were evaluated. It remains the responsibility of the owner to ensure compliance with all applicable legislative and regulatory requirements.

The Tecumseh Distribution System (DWS#260004969) is owned by the Corporation of the Town of Tecumseh. It is a standalone distribution system that receives treated surface water from the City of Windsor water supply via the Windsor municipal distribution system. The City of Windsor water supply draws its source water from the Detroit River in the vicinity of Belle Isle.

According to Tecumseh's drinking water system profile, a population of approximately 24,000 residents are served by the Tecumseh Distribution System. It therefore falls into the "large municipal residential" category under O.Reg. 170/03.

The water tower in the Town of Tecumseh maintains distribution system pressure and secondary disinfection is provided by the A.H. Weeks water treatment plant in Windsor.

This inspection was conducted remotely and the inspection review period was January 1, 2020 to November 30, 2020.

Treatment Processes

- The owner/operating authority was in compliance with the requirement to prepare Form 2 documents as required by their Drinking Water Works Permit during the inspection period.
- Where an activity has occurred that could introduce contamination, all parts of the drinking water system were disinfected in accordance with Schedule B, Condition 2.3 of the Drinking Water Works Permit.

The system's representative was made aware that the updated Ontario Watermain Disinfection Procedure was issued on August 1, 2020. The representative was advised that the municipality is required to modify its watermain repair/commissioning procedures and forms to meet the updated procedure's documentation requirements by the date required in its DWWP.
- The owner had evidence indicating that all chemicals and materials that come in contact with water within the drinking water system met the AWWA and ANSI standards in accordance with the Municipal Drinking Water Licence and Drinking Water Works Permit issued under Part V of the SDWA.

Treatment Process Monitoring

- The secondary disinfectant residual was measured as required for the distribution system.

As per O.Reg. 170/03 s 7-2 (3), the owner/operating authority of a system that provides secondary disinfection shall

Treatment Process Monitoring

ensure that at least seven distribution samples are taken each week and are tested immediately for, (a) free chlorine residual, if the system provides chlorination and does not provide chloramination; or (b) combined chlorine residual, if the system provides chloramination.

The following rules apply to the distribution samples referred above unless at least one sample is taken on each day of the week: At least four of the samples must be taken on one day of the week, at least 48 hours after the last sample was taken in the previous week. Then, at least three of the samples must be taken on a second day of the week, at least 48 hours after the last sample was taken on the first day of the sampling week. When more than one sample is taken on the same day of the week then each sample must be taken from a different location.

During the inspection review period (January 1, 2020 to November 30, 2020) at least seven distribution samples were collected each week using the 4/3 rule and tested for free chlorine residuals.

- **Samples for chlorine residual analysis were tested using an acceptable portable device.**

Distribution System

- **The owner had up-to-date documents describing the distribution components as required.**
- **There is a backflow prevention program, policy and/or bylaw in place.**
The Town of Tecumseh's By-law #2001-68 is a by-law which regulates backflow prevention. In addition, Tecumseh's Standard Operating Procedure #017 (SOP-017) is a procedure for the annual inspection and testing of backflow preventers.
- **The owner had a program or maintained a schedule for routine cleanout, inspection and maintenance of reservoirs and elevated storage tanks within the distribution system.**
- **The owner had implemented a program for the flushing of watermain as per industry standards.**
- **Records confirmed that disinfectant residuals were routinely checked at the extremities and "dead ends" of the distribution system.**
- **A program was in place for inspecting and exercising valves.**
- **There was a program in place for inspecting and operating hydrants.**
- **There was a by-law or policy in place limiting access to hydrants.**
The Town of Tecumseh's Water-Use By-law #2003-99 (Parts 7.3 and 11) contain conditions with respect to the use and restriction of hydrants.
- **The owner was able to maintain proper pressures in the distribution system and pressure was monitored to alert the operator of conditions which may lead to loss of pressure below the value under which the system is designed to operate.**

- **The donor had provided an Annual Report to the receiver drinking water system.**

Operations Manuals

- **Operators and maintenance personnel had ready access to operations and maintenance manuals.**

Operations Manuals

- The operations and maintenance manuals contained plans, drawings and process descriptions sufficient for the safe and efficient operation of the system.
- The operations and maintenance manuals met the requirements of the Drinking Water Works Permit and Municipal Drinking Water Licence issued under Part V of the SDWA.

Condition 16.2 under Schedule B of Tecumseh's Drinking Water Licence (#040-101, Issue #4 dated May 24, 2019) notes that the operations and maintenance manuals shall include (at a minimum) the following:

- 16.2.1 The requirements of this licence and associated procedures;
 - 16.2.2 The requirements of the drinking water works permit for the drinking water system;
 - 16.2.3 A description of the processes used to achieve secondary disinfection within the drinking water system;
 - 16.2.4 Procedures for monitoring and recording the in-process parameters necessary for the control of any treatment subsystem and for assessing the performance of the drinking water system;
 - 16.2.5 Procedures for the operation and maintenance of monitoring equipment;
 - 16.2.6 Contingency plans and procedures for the provision of adequate equipment and material to deal with emergencies, upset conditions and equipment breakdown;
 - 16.2.7 Procedures for dealing with complaints related to the drinking water system, including the recording of the nature of the complaint and any investigation and corrective action taken in respect of the complaint.
- A review of Tecumseh's operating manual and standard operating procedures suggests that these conditions appear to be satisfied. All secondary disinfection is provided by the City of Windsor's A.H. Weeks Water Treatment Plant and Tecumseh does not maintain or operate a re-chlorination system.

Logbooks

- Records or other record keeping mechanisms confirmed that operational testing not performed by continuous monitoring equipment was being done by a certified operator, water quality analyst, or person who suffices the requirements of O. Reg. 170/03 7-5.
- For every required operational test and every required sample, a record was made of the date, time, location, name of the person conducting the test and result of the test.
- Logs or other record keeping mechanisms were available for at least five (5) years.

Contingency/Emergency Planning

- Standby power generators were tested under normal load conditions.

The standby natural gas powered generator at the Public Works building is tested once a month.

Security

- All storage facilities were completely covered and secure.
- Air vents and overflows associated with reservoirs and elevated storage structures were equipped with screens.
- The owner had provided security measures to protect components of the drinking water system.

Consumer Relations

- The owner and/or operating authority undertook efforts to promote water conservation and reduce water

Consumer Relations

losses in their system.

The Owner/Operating Authority has taken various water conservation efforts including, public education/water conservation promotion, water line replacement, and fully metering customers.

The Town of Tecumseh's By-Law #2003-99 is a by-law which regulates the use of water within the Town.

Certification and Training

- **The overall responsible operator had been designated for each subsystem.**
- **Operators-in-charge had been designated for all subsystems which comprised the drinking water system.**
- **All operators possessed the required certification.**
- **An adequately licenced operator was designated to act in place of the overall responsible operator when the overall responsible operator was unable to act**

Water Quality Monitoring

- **All microbiological water quality monitoring requirements for distribution samples were being met.**

As per O.Reg. 170/03 s10-2, the owner/operating authority for the system shall ensure that if a system serves 100,000 people or less, at least eight distribution samples, plus one additional sample for every 1,000 people served, are taken every month, with at least one sample being taken each week. Each of the distribution samples collected must be tested for E. coli and total coliforms and at least 25 percent of these samples must be tested for general bacteria population expressed as colony counts on a heterotrophic plate count (HPC).

During the inspection review period (January 1, 2020 to November 30, 2020) all microbiological water monitoring requirements for distribution water samples were performed.

- **All haloacetic acid water quality monitoring requirements prescribed by legislation are being conducted within the required frequency and at the required location.**

As per O.Reg 170/03 s13-6.1, the owner/operating authority shall ensure that a minimum of one sample is collected and tested for haloacetic acid (HAA) per calendar quarter.

On January 1, 2020, the O.Reg. 169/03 standard for HAA (80ug/L) came into effect and is expressed as a RAA, where RAA is defined as "the running annual average of quarterly results" for HAA for a drinking water system. During the inspection review period (January 1, 2020 to November 30, 2020), these HAA samples were collected on Jan. 6, 2020 (HAA result = 13.9ug/L), Apr. 6, 2020 (HAA result = 16.5ug/L), July 7, 2020 (HAA result = 26.1ug/L) and Oct. 5, 2020 (HAA result = 26.3ug/L). All of these HAA results were below 80ug/L and the average for the inspection review period was 20.7ug/L.

- **All trihalomethane water quality monitoring requirements prescribed by legislation were conducted within the required frequency and at the required location.**

As per O.Reg. 170/03 s13-6, the owner/operating authority of a system that provides chlorination or chloramination shall ensure that at least one distribution sample is taken in each calendar quarter, from a point in the distribution system that is likely to have an elevated potential for the formation of trihalomethanes (THMs), and have the sample tested for THMs.

During the inspection review period (January 1, 2020 to November 30, 2020), these THM quarterly samples were collected on Jan. 6, 2020 (at 3 locations with a THM average = 15ug/L), Apr. 6, 2020 (at 4 locations with a THM average = 16.8ug/L), July 7, 2020 (at 3 locations with a THM average = 34.7ug/L) and Oct. 5, 2020 (at 3 locations with a THM average = 40ug/L).

The Ontario Drinking Water Quality Standard (ODWQS) for THM is 100 ug/L (expressed as a running annual

Water Quality Monitoring

average of quarterly results). All of the THM results were below 100ug/L and the average for the inspection review period was 26.6ug/L.

- **The owner ensured that water samples were taken at the prescribed location.**
- **All sampling requirements for lead prescribed by schedule 15.1 of O. Reg. 170/03 were being met.**

This drinking water system is exempt from plumbing lead sampling as per the exemption in O.Reg. 170/03 Schedule 15.1. Under this exemption and as per subsection 15.1-5 (10), the owner/operating authority are required to test for pH and alkalinity during each of the two periods described in subsection 15.1-5 (5) (i.e. Dec. 15 to Apr. 15 and June 15 to Oct. 15) in every 12-month period and to test for lead during each of the two periods described in subsection 15.1-5 (5) in every third 12-month period. In accordance with the "Reduced Sampling Table" (found in O.Reg. 170/03 Schedule 15.1) and based on the population served by the Tecumseh Distribution System, at least four sampling points must be tested in the distribution system per period (i.e. Dec. 15 to Apr. 15 and June 15 to Oct. 15).

During the inspection review period (Jan. 1, 2020 to Nov. 30, 2020), water samples were collected from four locations within the distribution system on Jan. 23, 2020 and Oct. 5, 2020 and tested for lead, alkalinity and pH.

- **Records confirmed that chlorine residual tests were being conducted at the same time and at the same location that microbiological samples were obtained.**
- **The owner indicated that the required records are kept and will be kept for the required time period.**

Water Quality Assessment

- **Records showed that all water sample results taken during the inspection review period did not exceed the values of tables 1, 2 and 3 of the Ontario Drinking Water Quality Standards (O.Reg. 169/03).**

Reporting & Corrective Actions

- **Summary Reports for municipal council were completed on time, included the required content, and were distributed in accordance with the regulatory requirements.**

NON-COMPLIANCE WITH REGULATORY REQUIREMENTS AND ACTIONS REQUIRED

This section provides a summary of all non-compliance with regulatory requirements identified during the inspection period, as well as actions required to address these issues. Further details pertaining to these items can be found in the body of the inspection report.

Not Applicable

SUMMARY OF RECOMMENDATIONS AND BEST PRACTICE ISSUES

This section provides a summary of all recommendations and best practice issues identified during the inspection period. Details pertaining to these items can be found in the body of the inspection report. In the interest of continuous improvement in the interim, it is recommended that owners and operators develop an awareness of the following issues and consider measures to address them.

Not Applicable

SIGNATURES

Inspected By:

Neil Gilbert

Signature: (Provincial Officer)

Reviewed & Approved By:

Marc Bechard

Signature: (Supervisor)

Review & Approval Date:

Note: This inspection does not in any way suggest that there is or has been compliance with applicable legislation and regulations as they apply or may apply to this facility. It is, and remains, the responsibility of the owner and/or operating authority to ensure compliance with all applicable legislative and regulatory requirements.



Stakeholder Appendix

Key Reference and Guidance Material for Municipal Residential Drinking Water Systems

Many useful materials are available to help you operate your drinking water system. Below is a list of key materials owners and operators of municipal residential drinking water systems frequently use.

To access these materials online click on their titles in the table below or use your web browser to search for their titles. Contact the Ministry if you need assistance or have questions at 1-866-793-2588 or waterforms@ontario.ca.

For more information on Ontario's drinking water visit www.ontario.ca/drinkingwater



PUBLICATION TITLE	PUBLICATION NUMBER
FORMS: Drinking Water System Profile Information Laboratory Services Notification Adverse Test Result Notification	012-2149E 012-2148E 012-4444E
Taking Care of Your Drinking Water: A Guide for Members of Municipal Councils	Website
Procedure for Disinfection of Drinking Water in Ontario	Website
Strategies for Minimizing the Disinfection Products Trihalomethanes and Haloacetic Acids	Website
Filtration Processes Technical Bulletin	Website
Ultraviolet Disinfection Technical Bulletin	Website
Guide for Applying for Drinking Water Works Permit Amendments, & License Amendments	Website
Certification Guide for Operators and Water Quality Analysts	Website
Guide to Drinking Water Operator Training Requirements	9802E
Community Sampling and Testing for Lead: Standard and Reduced Sampling and Eligibility for Exemption	Website
Drinking Water System Contact List	7128E01
Ontario's Drinking Water Quality Management Standard - Pocket Guide	Website
Watermain Disinfection Procedure	Website
List of Licensed Laboratories	Website

Principaux guides et documents de référence sur les réseaux résidentiels municipaux d'eau potable

De nombreux documents utiles peuvent vous aider à exploiter votre réseau d'eau potable. Vous trouverez ci-après une liste de documents que les propriétaires et exploitants de réseaux résidentiels municipaux d'eau potable utilisent fréquemment. Pour accéder à ces documents en ligne, cliquez sur leur titre dans le tableau ci-dessous ou faites une recherche à l'aide de votre navigateur Web. Communiquez avec le ministère au 1-866-793-2588, ou encore à waterforms@ontario.ca si vous avez des questions ou besoin d'aide.



Pour plus de renseignements sur l'eau potable en Ontario, consultez le site www.ontario.ca/eaupotable

TITRE DE LA PUBLICATION	NUMÉRO DE PUBLICATION
Renseignements sur le profil du réseau d'eau potable	012-2149F
Avis de demande de services de laboratoire	012-2148F
Avis de résultats d'analyse insatisfaisants et de règlement des problèmes	012-4444F
Prendre soin de votre eau potable - Un guide destiné aux membres des conseils municipaux	Site Web
Marche à suivre pour désinfecter l'eau potable en Ontario	Site Web
Stratégies pour minimiser les trihalométhanes et les acides haloacétiques de sous-produits de désinfection	Site Web
Filtration Processes Technical Bulletin (en anglais seulement)	Site Web
Ultraviolet Disinfection Technical Bulletin (en anglais seulement)	Site Web
Guide de présentation d'une demande de modification du permis d'aménagement de station de production d'eau potable	Site Web
Guide sur l'accréditation des exploitants de réseaux d'eau potable et des analystes de la qualité de l'eau de réseaux d'eau potable	Site Web
Guide sur les exigences relatives à la formation des exploitants de réseaux d'eau potable	9802F
Échantillonnage et analyse du plomb dans les collectivités : échantillonnage normalisé ou réduit et admissibilité à l'exemption	Site Web
Liste des personnes-ressources du réseau d'eau potable	Site Web
L'eau potable en Ontario - Norme de gestion de la qualité - Guide de poche	Site Web
Procédure de désinfection des conduites principales	Site Web
Laboratoires autorisés	Site Web



Inspection Rating Record

Ministry of the Environment - Inspection Summary Rating Record (Reporting Year - 2020-2021)

DWS Name: TECUMSEH DISTRIBUTION SYSTEM
DWS Number: 260004969
DWS Owner: Tecumseh, The Corporation Of The Town Of
Municipal Location: Tecumseh

Regulation: O.REG 170/03
Category: Large Municipal Residential System
Type Of Inspection: Standalone
Inspection Date: December 7, 2020
Ministry Office: Windsor Area Office

Maximum Question Rating: 240

Inspection Module	Non-Compliance Rating
Treatment Processes	0 / 33
Distribution System	0 / 4
Operations Manuals	0 / 42
Logbooks	0 / 22
Certification and Training	0 / 35
Water Quality Monitoring	0 / 71
Reporting & Corrective Actions	0 / 4
Treatment Process Monitoring	0 / 29
TOTAL	0 / 240

Inspection Risk Rating	0.00%
------------------------	-------

FINAL INSPECTION RATING:	100.00%
---------------------------------	----------------

Ministry of the Environment - Detailed Inspection Rating Record (Reporting Year - 2020-2021)

DWS Name: TECUMSEH DISTRIBUTION SYSTEM
DWS Number: 260004969
DWS Owner: Tecumseh, The Corporation Of The Town Of
Municipal Location: Tecumseh

Regulation: O.REG 170/03

Category: Large Municipal Residential System

Type Of Inspection: Standalone

Inspection Date: December 7, 2020

Ministry Office: Windsor Area Office

Maximum Question Rating: 240

Inspection Risk Rating	0.00%
-------------------------------	--------------

FINAL INSPECTION RATING:	100.00%
---------------------------------	----------------