

Summary Report
For the
Tecumseh Distribution System
(260004969)
For the year
2020

Prepared for the Town of Tecumseh
By Brad Dupuis, C.Tech.
Manager Water & Wastewater Division O.R.O.

Table of Contents

Section 1: Overview	3
Section 2: Non-Compliance Issues	4
Section 3: System Capability – 2020 Water Consumption.....	4

Section 1: Overview

This report has been prepared and submitted in accordance with Schedule 22 of O. Reg. 170/03 under the *Safe Drinking Water Act*. Schedule 22 requires:

The owner of a drinking-water system shall ensure that, not later than March 31 of each year after 2003, a report is prepared in accordance with subsections (1) and (2) for the preceding calendar year and is given to the members of the municipal council.

Schedule 22 also states that:

- 1) The report must:
 - a) list the requirements of the *Act*, the regulations, the system's approval and any order that the system failed to meet at any time during the period covered by the report and specify the duration of the failure; and
 - b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.
- 2) The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system. A summary of the quantities of the water supplied during the period covered by the report, including monthly flows.

In June 2003, the provincial *Safe Drinking Water Act* came into effect. The Drinking Water Systems Regulation (O.Reg. 170/03) defines how various drinking water systems are to be operated.

According to this Regulation, the Tecumseh Distribution System is classified as a Large Municipal Residential System (LMR).

Section 2: Non-Compliance Issues

During the year of 2020 there was zero (0) reportable issue.

Section 3: System Capability – 2020 Water Consumption

In accordance with the Agreement between the Town of Tecumseh and the City of Windsor for the provision of water services to the Town of Tecumseh, executed under By-Law No. 2004-71, the Maximum Daily Flow shall not exceed **87 Million Litres** (87 MLD) or 87,000 cubic meters.

The **Maximum Daily Flow** for 2020 was **17,371,000 Litres** (17,371 Cubic Meters) on July 06, 2020.

Monthly average and daily flows for 2020 are attached for reference.

A summary of the **monthly** total volume supplied by the City of Windsor to the Town of Tecumseh in the year 2020 is provided below:

Month	Total Volume (cubic meters)
January	205,499
February	185,850
March	203,244
April	202,201
May	261,947
June	379,234
July	424,549
August	400,946
September	364,352
October	291,363
November	255,254
December	237,754
Total	3,174,439

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202001 Date: 2021-01-27
Page: 1 of 1

Date: Jan-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	634.0	375.0	1616.0	2962.0	0.0	-76.0	-50.0	205.0	365.0	543.0	-430.0	n/a	6144.0
2	674.0	404.0	1568.0	2891.0	0.0	-89.0	-63.0	182.0	381.0	618.0	-194.0	n/a	6372.0
3	657.0	398.0	1549.0	2872.0	0.0	-116.0	-91.0	211.0	381.0	593.0	-252.0	n/a	6202.0
4	694.0	408.0	1679.0	3048.0	0.0	-67.0	-37.0	203.0	351.0	515.0	-434.0	n/a	6360.0
5	728.0	429.0	1740.0	3164.0	0.0	-58.0	-27.0	204.0	355.0	512.0	-481.0	n/a	6566.0
6	657.0	402.0	1578.0	2900.0	0.0	-104.0	-79.0	207.0	404.0	657.0	-184.0	n/a	6438.0
7	1139.0	695.0	1995.0	3519.0	0.0	-60.0	-34.0	176.0	389.0	634.0	-120.0	n/a	8333.0
8	709.0	428.0	1593.0	2906.0	0.0	-90.0	-69.0	203.0	412.0	663.0	-220.0	n/a	6535.0
9	732.0	438.0	1592.0	2943.0	0.0	-114.0	-89.0	230.0	417.0	675.0	-229.0	n/a	6595.0
10	1121.0	690.0	1984.0	3481.0	0.0	-53.0	-27.0	156.0	344.0	577.0	-89.0	n/a	8184.0
11	719.0	418.0	1697.0	3083.0	0.0	-71.0	-46.0	272.0	409.0	598.0	-517.0	n/a	6562.0
12	738.0	434.0	1740.0	3147.0	0.0	-63.0	-31.0	241.0	382.0	567.0	-492.0	n/a	6663.0
13	695.0	412.0	1567.0	2855.0	0.0	-80.0	-58.0	218.0	411.0	672.0	-205.0	n/a	6487.0
14	721.0	426.0	1586.0	2890.0	0.0	-96.0	-66.0	235.0	435.0	725.0	-192.0	n/a	6664.0
15	693.0	414.0	1552.0	2848.0	0.0	-88.0	-56.0	243.0	427.0	707.0	-150.0	n/a	6590.0
16	727.0	430.0	1571.0	2868.0	0.0	-86.0	-52.0	237.0	423.0	694.0	-137.0	n/a	6675.0
17	826.0	534.0	1801.0	3181.0	0.0	-53.0	-22.0	199.0	376.0	629.0	-187.0	n/a	7284.0
18	732.0	417.0	1688.0	3059.0	0.0	-64.0	-37.0	253.0	383.0	577.0	-475.0	n/a	6533.0
19	748.0	431.0	1726.0	3127.0	0.0	-68.0	-30.0	260.0	390.0	575.0	-535.0	n/a	6624.0
20	717.0	426.0	1577.0	2897.0	0.0	-108.0	-74.0	255.0	428.0	707.0	-300.0	n/a	6525.0
21	715.0	421.0	1559.0	2883.0	0.0	-123.0	-93.0	265.0	450.0	733.0	-306.0	n/a	6504.0
22	725.0	431.0	1585.0	2907.0	0.0	-104.0	-75.0	256.0	446.0	730.0	-305.0	n/a	6596.0
23	724.0	425.0	1572.0	2875.0	0.0	-98.0	-64.0	228.0	418.0	684.0	-209.0	n/a	6555.0
24	680.0	406.0	1537.0	2841.0	0.0	-90.0	-54.0	223.0	406.0	672.0	-161.0	n/a	6460.0
25	725.0	426.0	1692.0	3055.0	0.0	-59.0	-32.0	228.0	376.0	590.0	-362.0	n/a	6639.0
26	698.0	407.0	1663.0	3014.0	0.0	-68.0	-28.0	210.0	355.0	545.0	-380.0	n/a	6416.0
27	681.0	409.0	1542.0	2821.0	0.0	-108.0	-73.0	217.0	399.0	663.0	-181.0	n/a	6370.0
28	689.0	403.0	1524.0	2824.0	0.0	-123.0	-89.0	227.0	409.0	688.0	-148.0	n/a	6404.0
29	692.0	403.0	1546.0	2871.0	0.0	-123.0	-91.0	241.0	434.0	730.0	-170.0	n/a	6533.0
30	702.0	410.0	1551.0	2876.0	0.0	-132.0	-95.0	261.0	449.0	746.0	-257.0	n/a	6511.0
31	645.0	374.0	1492.0	2767.0	0.0	-122.0	-94.0	224.0	410.0	682.0	-203.0	n/a	6175.0
Monthly Total	22,737.00	13,524.00	50,662.00	92,375.00	0.00	-2,754.00	-1,826.00	6,970.00	12,415.00	19,901.00	-8,505.00	n/a	205,499.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202002 Date: 2021-01-27
Page: 1 of 1

Date: Feb-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	676.0	384.0	1649.0	3020.0	0.0	-68.0	-34.0	229.0	393.0	609.0	-313.0	n/a	6545.0
2	706.0	401.0	1691.0	3113.0	0.0	-90.0	-52.0	234.0	388.0	579.0	-445.0	n/a	6525.0
3	693.0	401.0	1538.0	2855.0	0.0	-104.0	-68.0	203.0	405.0	676.0	-125.0	n/a	6474.0
4	651.0	383.0	1532.0	2827.0	0.0	-85.0	-55.0	185.0	400.0	665.0	-104.0	n/a	6399.0
5	662.0	389.0	1523.0	2797.0	0.0	-110.0	-76.0	222.0	415.0	678.0	-202.0	n/a	6298.0
6	641.0	373.0	1501.0	2760.0	0.0	-111.0	-81.0	206.0	411.0	676.0	-109.0	n/a	6267.0
7	658.0	389.0	1513.0	2775.0	0.0	-99.0	-64.0	178.0	369.0	619.0	-125.0	n/a	6213.0
8	691.0	391.0	1656.0	3018.0	0.0	-57.0	-31.0	201.0	366.0	568.0	-388.0	n/a	6415.0
9	707.0	408.0	1683.0	3103.0	0.0	-87.0	-48.0	214.0	361.0	538.0	-447.0	n/a	6432.0
10	679.0	401.0	1538.0	2857.0	0.0	-111.0	-78.0	189.0	380.0	633.0	-106.0	n/a	6382.0
11	667.0	399.0	1524.0	2805.0	0.0	-106.0	-75.0	198.0	387.0	650.0	-74.0	n/a	6375.0
12	679.0	412.0	1551.0	2858.0	0.0	-112.0	-80.0	224.0	406.0	677.0	-93.0	n/a	6522.0
13	644.0	383.0	1505.0	2766.0	0.0	-100.0	-65.0	188.0	370.0	634.0	-76.0	n/a	6249.0
14	692.0	415.0	1575.0	2904.0	0.0	-105.0	-72.0	222.0	404.0	689.0	-40.0	n/a	6684.0
15	740.0	438.0	1713.0	3142.0	0.0	-76.0	-42.0	239.0	381.0	585.0	-396.0	n/a	6724.0
16	663.0	379.0	1613.0	2988.0	0.0	-81.0	-37.0	207.0	344.0	516.0	-426.0	n/a	6166.0
17	660.0	373.0	1610.0	2991.0	0.0	-81.0	-50.0	192.0	357.0	551.0	-321.0	n/a	6282.0
18	647.0	385.0	1536.0	2819.0	0.0	-111.0	-78.0	205.0	396.0	660.0	-22.0	n/a	6437.0
19	661.0	389.0	1544.0	2842.0	0.0	-121.0	-84.0	199.0	388.0	639.0	-93.0	n/a	6364.0
20	643.0	379.0	1509.0	2760.0	0.0	-101.0	-71.0	167.0	378.0	623.0	-59.0	n/a	6228.0
21	658.0	392.0	1542.0	2816.0	0.0	-82.0	-51.0	173.0	403.0	689.0	48.0	n/a	6588.0
22	687.0	392.0	1681.0	3070.0	0.0	-67.0	-43.0	228.0	389.0	596.0	-369.0	n/a	6564.0
23	693.0	397.0	1691.0	3067.0	0.0	-74.0	-38.0	232.0	381.0	577.0	-387.0	n/a	6539.0
24	624.0	364.0	1510.0	2768.0	0.0	-105.0	-71.0	201.0	400.0	672.0	-62.0	n/a	6301.0
25	643.0	365.0	1489.0	2742.0	0.0	-107.0	-73.0	201.0	411.0	684.0	-63.0	n/a	6292.0
26	641.0	370.0	1505.0	2750.0	0.0	-118.0	-87.0	215.0	407.0	669.0	-175.0	n/a	6177.0
27	689.0	406.0	1535.0	2814.0	0.0	-102.0	-72.0	197.0	393.0	660.0	-113.0	n/a	6407.0
28	673.0	403.0	1530.0	2826.0	0.0	-126.0	-94.0	194.0	377.0	627.0	-91.0	n/a	6319.0
29	750.0	431.0	1709.0	3158.0	0.0	-121.0	-67.0	267.0	392.0	579.0	-416.0	n/a	6682.0
30													
31													
Monthly Total	19,518.00	11,392.00	45,696.00	84,011.00	0.00	-2,818.00	-1,837.00	6,010.00	11,252.00	18,218.00	-5,592.00	0.00	185,850.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202003 Date: 2021-01-27
Page: 1 of 1

Date: Mar-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	699.0	402.0	1693.0	3101.0	0.0	-85.0	-45.0	170.0	388.0	592.0	-346.0	n/a	6569.0
2	644.0	380.0	1512.0	2813.0	0.0	-117.0	-83.0	160.0	401.0	660.0	-121.0	n/a	6249.0
3	661.0	388.0	1512.0	2802.0	0.0	-121.0	-88.0	166.0	418.0	694.0	-55.0	n/a	6377.0
4	676.0	397.0	1523.0	2829.0	0.0	-121.0	-87.0	232.0	413.0	683.0	-106.0	n/a	6439.0
5	655.0	392.0	1530.0	2839.0	0.0	-122.0	-88.0	196.0	378.0	638.0	-56.0	n/a	6362.0
6	671.0	402.0	1513.0	2795.0	0.0	-125.0	-91.0	234.0	387.0	641.0	-171.0	n/a	6256.0
7	737.0	426.0	1691.0	3109.0	0.0	-83.0	-52.0	248.0	376.0	598.0	-347.0	n/a	6703.0
8	706.0	398.0	1666.0	3041.0	0.0	-70.0	-32.0	243.0	360.0	559.0	-400.0	n/a	6471.0
9	718.0	420.0	1555.0	2885.0	0.0	-124.0	-94.0	236.0	425.0	707.0	-104.0	n/a	6624.0
10	655.0	383.0	1497.0	2764.0	0.0	-110.0	-76.0	208.0	400.0	687.0	-40.0	n/a	6368.0
11	682.0	399.0	1540.0	2865.0	0.0	-132.0	-96.0	260.0	461.0	776.0	35.0	n/a	6790.0
12	703.0	410.0	1536.0	2857.0	0.0	-115.0	-80.0	229.0	418.0	719.0	-3.0	n/a	6674.0
13	677.0	395.0	1527.0	2821.0	0.0	-103.0	-69.0	218.0	403.0	674.0	-60.0	n/a	6483.0
14	749.0	421.0	1729.0	3126.0	0.0	-57.0	-22.0	239.0	376.0	590.0	-336.0	n/a	6815.0
15	707.0	402.0	1686.0	3074.0	0.0	-77.0	-44.0	226.0	371.0	562.0	-412.0	n/a	6495.0
16	657.0	382.0	1533.0	2834.0	0.0	-95.0	-64.0	210.0	391.0	656.0	-110.0	n/a	6394.0
17	668.0	378.0	1526.0	2846.0	0.0	-114.0	-80.0	259.0	447.0	756.0	-201.0	n/a	6485.0
18	667.0	381.0	1563.0	2872.0	0.0	-108.0	-75.0	274.0	454.0	776.0	-203.0	n/a	6601.0
19	673.0	388.0	1577.0	2880.0	0.0	-71.0	-38.0	280.0	462.0	781.0	-222.0	n/a	6710.0
20	658.0	387.0	1590.0	2930.0	0.0	-92.0	-62.0	292.0	453.0	736.0	-320.0	n/a	6572.0
21	734.0	420.0	1761.0	3181.0	0.0	-46.0	-17.0	288.0	417.0	629.0	-550.0	n/a	6817.0
22	713.0	405.0	1713.0	3084.0	0.0	-54.0	-24.0	278.0	409.0	613.0	-574.0	n/a	6563.0
23	688.0	398.0	1600.0	2914.0	0.0	-84.0	-53.0	286.0	450.0	724.0	-337.0	n/a	6586.0
24	676.0	391.0	1598.0	2903.0	0.0	-73.0	-44.0	290.0	457.0	733.0	-315.0	n/a	6616.0
25	718.0	420.0	1656.0	3028.0	0.0	-96.0	-65.0	299.0	460.0	719.0	-420.0	n/a	6719.0
26	695.0	405.0	1622.0	2965.0	0.0	-58.0	-31.0	247.0	440.0	701.0	-392.0	n/a	6594.0
27	695.0	405.0	1623.0	2977.0	0.0	-89.0	-60.0	267.0	447.0	673.0	-460.0	n/a	6478.0
28	707.0	402.0	1699.0	3070.0	0.0	-54.0	-25.0	248.0	394.0	579.0	-484.0	n/a	6536.0
29	746.0	429.0	1756.0	3368.0	0.0	12.0	44.0	238.0	366.0	531.0	-488.0	n/a	7002.0
30	676.0	401.0	1618.0	2932.0	0.0	-72.0	-43.0	243.0	421.0	652.0	-314.0	n/a	6514.0
31	683.0	406.0	1605.0	2909.0	0.0	-53.0	-26.0	219.0	405.0	620.0	-386.0	n/a	6382.0
Monthly Total	21,394.00	12,413.00	49,750.00	91,414.00	0.00	-2,709.00	-1,710.00	7,483.00	12,848.00	20,659.00	-8,298.00	n/a	203,244.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202004 Date: 2021-01-27
Page: 1 of 1

Date: Apr-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	658.0	387.0	1616.0	2944.0	0.0	-71.0	-41.0	241.0	428.0	663.0	-453.0	n/a	6372.0
2	721.0	412.0	1666.0	3050.0	0.0	-79.0	-44.0	287.0	432.0	643.0	-472.0	n/a	6616.0
3	717.0	419.0	1685.0	3066.0	0.0	-66.0	-33.0	249.0	413.0	621.0	-373.0	n/a	6698.0
4	756.0	429.0	1747.0	3170.0	0.0	-29.0	4.0	268.0	406.0	579.0	-521.0	n/a	6809.0
5	748.0	428.0	1716.0	3106.0	0.0	-46.0	-21.0	281.0	416.0	575.0	-650.0	n/a	6553.0
6	759.0	439.0	1678.0	3055.0	0.0	-68.0	-41.0	286.0	445.0	664.0	-450.0	n/a	6767.0
7	702.0	402.0	1605.0	2925.0	0.0	-73.0	-43.0	267.0	415.0	633.0	-446.0	n/a	6387.0
8	763.0	440.0	1707.0	3120.0	0.0	-73.0	-44.0	284.0	435.0	683.0	-370.0	n/a	6945.0
9	681.0	400.0	1595.0	2888.0	0.0	-52.0	-37.0	239.0	388.0	628.0	-333.0	n/a	6397.0
10	726.0	415.0	1666.0	2998.0	0.0	-42.0	n/a	244.0	378.0	555.0	-562.0	n/a	6378.0
11	743.0	424.0	1722.0	3126.0	0.0	-52.0	n/a	293.0	395.0	557.0	-503.0	n/a	6705.0
12	691.0	388.0	1651.0	2948.0	0.0	-44.0	n/a	245.0	364.0	542.0	-536.0	n/a	6249.0
13	686.0	393.0	1607.0	2929.0	0.0	-120.0	n/a	320.0	434.0	646.0	-541.0	n/a	6354.0
14	698.0	407.0	1619.0	2934.0	0.0	-51.0	n/a	200.0	371.0	614.0	-233.0	n/a	6559.0
15	714.0	413.0	1619.0	2933.0	0.0	-43.0	n/a	230.0	386.0	648.0	-272.0	n/a	6628.0
16	742.0	431.0	1648.0	2995.0	0.0	-60.0	n/a	242.0	418.0	677.0	-362.0	n/a	6731.0
17	692.0	402.0	1595.0	2898.0	0.0	-78.0	n/a	273.0	432.0	660.0	-489.0	n/a	6385.0
18	741.0	417.0	1719.0	3113.0	0.0	-38.0	n/a	270.0	385.0	587.0	-513.0	n/a	6681.0
19	722.0	405.0	1677.0	3044.0	0.0	-40.0	n/a	255.0	377.0	561.0	-550.0	n/a	6451.0
20	741.0	437.0	1675.0	3066.0	0.0	-69.0	n/a	281.0	432.0	683.0	-343.0	n/a	6903.0
21	716.0	420.0	1636.0	2967.0	0.0	-70.0	n/a	275.0	440.0	712.0	-403.0	n/a	6693.0
22	748.0	439.0	1663.0	3014.0	0.0	-77.0	n/a	278.0	432.0	697.0	-389.0	n/a	6805.0
23	756.0	449.0	1699.0	3081.0	0.0	-114.0	n/a	327.0	441.0	685.0	-437.0	n/a	6887.0
24	725.0	434.0	1711.0	3094.0	0.0	-48.0	n/a	272.0	420.0	687.0	-301.0	n/a	6994.0
25	847.0	481.0	1828.0	3293.0	0.0	-47.0	n/a	286.0	406.0	606.0	-555.0	n/a	7145.0
26	821.0	473.0	1781.0	3191.0	0.0	-27.0	n/a	253.0	374.0	570.0	-509.0	n/a	6927.0
27	839.0	501.0	1836.0	3370.0	0.0	-56.0	24.0	284.0	468.0	755.0	-385.0	n/a	7636.0
28	843.0	507.0	1833.0	3326.0	0.0	-52.0	-20.0	268.0	450.0	744.0	-315.0	n/a	7584.0
29	792.0	470.0	1715.0	3128.0	0.0	-65.0	-32.0	270.0	423.0	679.0	-370.0	n/a	7010.0
30	798.0	466.0	1701.0	3078.0	0.0	-74.0	-43.0	280.0	443.0	702.0	-399.0	n/a	6952.0
31													
Monthly Total	22,286.00	12,928.00	50,616.00	91,850.00	0.00	-1,824.00	-371.00	8,048.00	12,447.00	19,256.00	-13,035.00	0.00	202,201.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202005 Date: 2021-01-27
Page: 1 of 1

Date: May-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	858.0	499.0	1838.0	3356.0	0.0	-59.0	-29.0	292.0	464.0	734.0	-463.0	n/a	7490.0
2	981.0	551.0	2016.0	3700.0	0.0	-37.0	-14.0	330.0	474.0	703.0	-691.0	n/a	8013.0
3	1077.0	611.0	2133.0	3955.0	0.0	-35.0	2.0	343.0	486.0	731.0	-675.0	n/a	8628.0
4	859.0	508.0	1842.0	3400.0	0.0	-55.0	-36.0	294.0	467.0	756.0	-347.0	n/a	7688.0
5	839.0	495.0	1780.0	3293.0	0.0	-87.0	-56.0	301.0	452.0	711.0	-460.0	n/a	7268.0
6	952.0	561.0	1949.0	3566.0	0.0	-62.0	-29.0	298.0	464.0	744.0	-399.0	n/a	8044.0
7	972.0	574.0	1932.0	3538.0	0.0	-57.0	-30.0	293.0	469.0	785.0	-289.0	n/a	8187.0
8	882.0	529.0	1833.0	3354.0	0.0	-87.0	-49.0	327.0	468.0	770.0	-470.0	n/a	7557.0
9	913.0	536.0	1932.0	3496.0	0.0	-24.0	2.0	278.0	399.0	625.0	-551.0	n/a	7606.0
10	891.0	519.0	1841.0	3347.0	0.0	-46.0	-17.0	258.0	395.0	609.0	-547.0	n/a	7250.0
11	865.0	519.0	1816.0	3259.0	0.0	-70.0	-39.0	272.0	439.0	724.0	-394.0	n/a	7391.0
12	986.0	579.0	1932.0	3501.0	0.0	-69.0	-38.0	316.0	478.0	773.0	-456.0	n/a	8002.0
13	1064.0	620.0	2042.0	3726.0	0.0	-48.0	-31.0	333.0	492.0	779.0	-456.0	n/a	8521.0
14	911.0	536.0	1830.0	3304.0	0.0	-41.0	-15.0	266.0	434.0	684.0	-383.0	n/a	7526.0
15	951.0	541.0	1905.0	3417.0	0.0	-55.0	-44.0	290.0	465.0	701.0	-518.0	n/a	7653.0
16	1165.0	645.0	2210.0	4011.0	0.0	-8.0	25.0	302.0	459.0	667.0	-619.0	n/a	8857.0
17	832.0	468.0	1832.0	3367.0	0.0	-53.0	-17.0	311.0	432.0	607.0	-691.0	n/a	7088.0
18	737.0	415.0	1712.0	3122.0	0.0	-34.0	-4.0	213.0	376.0	556.0	-500.0	n/a	6593.0
19	815.0	490.0	1763.0	3222.0	0.0	-54.0	-24.0	266.0	441.0	715.0	-333.0	n/a	7301.0
20	1019.0	592.0	1980.0	3607.0	0.0	-57.0	-30.0	329.0	491.0	788.0	-429.0	n/a	8290.0
21	1155.0	673.0	2156.0	3952.0	0.0	-50.0	-17.0	346.0	503.0	792.0	-473.0	n/a	9037.0
22	1032.0	616.0	1995.0	3637.0	0.0	-76.0	-37.0	323.0	471.0	739.0	-473.0	n/a	8227.0
23	1194.0	668.0	2321.0	4229.0	0.0	-22.0	12.0	302.0	468.0	698.0	-626.0	n/a	9244.0
24	1411.0	791.0	2606.0	4735.0	0.0	-8.0	14.0	320.0	530.0	763.0	-719.0	n/a	10443.0
25	1414.0	794.0	2556.0	4720.0	0.0	-64.0	-65.0	400.0	630.0	977.0	-516.0	n/a	10846.0
26	1422.0	793.0	2613.0	4827.0	0.0	-66.0	-86.0	350.0	611.0	961.0	-416.0	n/a	11009.0
27	1367.0	785.0	2486.0	4599.0	0.0	-81.0	-59.0	375.0	603.0	941.0	-492.0	n/a	10524.0
28	1138.0	645.0	2115.0	3891.0	0.0	-100.0	-62.0	319.0	541.0	882.0	-355.0	n/a	9014.0
29	1119.0	665.0	2063.0	3807.0	0.0	-73.0	-20.0	278.0	489.0	813.0	-290.0	n/a	8851.0
30	1239.0	719.0	2357.0	4314.0	0.0	-37.0	15.0	357.0	520.0	799.0	-527.0	n/a	9756.0
31	1326.0	776.0	2491.0	4515.0	0.0	-27.0	12.0	358.0	505.0	747.0	-660.0	n/a	10043.0
Monthly Total	32,386.00	18,713.00	63,877.00	116,767.00	0.00	-1,642.00	-766.00	9,640.00	14,916.00	23,274.00	-15,218.00	n/a	261,947.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202006 Date: 2021-01-27
Page: 1 of 1

Date: Jun-20

Day of the Month	MCT01 <i>m3</i>	MCT02 <i>m3</i>	MCT03 <i>m3</i>	MCT04 <i>m3</i>	MCT05 <i>m3</i>	MCT06 <i>m3</i>	MCT07 <i>m3</i>	MCT08 <i>m3</i>	MCT09 <i>m3</i>	MCT10 <i>m3</i>	MCT11 <i>m3</i>	MCT12 <i>m3</i>	System Total <i>m3</i>
1	1322.0	789.0	2424.0	4423.0	0.0	-60.0	-40.0	336.0	560.0	912.0	-364.0	n/a	10302.0
2	1299.0	771.0	2420.0	4420.0	0.0	-88.0	-50.0	372.0	581.0	951.0	-305.0	n/a	10371.0
3	1370.0	811.0	2546.0	4691.0	0.0	-87.0	-44.0	414.0	651.0	1064.0	-372.0	n/a	11044.0
4	1489.0	865.0	2678.0	4900.0	0.0	-58.0	-26.0	404.0	657.0	1105.0	-273.0	n/a	11741.0
5	1606.0	933.0	2890.0	5308.0	0.0	-47.0	-24.0	467.0	737.0	1207.0	-594.0	n/a	12483.0
6	1685.0	967.0	3113.0	5709.0	0.0	-32.0	20.0	403.0	574.0	1122.0	-896.0	n/a	12665.0
7	1652.0	950.0	3063.0	5641.0	0.0	-38.0	-28.0	n/a	n/a	1109.0	-928.0	n/a	11421.0
8	1546.0	869.0	2897.0	5419.0	0.0	-79.0	-66.0	n/a	n/a	1364.0	-565.0	n/a	11385.0
9	1546.0	877.0	2873.0	5327.0	0.0	-108.0	-75.0	246.0	472.0	1299.0	-642.0	n/a	11815.0
10	1298.0	743.0	2444.0	4488.0	0.0	-123.0	-105.0	400.0	668.0	1126.0	-394.0	n/a	10545.0
11	1428.0	777.0	2483.0	4663.0	0.0	-91.0	-81.0	367.0	627.0	1067.0	-152.0	n/a	11088.0
12	1646.0	918.0	2819.0	5256.0	0.0	-74.0	-30.0	438.0	749.0	1252.0	-492.0	n/a	12482.0
13	1754.0	957.0	3026.0	5617.0	0.0	-35.0	4.0	538.0	748.0	1162.0	-818.0	n/a	12953.0
14	1736.0	866.0	3115.0	5811.0	0.0	9.0	48.0	492.0	740.0	1150.0	-849.0	n/a	13118.0
15	1778.0	948.0	3136.0	5899.0	0.0	-57.0	-35.0	530.0	841.0	1387.0	-721.0	n/a	13706.0
16	1927.0	1074.0	3337.0	6188.0	0.0	-61.0	-30.0	572.0	887.0	1442.0	-718.0	n/a	14618.0
17	2110.0	1137.0	3250.0	6145.0	0.0	2.0	35.0	610.0	910.0	1486.0	-913.0	n/a	14772.0
18	2060.0	1117.0	3475.0	6457.0	0.0	-52.0	-9.0	593.0	893.0	1457.0	-761.0	n/a	15230.0
19	2146.0	1148.0	3704.0	6806.0	0.0	-6.0	3.0	550.0	860.0	1405.0	-678.0	n/a	15938.0
20	2327.0	1273.0	3929.0	7173.0	0.0	29.0	64.0	607.0	897.0	1417.0	-954.0	n/a	16762.0
21	1887.0	984.0	3308.0	6021.0	0.0	-15.0	16.0	485.0	694.0	1071.0	-803.0	n/a	13648.0
22	1730.0	908.0	3143.0	5806.0	0.0	-66.0	-48.0	502.0	779.0	1300.0	-615.0	n/a	13439.0
23	1448.0	813.0	2541.0	4605.0	0.0	-73.0	-35.0	380.0	611.0	1052.0	-420.0	n/a	10922.0
24	1568.0	832.0	2733.0	5009.0	0.0	-95.0	-62.0	441.0	686.0	1151.0	-529.0	n/a	11734.0
25	1765.0	964.0	3019.0	5495.0	0.0	-24.0	14.0	448.0	700.0	1210.0	-328.0	n/a	13263.0
26	1835.0	1017.0	3075.0	5638.0	0.0	-53.0	-4.0	505.0	758.0	1281.0	-488.0	n/a	13564.0
27	1385.0	762.0	2484.0	4469.0	0.0	-29.0	7.0	329.0	507.0	848.0	-437.0	n/a	10325.0
28	1434.0	805.0	2713.0	4924.0	0.0	-34.0	12.0	388.0	543.0	828.0	-672.0	n/a	10941.0
29	1526.0	887.0	3171.0	5642.0	0.0	36.0	96.0	381.0	640.0	1082.0	-331.0	n/a	13130.0
30	1867.0	1014.0	3246.0	5940.0	0.0	-91.0	-66.0	525.0	760.0	1213.0	-579.0	n/a	13829.0
31													
Monthly Total	50,170.00	27,776.00	89,055.00	163,890.00	0.00	-1,500.00	-539.00	12,723.00	19,730.00	35,520.00	-17,591.00	0.00	379,234.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202007 Date: 2021-01-27
Page: 1 of 1

Date: Jul-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	2278.0	1251.0	3661.0	6598.0	0.0	-25.0	-14.0	440.0	807.0	1323.0	-643.0	n/a	15676.0
2	2079.0	1134.0	3517.0	6384.0	0.0	-19.0	-2.0	510.0	819.0	1369.0	-580.0	n/a	15211.0
3	2281.0	1276.0	3838.0	6981.0	0.0	11.0	47.0	558.0	845.0	1305.0	-1109.0	n/a	16033.0
4	2239.0	1254.0	3804.0	6986.0	0.0	7.0	26.0	551.0	826.0	1259.0	-1135.0	n/a	15817.0
5	2292.0	1251.0	3922.0	7214.0	0.0	9.0	25.0	578.0	851.0	1278.0	-1118.0	n/a	16302.0
6	2396.0	1306.0	3991.0	7286.0	0.0	2.0	31.0	580.0	940.0	1564.0	-725.0	n/a	17371.0
7	2140.0	1171.0	3629.0	6663.0	0.0	-111.0	-68.0	591.0	917.0	1533.0	-812.0	n/a	15653.0
8	1516.0	870.0	3185.0	5579.0	0.0	-43.0	-9.0	460.0	724.0	1202.0	-459.0	n/a	13025.0
9	2023.0	1137.0	3603.0	6334.0	0.0	-71.0	-31.0	535.0	821.0	1326.0	-613.0	n/a	15064.0
10	1869.0	1051.0	3155.0	5657.0	0.0	-78.0	-54.0	417.0	724.0	1208.0	-414.0	n/a	13535.0
11	1531.0	858.0	2764.0	4892.0	0.0	1.0	33.0	318.0	515.0	832.0	-400.0	n/a	11344.0
12	1706.0	939.0	3152.0	5621.0	0.0	20.0	92.0	415.0	474.0	747.0	-410.0	n/a	12756.0
13	1801.0	957.0	3244.0	5784.0	0.0	-14.0	43.0	406.0	696.0	1146.0	-176.0	n/a	13887.0
14	1773.0	946.0	3248.0	5897.0	0.0	-53.0	4.0	467.0	756.0	1239.0	-321.0	n/a	13956.0
15	1995.0	1130.0	3497.0	6267.0	0.0	-54.0	4.0	509.0	800.0	1318.0	-364.0	n/a	15102.0
16	1555.0	872.0	2648.0	4758.0	0.0	-97.0	-43.0	378.0	634.0	1080.0	-186.0	n/a	11599.0
17	1671.0	921.0	2890.0	5173.0	0.0	-80.0	-32.0	462.0	692.0	1143.0	-408.0	n/a	12432.0
18	2010.0	1143.0	3361.0	6008.0	0.0	15.0	66.0	448.0	649.0	982.0	-648.0	n/a	14034.0
19	1763.0	1016.0	3007.0	5365.0	0.0	-5.0	35.0	387.0	566.0	883.0	-610.0	n/a	12407.0
20	1247.0	649.0	2450.0	4417.0	0.0	-57.0	-13.0	361.0	590.0	989.0	-297.0	n/a	10336.0
21	1396.0	754.0	2640.0	4717.0	0.0	-88.0	-55.0	402.0	613.0	1016.0	-314.0	n/a	11081.0
22	1502.0	838.0	2767.0	4946.0	0.0	-40.0	-1.0	365.0	618.0	1048.0	-316.0	n/a	11727.0
23	1557.0	870.0	2830.0	5106.0	0.0	-44.0	-1.0	426.0	681.0	1109.0	-395.0	n/a	12139.0
24	1646.0	919.0	3029.0	5532.0	0.0	-57.0	-10.0	497.0	791.0	1299.0	-286.0	n/a	13360.0
25	1756.0	977.0	3162.0	5804.0	0.0	-72.0	-20.0	542.0	763.0	1187.0	-856.0	n/a	13243.0
26	1849.0	1041.0	3292.0	5986.0	0.0	-22.0	3.0	496.0	727.0	1089.0	-721.0	n/a	13740.0
27	1775.0	988.0	3129.0	5720.0	0.0	-70.0	-47.0	497.0	812.0	1367.0	-444.0	n/a	13727.0
28	1794.0	983.0	3296.0	6092.0	0.0	-78.0	-58.0	591.0	913.0	1436.0	-372.0	n/a	14597.0
29	1583.0	899.0	2972.0	5414.0	0.0	-48.0	-14.0	448.0	726.0	1239.0	-421.0	n/a	12798.0
30	1725.0	981.0	3071.0	5624.0	0.0	-4.0	17.0	434.0	715.0	1217.0	-177.0	n/a	13603.0
31	1563.0	866.0	2982.0	5616.0	0.0	17.0	30.0	422.0	689.0	1137.0	-328.0	n/a	12994.0
Monthly Total	56,311.00	31,248.00	99,736.00	180,421.00	0.00	-1,148.00	-16.00	14,491.00	22,694.00	36,870.00	-16,058.00	n/a	424,549.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202008 Date: 2021-01-27
Page: 1 of 1

Date: Aug-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	1415.0	805.0	2666.0	4857.0	0.0	-7.0	23.0	359.0	576.0	916.0	-548.0	n/a	11062.0
2	1184.0	705.0	2329.0	4168.0	0.0	-18.0	21.0	281.0	467.0	751.0	-494.0	n/a	9394.0
3	1365.0	781.0	2502.0	4510.0	0.0	-51.0	-20.0	330.0	538.0	857.0	-432.0	n/a	10380.0
4	1306.0	754.0	2361.0	4272.0	0.0	-74.0	-38.0	299.0	541.0	933.0	-96.0	n/a	10258.0
5	1354.0	795.0	2510.0	4570.0	0.0	-92.0	-58.0	411.0	656.0	1172.0	-91.0	n/a	11227.0
6	1376.0	797.0	2563.0	4697.0	0.0	-79.0	-46.0	435.0	730.0	1268.0	149.0	n/a	11890.0
7	1525.0	859.0	2816.0	5131.0	0.0	-45.0	40.0	435.0	697.0	1166.0	-224.0	n/a	12400.0
8	1787.0	1041.0	3134.0	5641.0	0.0	-16.0	59.0	451.0	671.0	1066.0	-627.0	n/a	13207.0
9	1645.0	942.0	3099.0	5694.0	0.0	1.0	45.0	438.0	662.0	1013.0	-702.0	n/a	12837.0
10	1490.0	795.0	2855.0	5395.0	0.0	-90.0	11.0	476.0	746.0	1231.0	-565.0	n/a	12344.0
11	1729.0	961.0	3078.0	5714.0	0.0	-158.0	-15.0	537.0	820.0	1332.0	-796.0	n/a	13202.0
12	1961.0	1138.0	3350.0	6155.0	0.0	-118.0	-5.0	558.0	858.0	1388.0	-788.0	n/a	14497.0
13	2103.0	1227.0	3453.0	6448.0	0.0	-98.0	-13.0	529.0	817.0	1328.0	-682.0	n/a	15112.0
14	1980.0	1144.0	3276.0	6142.0	0.0	-69.0	n/a	521.0	814.0	1322.0	-803.0	n/a	14327.0
15	1819.0	1051.0	3224.0	5952.0	0.0	-27.0	n/a	468.0	710.0	1095.0	-662.0	n/a	13630.0
16	1246.0	705.0	2440.0	4495.0	0.0	-76.0	28.0	409.0	581.0	893.0	-759.0	n/a	9962.0
17	1420.0	796.0	2550.0	4656.0	0.0	-76.0	-50.0	379.0	622.0	1045.0	-337.0	n/a	11005.0
18	1676.0	957.0	2904.0	5336.0	0.0	-2.0	94.0	394.0	635.0	1029.0	-405.0	n/a	12618.0
19	2010.0	1186.0	3253.0	5917.0	0.0	-81.0	125.0	438.0	732.0	1211.0	-513.0	n/a	14278.0
20	2203.0	1326.0	3426.0	6287.0	0.0	19.0	58.0	417.0	704.0	1168.0	-330.0	n/a	15278.0
21	2213.0	1307.0	3581.0	6455.0	0.0	-13.0	36.0	437.0	752.0	1260.0	-319.0	n/a	15709.0
22	2269.0	1346.0	3687.0	6615.0	0.0	-9.0	38.0	528.0	789.0	1249.0	-743.0	n/a	15769.0
23	2235.0	1322.0	3668.0	6632.0	0.0	-5.0	46.0	507.0	758.0	1199.0	-760.0	n/a	15602.0
24	2248.0	1303.0	3553.0	6384.0	0.0	-65.0	-40.0	458.0	760.0	1268.0	-314.0	n/a	15555.0
25	2186.0	1272.0	3455.0	6123.0	0.0	-80.0	-57.0	466.0	727.0	1193.0	-284.0	n/a	15001.0
26	1970.0	1208.0	3081.0	5452.0	0.0	-59.0	-65.0	383.0	653.0	1093.0	-247.0	n/a	13469.0
27	1819.0	1118.0	2941.0	5261.0	0.0	-110.0	-93.0	368.0	659.0	1107.0	-81.0	n/a	12989.0
28	1665.0	999.0	2704.0	4749.0	0.0	-111.0	-94.0	381.0	593.0	962.0	-325.0	n/a	11523.0
29	1655.0	1007.0	2741.0	4777.0	0.0	31.0	48.0	243.0	472.0	803.0	-218.0	n/a	11559.0
30	1734.0	1035.0	2865.0	4971.0	0.0	-5.0	10.0	341.0	522.0	827.0	-444.0	n/a	11856.0
31	1837.0	954.0	3015.0	5249.0	0.0	19.0	39.0	310.0	591.0	1022.0	-30.0	n/a	13006.0
Monthly Total	54,425.00	31,636.00	93,080.00	168,705.00	0.00	-1,564.00	127.00	12,987.00	20,853.00	34,167.00	-13,470.00	n/a	400,946.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202009 Date: 2021-01-27
Page: 1 of 1

Date: Sep-20

Day of the Month	MCT01 <i>m3</i>	MCT02 <i>m3</i>	MCT03 <i>m3</i>	MCT04 <i>m3</i>	MCT05 <i>m3</i>	MCT06 <i>m3</i>	MCT07 <i>m3</i>	MCT08 <i>m3</i>	MCT09 <i>m3</i>	MCT10 <i>m3</i>	MCT11 <i>m3</i>	MCT12 <i>m3</i>	System Total <i>m3</i>
1	1960.0	1128.0	3056.0	5321.0	0.0	-50.0	-16.0	334.0	598.0	992.0	-205.0	n/a	13118.0
2	1805.0	1115.0	2838.0	4935.0	0.0	-37.0	-7.0	315.0	570.0	963.0	-41.0	n/a	12456.0
3	1951.0	1197.0	3001.0	5218.0	0.0	0.0	29.0	310.0	574.0	971.0	-14.0	n/a	13237.0
4	1974.0	1084.0	3102.0	5410.0	0.0	3.0	25.0	373.0	609.0	1007.0	-267.0	n/a	13320.0
5	1837.0	1046.0	2968.0	5190.0	0.0	22.0	40.0	348.0	526.0	832.0	-482.0	n/a	12327.0
6	1842.0	1044.0	2952.0	5118.0	0.0	21.0	43.0	336.0	496.0	768.0	-538.0	n/a	12082.0
7	1392.0	810.0	2548.0	4596.0	0.0	29.0	50.0	278.0	470.0	736.0	-379.0	n/a	10530.0
8	1610.0	958.0	2590.0	4552.0	0.0	-12.0	11.0	280.0	487.0	828.0	-152.0	n/a	11152.0
9	1703.0	1044.0	2677.0	4684.0	0.0	-13.0	11.0	287.0	520.0	879.0	-57.0	n/a	11735.0
10	1636.0	1026.0	2590.0	4544.0	0.0	-47.0	-15.0	281.0	505.0	854.0	-120.0	n/a	11254.0
11	1686.0	1025.0	2680.0	4701.0	0.0	-31.0	-5.0	312.0	516.0	873.0	-149.0	n/a	11608.0
12	1724.0	1042.0	2819.0	4954.0	0.0	-10.0	2.0	304.0	487.0	763.0	-370.0	n/a	11715.0
13	1748.0	1073.0	2842.0	4942.0	0.0	30.0	50.0	256.0	458.0	715.0	-438.0	n/a	11676.0
14	1792.0	1109.0	2807.0	4880.0	0.0	-16.0	6.0	323.0	568.0	949.0	-159.0	n/a	12259.0
15	1814.0	1106.0	2809.0	4899.0	0.0	-11.0	10.0	330.0	561.0	941.0	-132.0	n/a	12327.0
16	1856.0	1135.0	2894.0	5066.0	0.0	-21.0	7.0	325.0	574.0	974.0	-135.0	n/a	12675.0
17	1814.0	1131.0	2804.0	4936.0	0.0	-25.0	6.0	332.0	571.0	949.0	-144.0	n/a	12374.0
18	1719.0	1046.0	2727.0	4806.0	0.0	-26.0	-5.0	305.0	533.0	884.0	-185.0	n/a	11804.0
19	1799.0	1081.0	2889.0	5082.0	0.0	-5.0	17.0	323.0	504.0	777.0	-432.0	n/a	12035.0
20	1865.0	1136.0	2998.0	5269.0	0.0	14.0	38.0	324.0	513.0	771.0	-530.0	n/a	12398.0
21	1835.0	1147.0	2982.0	5209.0	0.0	11.0	32.0	319.0	576.0	951.0	-178.0	n/a	12884.0
22	1804.0	1091.0	2888.0	5112.0	0.0	-16.0	1.0	364.0	590.0	943.0	-279.0	n/a	12498.0
23	1868.0	1117.0	2961.0	5207.0	0.0	-15.0	14.0	350.0	601.0	1004.0	-251.0	n/a	12856.0
24	1827.0	1127.0	2902.0	5114.0	0.0	-10.0	15.0	359.0	601.0	983.0	-299.0	n/a	12619.0
25	1855.0	1116.0	2946.0	5213.0	0.0	-14.0	9.0	355.0	608.0	990.0	-300.0	n/a	12778.0
26	1890.0	1135.0	3074.0	5381.0	0.0	27.0	39.0	352.0	549.0	853.0	-494.0	n/a	12806.0
27	1836.0	1125.0	3007.0	5250.0	0.0	3.0	21.0	330.0	516.0	771.0	-542.0	n/a	12317.0
28	1630.0	1010.0	2647.0	4450.0	0.0	-29.0	-12.0	308.0	540.0	884.0	-258.0	n/a	11170.0
29	1560.0	957.0	2588.0	4491.0	0.0	-22.0	-5.0	325.0	537.0	884.0	-249.0	n/a	11066.0
30	1615.0	992.0	2613.0	4532.0	0.0	-17.0	3.0	317.0	545.0	909.0	-233.0	n/a	11276.0
31													
Monthly Total	53,247.00	32,153.00	85,199.00	149,062.00	0.00	-267.00	414.00	9,655.00	16,303.00	26,598.00	-8,012.00	0.00	364,352.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202010 Date: 2021-01-27
Page: 1 of 1

Date: Oct-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	1495.0	933.0	2439.0	4266.0	0.0	-32.0	-14.0	322.0	519.0	843.0	-199.0	n/a	10572.0
2	1612.0	976.0	2576.0	4476.0	0.0	-4.0	12.0	297.0	493.0	810.0	-190.0	n/a	11058.0
3	1564.0	934.0	2604.0	4558.0	0.0	13.0	28.0	299.0	446.0	680.0	-487.0	n/a	10639.0
4	1545.0	936.0	2570.0	4467.0	0.0	7.0	24.0	279.0	431.0	622.0	-611.0	n/a	10270.0
5	1500.0	921.0	2505.0	4389.0	0.0	-10.0	7.0	300.0	487.0	796.0	-260.0	n/a	10635.0
6	1576.0	957.0	2575.0	4496.0	0.0	-18.0	-3.0	283.0	497.0	810.0	-165.0	n/a	11008.0
7	1675.0	1028.0	2687.0	4684.0	0.0	-37.0	-16.0	354.0	576.0	968.0	-277.0	n/a	11642.0
8	1644.0	1023.0	2653.0	4631.0	0.0	-34.0	-19.0	358.0	554.0	890.0	-271.0	n/a	11429.0
9	1524.0	910.0	2566.0	4502.0	0.0	-4.0	14.0	312.0	508.0	859.0	-268.0	n/a	10923.0
10	1677.0	1011.0	2811.0	4885.0	0.0	8.0	17.0	307.0	475.0	705.0	-603.0	n/a	11293.0
11	1558.0	932.0	2622.0	4564.0	0.0	11.0	33.0	287.0	428.0	683.0	-541.0	n/a	10577.0
12	1620.0	982.0	2686.0	4655.0	0.0	13.0	28.0	269.0	446.0	695.0	-545.0	n/a	10849.0
13	1352.0	824.0	2323.0	4080.0	0.0	-34.0	-18.0	282.0	459.0	762.0	-197.0	n/a	9833.0
14	1398.0	852.0	2368.0	4161.0	0.0	-16.0	-2.0	246.0	455.0	767.0	-151.0	n/a	10078.0
15	1424.0	281.0	2345.0	4106.0	0.0	-27.0	-14.0	288.0	459.0	769.0	-281.0	n/a	9350.0
16	1356.0	n/a	2308.0	4026.0	0.0	-26.0	-9.0	249.0	422.0	721.0	-217.0	n/a	8830.0
17	1372.0	n/a	2372.0	4158.0	0.0	-6.0	8.0	243.0	401.0	634.0	-437.0	n/a	8745.0
18	1191.0	n/a	2207.0	3923.0	0.0	-31.0	-9.0	272.0	402.0	608.0	-558.0	n/a	8005.0
19	1252.0	n/a	2164.0	3816.0	0.0	-37.0	-22.0	237.0	386.0	690.0	-141.0	n/a	8345.0
20	1209.0	n/a	2104.0	3794.0	0.0	-132.0	-114.0	414.0	-73.0	400.0	521.0	n/a	8123.0
21	1155.0	n/a	2061.0	3697.0	0.0	-64.0	-42.0	243.0	454.0	756.0	-203.0	n/a	8057.0
22	1145.0	n/a	2046.0	3639.0	0.0	-47.0	-34.0	238.0	422.0	700.0	-206.0	n/a	7903.0
23	1167.0	n/a	2073.0	3690.0	0.0	-57.0	-39.0	216.0	421.0	687.0	-231.0	n/a	7927.0
24	1166.0	n/a	2175.0	3769.0	0.0	-12.0	-2.0	253.0	400.0	610.0	-471.0	n/a	7888.0
25	1038.0	n/a	2075.0	3624.0	0.0	-23.0	3.0	247.0	392.0	574.0	-547.0	n/a	7383.0
26	1085.0	n/a	2019.0	3533.0	0.0	-64.0	-35.0	258.0	431.0	694.0	-157.0	12.0	7776.0
27	1099.0	n/a	2024.0	3584.0	0.0	-68.0	-55.0	245.0	438.0	730.0	-40.0	n/a	7957.0
28	1084.0	n/a	2017.0	3597.0	0.0	-56.0	-44.0	245.0	434.0	718.0	-58.0	n/a	7937.0
29	1164.0	471.0	2058.0	3663.0	0.0	-84.0	-33.0	279.0	478.0	777.0	-137.0	n/a	8636.0
30	1119.0	697.0	2029.0	3621.0	0.0	-79.0	-5.0	258.0	384.0	632.0	-21.0	n/a	8635.0
31	1175.0	727.0	2194.0	3838.0	0.0	-34.0	29.0	259.0	416.0	691.0	-235.0	n/a	9060.0
Monthly Total	41,941.00	15,395.00	72,256.00	126,892.00	0.00	-984.00	-326.00	8,639.00	13,441.00	22,281.00	-8,184.00	12.00	291,363.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202011 Date: 2021-01-27
Page: 1 of 1

Date: Nov-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	1177.0	734.0	2266.0	3949.0	0.0	-45.0	26.0	297.0	430.0	732.0	-344.0	n/a	9222.0
2	1140.0	717.0	2090.0	3687.0	0.0	-66.0	8.0	281.0	448.0	776.0	-119.0	n/a	8962.0
3	1131.0	702.0	2032.0	3632.0	0.0	-85.0	-12.0	263.0	476.0	818.0	-73.0	n/a	8884.0
4	1110.0	685.0	2040.0	3609.0	0.0	-71.0	2.0	250.0	469.0	791.0	-89.0	n/a	8796.0
5	1281.0	790.0	2184.0	3758.0	0.0	-31.0	31.0	232.0	426.0	685.0	1.0	n/a	9357.0
6	1081.0	660.0	1996.0	3542.0	0.0	-52.0	18.0	236.0	404.0	666.0	52.0	n/a	8603.0
7	1117.0	678.0	2115.0	3711.0	0.0	-12.0	56.0	207.0	374.0	569.0	-118.0	n/a	8697.0
8	1130.0	691.0	2167.0	3769.0	0.0	-7.0	61.0	206.0	374.0	541.0	-277.0	n/a	8655.0
9	1071.0	667.0	1990.0	3505.0	0.0	-55.0	13.0	198.0	423.0	696.0	163.0	n/a	8671.0
10	963.0	599.0	1875.0	3360.0	0.0	-61.0	6.0	206.0	442.0	739.0	170.0	n/a	8299.0
11	1030.0	648.0	2019.0	3536.0	0.0	-39.0	32.0	195.0	397.0	670.0	135.0	n/a	8623.0
12	1021.0	645.0	2011.0	3516.0	0.0	-45.0	31.0	234.0	475.0	846.0	334.0	n/a	9068.0
13	1075.0	671.0	1981.0	3479.0	0.0	-18.0	53.0	169.0	355.0	592.0	-37.0	n/a	8320.0
14	1083.0	661.0	2082.0	3665.0	0.0	-13.0	52.0	193.0	339.0	516.0	-303.0	n/a	8275.0
15	1067.0	652.0	2089.0	3653.0	0.0	-6.0	61.0	193.0	336.0	486.0	-448.0	n/a	8083.0
16	1144.0	711.0	2077.0	3661.0	0.0	-35.0	32.0	181.0	367.0	593.0	-113.0	n/a	8618.0
17	1050.0	653.0	1950.0	3475.0	0.0	-60.0	7.0	186.0	364.0	589.0	-115.0	n/a	8099.0
18	1112.0	683.0	2016.0	3569.0	0.0	-68.0	2.0	225.0	390.0	626.0	-81.0	n/a	8474.0
19	1426.0	884.0	2344.0	4029.0	0.0	-32.0	37.0	195.0	367.0	601.0	-37.0	n/a	9814.0
20	1150.0	708.0	2038.0	3593.0	0.0	-44.0	27.0	183.0	343.0	566.0	-38.0	n/a	8526.0
21	1075.0	653.0	2075.0	3652.0	0.0	-10.0	55.0	210.0	340.0	509.0	-318.0	n/a	8241.0
22	1045.0	632.0	2057.0	3582.0	0.0	3.0	69.0	195.0	325.0	528.0	-337.0	n/a	8099.0
23	974.0	601.0	1892.0	3341.0	0.0	-65.0	5.0	211.0	371.0	618.0	-84.0	n/a	7864.0
24	1053.0	648.0	1949.0	3419.0	0.0	-33.0	33.0	170.0	341.0	567.0	-3.0	n/a	8144.0
25	1046.0	647.0	1944.0	3423.0	0.0	-50.0	21.0	191.0	363.0	598.0	9.0	n/a	8192.0
26	1003.0	618.0	1912.0	3371.0	0.0	-89.0	-13.0	206.0	362.0	592.0	-78.0	n/a	7884.0
27	1086.0	666.0	1952.0	3439.0	0.0	-90.0	-21.0	253.0	396.0	619.0	-214.0	n/a	8086.0
28	1082.0	657.0	2069.0	3599.0	0.0	-7.0	62.0	184.0	322.0	472.0	-294.0	n/a	8146.0
29	1124.0	682.0	2130.0	3682.0	0.0	1.0	69.0	189.0	319.0	472.0	-360.0	n/a	8308.0
30	1105.0	681.0	1993.0	3503.0	0.0	-43.0	28.0	175.0	350.0	566.0	-114.0	n/a	8244.0
31													
Monthly Total	32,952.00	20,324.00	61,335.00	107,709.00	0.00	-1,228.00	851.00	6,314.00	11,488.00	18,639.00	-3,130.00	0.00	255,254.00

NETFlowTotal

Monthly Report Meter Chamber Flow Totals (NET)

Town of Tecumseh Water System
Report Name: 202012 Date: 2021-01-27
Page: 1 of 1

Date: Dec-20

Day of the Month	MCT01 m3	MCT02 m3	MCT03 m3	MCT04 m3	MCT05 m3	MCT06 m3	MCT07 m3	MCT08 m3	MCT09 m3	MCT10 m3	MCT11 m3	MCT12 m3	System Total m3
1	1084.0	666.0	1965.0	3433.0	0.0	-45.0	24.0	181.0	355.0	571.0	-67.0	n/a	8167.0
2	1121.0	696.0	2036.0	3574.0	0.0	-38.0	29.0	176.0	358.0	581.0	21.0	n/a	8554.0
3	1114.0	686.0	2007.0	3539.0	0.0	-49.0	19.0	185.0	385.0	620.0	-43.0	n/a	8463.0
4	1101.0	673.0	1973.0	3489.0	0.0	-50.0	16.0	175.0	386.0	611.0	-73.0	n/a	8301.0
5	1104.0	664.0	2100.0	3672.0	0.0	-13.0	52.0	201.0	340.0	503.0	-282.0	n/a	8341.0
6	1025.0	615.0	2045.0	3577.0	0.0	8.0	72.0	178.0	325.0	470.0	-295.0	n/a	8020.0
7	1096.0	674.0	1997.0	3503.0	0.0	-44.0	21.0	199.0	385.0	631.0	-85.0	n/a	8377.0
8	1058.0	652.0	1968.0	3482.0	0.0	-51.0	19.0	203.0	387.0	633.0	8.0	n/a	8359.0
9	972.0	598.0	1891.0	3392.0	0.0	-50.0	19.0	177.0	361.0	594.0	-24.0	n/a	7930.0
10	1028.0	631.0	1935.0	3450.0	0.0	-73.0	0.0	198.0	362.0	569.0	-27.0	n/a	8073.0
11	1004.0	619.0	1924.0	3435.0	0.0	-63.0	8.0	121.0	325.0	523.0	45.0	n/a	7941.0
12	948.0	613.0	2083.0	3643.0	0.0	-1.0	56.0	142.0	341.0	487.0	-282.0	n/a	8030.0
13	1041.0	631.0	2061.0	3602.0	0.0	-10.0	56.0	190.0	325.0	451.0	-363.0	n/a	7984.0
14	1095.0	676.0	2004.0	3514.0	0.0	-40.0	27.0	165.0	354.0	556.0	-22.0	n/a	8329.0
15	1061.0	644.0	1959.0	3450.0	0.0	-54.0	17.0	174.0	350.0	559.0	-18.0	n/a	8142.0
16	976.0	597.0	1880.0	3325.0	0.0	-52.0	18.0	161.0	346.0	556.0	37.0	n/a	7844.0
17	1029.0	633.0	1930.0	3473.0	0.0	-48.0	22.0	155.0	336.0	541.0	43.0	n/a	8114.0
18	988.0	604.0	1897.0	3365.0	0.0	-55.0	16.0	173.0	342.0	529.0	-61.0	n/a	7798.0
19	1018.0	612.0	2033.0	3585.0	0.0	-9.0	52.0	174.0	316.0	451.0	-252.0	n/a	7980.0
20	1312.0	803.0	2317.0	3974.0	0.0	28.0	87.0	187.0	315.0	433.0	-302.0	n/a	9154.0
21	946.0	574.0	1877.0	3364.0	0.0	-44.0	26.0	172.0	348.0	549.0	-20.0	n/a	7792.0
22	849.0	516.0	1778.0	3244.0	0.0	-43.0	33.0	164.0	344.0	559.0	28.0	n/a	7472.0
23	735.0	444.0	1686.0	3106.0	0.0	-56.0	12.0	167.0	339.0	538.0	-95.0	n/a	6876.0
24	757.0	446.0	1757.0	3201.0	0.0	-32.0	36.0	153.0	322.0	480.0	-229.0	n/a	6891.0
25	683.0	409.0	1624.0	2945.0	0.0	-19.0	49.0	153.0	300.0	427.0	-351.0	n/a	6220.0
26	711.0	418.0	1682.0	3043.0	0.0	-20.0	48.0	159.0	306.0	441.0	-344.0	n/a	6444.0
27	697.0	415.0	1693.0	3065.0	0.0	-31.0	45.0	169.0	309.0	449.0	-308.0	n/a	6503.0
28	677.0	402.0	1643.0	3010.0	0.0	-20.0	46.0	154.0	321.0	479.0	-246.0	n/a	6466.0
29	662.0	398.0	1618.0	2975.0	0.0	-21.0	46.0	139.0	322.0	500.0	-208.0	n/a	6431.0
30	662.0	392.0	1611.0	2964.0	0.0	-23.0	41.0	148.0	321.0	498.0	-252.0	n/a	6362.0
31	670.0	395.0	1655.0	3046.0	0.0	-29.0	38.0	162.0	324.0	477.0	-342.0	n/a	6396.0
Monthly Total	29,224.00	17,796.00	58,629.00	104,440.00	0.00	-1,047.00	1,050.00	5,255.00	10,550.00	16,266.00	-4,409.00	n/a	237,754.00

NETFlowTotal