



WATER NOTES:

1. DOMESTIC WATER SERVICE SHALL BE MUNICIPEX PIPE INSTALLED WITH 1.5m MINIMUM CLEAR COVER.
2. CONTRACTOR TO PERFORM ALL WORKS IN ACCORDANCE WITH THE LATEST VERSION OF THE TOWN OF TECUMSEH WATER STANDARDS.
3. ALL PROPOSED WATERMAIN/SERVICE CONNECTION MATERIALS TO BE IN ACCORDANCE WITH THE LATEST VERSION OF THE TOWN OF TECUMSEH WATER STANDARDS.
4. A LICENSED WATER OPERATOR FROM THE TOWN OF TECUMSEH MUST BE ON SITE AT ALL TIMES WHEN WATER SERVICE MAIN WORK IS PERFORMED.
5. CONTRACTOR TO PROVIDE THIRD PARTY TO PERFORM LIVE TAP OF THE EXISTING WATERMAIN AND WORK SHALL BE CARRIED OUT IN ACCORDANCE WITH THE TOWN OF TECUMSEH STANDARDS AND SPECIFICATIONS.
6. ALL FLUSHING/BACTERIA/PRESSURE TESTING TO BE COMPLETED BY TOWN OF TECUMSEH.
7. ALL MATERIALS INSTALLED UNDERGROUND THAT MAY CORRODE MUST BE WRAPPED WITH DENSOPASTE/FILLERWRAP.
8. PROVIDE A MINIMUM OF 2 BUSINESS DAYS NOTICE TO THE WATER DEPARTMENT BEFORE ANY WATER WORK BEGINS.
9. A WATER PERMIT IS REQUIRED WITH FINAL WATER DRAWINGS (THAT HAVE BEEN APPROVED BY THE WATER DIVISION).
10. A WATER INSPECTION FEE INVOICED TO THE CONTRACTOR WILL BE SENT AT THE END OF THE PROJECT (\$10 PER METRE OF WATERMAIN INSTALLED/INSPECTED).

2021/03/05 REVISED FOR PERMIT
2021/02/26 REVISED FOR PERMIT

2020/10/06 PERMIT

date (yyy/mm/dd): issued for:

general notes:

1. THIS PRINT IS AN INSTRUMENT OF SERVICE ONLY AND IS THE PROPERTY OF THE ARCHITECT.
2. DRAWINGS SHALL NOT BE SCALED.
3. CONTRACTORS SHALL VERIFY AND BE RESPONSIBLE FOR ALL DIMENSIONS AND CONDITIONS ON THE JOB AND THIS OFFICE MUST BE NOTIFIED OF ANY VARIATIONS FROM THE DIMENSIONS AND CONDITIONS SHOWN BY THESE DRAWINGS.
4. ATTENTION IS DIRECTED TO PROVISIONS IN THE GENERAL CONDITIONS REGARDING CONTRACTOR'S RESPONSIBILITIES IN REGARD TO SUBMISSION OF SHOP DRAWINGS.
5. IN THE EVENT THE ARCHITECT IS RETAINED TO REVIEW SHOP DRAWINGS, SUCH REVIEW IS ONLY TO CHECK FOR CONFORMANCE WITH DESIGN CONCEPT AND WITH THE INFORMATION GIVEN IN THE CONTRACT DOCUMENTS.
6. CONTRACTORS SHALL PROMPTLY NOTIFY THE ARCHITECT IN WRITING OF THE EXISTENCE OF ANY OBSERVED VARIATIONS BETWEEN THE CONTRACT DOCUMENTS AND ANY APPLICABLE CODES OR BY-LAWS.
7. THE ARCHITECT IS NOT RESPONSIBLE FOR THE MEANS, METHODS OR TECHNIQUES IN THE CONSTRUCTION OF THIS FACILITY.

stamp:



project:
PROPOSED 2-STOREY
OFFICE / INDUSTRIAL
5205 8TH CONCESSION ROAD
TOWN OF TECUMSEH, ONT.

client:
EAGLE HEATING & COOLING

title:
SERVICING PLAN

scale:
AS SHOWN

drawn by:
JPA

checked by:
PAA / JPA

date:
AUGUST 2020

proj. no.:
7403

sheet no.:

C1.2