



February 9, 2022

Mr. Enrico De Cecco  
Town of Tecumseh  
917 Lesperance Road  
Tecumseh, Ontario  
N8N 1W2

Dear Mr. De Cecco:

**Re: COA Submissions, D19 6067WA, Revenberg Holdings Ltd.**

---

Please be advised that the County has reviewed the aforementioned application and the comments provided are engineering-related only. This application has not been reviewed from a planning perspective. The subject lands have frontage on County Road No. 11. The Applicant will be required to comply with the following County Road regulations:

County By-Law Number 2481 – A By-Law to Provide for the Protection of Highways and to Provide for the Installation of Entrance Ways.

County By-Law Number 2480 – A By-Law of the Corporation of the County of Essex to Regulate the Location of Buildings and Structures on Land Adjacent to County Roads.

The minimum setback must be 85 feet from the original limit of County Road No. 11. Permits are necessary for any changes to existing entrances and structures, or the construction of new entrances or structures.

No new direct connections will be permitted to County Road drains.

We are requesting a copy of the Decision of the aforementioned applications. Thank you for your assistance and cooperation in this matter.

519-776-6441  
TTY 1-877-624-4832

360 Fairview Ave. W.  
Essex, ON N8M 1Y6

countyofessex.ca

---

Should you require further information, please contact me by email at [kbalallo@countyofessex.ca](mailto:kbalallo@countyofessex.ca) or by phone at extension 1564.

Regards,

Kristoffer Balallo  
Engineering Technologist

 519-776-6441  
TTY 1-877-624-4832

 360 Fairview Ave. W.  
Essex, ON N8M 1Y6

 [countyofessex.ca](http://countyofessex.ca)