

SUMMARY REPORT

For the

TECUMSEH DISTRIBUTION SYSTEM

(260004969)

For the year

2022

Prepared for the Town of Tecumseh

By Brad Dupuis, C.Tech.
Manager Water Services O.R.O.

Table of Contents

<i>Section 1: Overview</i>	<i>3</i>
<i>Section 2: Non-compliance Issues</i>	<i>4</i>
<i>Section 3: System Capability.....</i>	<i>4</i>

Section 1: Overview

This report has been prepared and submitted in accordance with Schedule 22 of O. Reg. 170/03 under the *Safe Drinking Water Act*. Schedule 22 requires:

The owner of a drinking-water system shall ensure that, not later than March 31 of each year after 2003, a report is prepared in accordance with subsections (1) and (2) for the preceding calendar year and is given to the members of the municipal council.

Schedule 22 also states that:

- 1) The report must:
 - a) list the requirements of the *Act*, the regulations, the system's approval and any order that the system failed to meet at any time during the period covered by the report and specify the duration of the failure; and
 - b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.
- 2) The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system. A summary of the quantities of the water supplied during the period covered by the report, including monthly flows.

In June 2003, the provincial *Safe Drinking Water Act* came into effect. The Drinking-Water Systems Regulation (O.Reg. 170/03) defines how various drinking-water systems are to be operated.

According to this Regulation, the Tecumseh Distribution System is classified as a Large Municipal Residential System (LMR).

Section 2: Non-Compliance Issues

1. During the year 2022 there was zero (0) **reportable issues**.

Section 3: System Capability – 2022 Water Consumption

In accordance with the Agreement between the Town of Tecumseh and the City of Windsor for the provision of water services to the Town of Tecumseh, executed under By-Law No. 2004-71, the Maximum Daily Flow shall not exceed **87 Million Litres** (87 MLD) or 87,000 cubic meters.

The **Maximum Daily Flow** for 2022 was 15,661,000 **Litres** (15,661 Cubic Meters) on August 17, 2022.

Monthly average and daily flows for 2022 are attached for reference.

A summary of the **monthly** total volume supplied by the City of Windsor to the Town of Tecumseh is provided below:

2022 Water Consumption	
Month	Total Volume (cubic meters)
January	216,158
February	190,164
March	208,740
April	211,046
May	262,392
June	287,386
July	416,289
August	381,957
September	378,445
October	313,177
November	260,345
December	241,345
Total	3,367,444



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/02/2022 03:26:00 AM

Report Date From: 01/01/2022 12:00:00 AM

To: 01/02/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	655.0	397.0	1600.0	2970.0	0.0	-33.0	41.0	148.0	283.0	313.0	-70.0	0.0	6304.0
2	661.0	407.0	1636.0	3004.0	0.0	-13.0	52.0	158.0	279.0	321.0	-61.0	0.0	6444.0
3	638.0	403.0	1584.0	2948.0	0.0	-44.0	24.0	189.0	353.0	507.0	-28.0	0.0	6574.0
4	664.0	413.0	1580.0	2937.0	0.0	-40.0	26.0	204.0	407.0	670.0	20.0	0.0	6881.0
5	699.0	421.0	1607.0	2966.0	0.0	-30.0	38.0	194.0	396.0	620.0	8.0	0.0	6919.0
6	683.0	418.0	1586.0	2947.0	0.0	-32.0	33.0	188.0	395.0	613.0	9.0	0.0	6840.0
7	668.0	411.0	1580.0	2943.0	0.0	-48.0	18.0	201.0	382.0	572.0	-17.0	0.0	6710.0
8	698.0	414.0	1708.0	3152.0	0.0	-18.0	56.0	177.0	316.0	433.0	-26.0	0.0	6910.0
9	712.0	415.0	1726.0	3207.0	0.0	-24.0	47.0	181.0	309.0	358.0	0.0	0.0	6931.0
10	691.0	420.0	1603.0	3001.0	0.0	-34.0	49.0	159.0	375.0	588.0	10.0	0.0	6862.0
11	781.0	476.0	1671.0	3078.0	0.0	-33.0	56.0	163.0	374.0	574.0	-8.0	0.0	7132.0
12	832.0	509.0	1727.0	3163.0	0.0	-23.0	44.0	187.0	401.0	632.0	9.0	0.0	7481.0
13	801.0	486.0	1710.0	3142.0	0.0	-19.0	43.0	198.0	429.0	707.0	37.0	0.0	7534.0
14	743.0	431.0	1673.0	3109.0	0.0	-13.0	55.0	173.0	383.0	587.0	3.0	0.0	7144.0
15	758.0	454.0	1770.0	3292.0	0.0	-11.0	54.0	174.0	322.0	417.0	-57.0	0.0	7173.0
16	920.0	551.0	1844.0	3342.0	0.0	-11.0	52.0	177.0	333.0	490.0	-45.0	0.0	7653.0
17	734.0	450.0	1634.0	3038.0	0.0	-46.0	20.0	189.0	403.0	669.0	7.0	0.0	7098.0
18	722.0	436.0	1627.0	3014.0	0.0	-42.0	22.0	199.0	415.0	675.0	48.0	0.0	7116.0
19	710.0	439.0	1635.0	3058.0	0.0	-50.0	31.0	199.0	422.0	689.0	19.0	0.0	7152.0
20	730.0	450.0	1630.0	3038.0	0.0	-71.0	-1.0	189.0	418.0	659.0	-3.0	0.0	7039.0
21	726.0	439.0	1621.0	3044.0	0.0	-68.0	9.0	197.0	416.0	655.0	-7.0	0.0	7032.0
22	726.0	431.0	1705.0	3158.0	0.0	-34.0	34.0	182.0	343.0	469.0	-53.0	0.0	6961.0
23	695.0	409.0	1674.0	3120.0	0.0	-34.0	28.0	160.0	333.0	443.0	-54.0	0.0	6774.0
24	699.0	425.0	1592.0	2974.0	0.0	-40.0	23.0	168.0	388.0	616.0	-17.0	0.0	6828.0
25	718.0	445.0	1616.0	3039.0	0.0	-52.0	16.0	183.0	396.0	613.0	7.0	0.0	6981.0
26	693.0	432.0	1611.0	3037.0	0.0	-43.0	25.0	189.0	410.0	658.0	14.0	0.0	7026.0
27	698.0	434.0	1612.0	3031.0	0.0	-44.0	18.0	178.0	426.0	680.0	18.0	0.0	7051.0
28	688.0	427.0	1615.0	3045.0	0.0	-51.0	13.0	129.0	409.0	659.0	12.0	0.0	6946.0
29	702.0	427.0	1711.0	3184.0	0.0	-42.0	25.0	162.0	329.0	434.0	-56.0	0.0	6876.0
30	705.0	424.0	1731.0	3223.0	0.0	-38.0	28.0	162.0	316.0	394.0	-71.0	0.0	6874.0
31	689.0	432.0	1609.0	3021.0	0.0	-79.0	-13.0	185.0	406.0	657.0	5.0	0.0	6912.0
Monthly T...	22239.00	13526.00	51228.00	95225.00	0.00	-1160.00	966.00	5542.00	11567.00	17372.00	-347.00	0.00	216158.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/03/2022 03:26:00 AM

Report Date From: 01/02/2022 12:00:00 AM

To: 01/03/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	689.0	426.0	1576.0	2965.0	0.0	-89.0	-24.0	193.0	411.0	667.0	5.0	0.0	6819.0
2	651.0	391.0	1542.0	2921.0	0.0	-98.0	-37.0	153.0	309.0	542.0	0.0	0.0	6374.0
3	633.0	371.0	1542.0	2903.0	0.0	-60.0	1.0	171.0	389.0	627.0	0.0	0.0	6577.0
4	672.0	401.0	1586.0	2983.0	0.0	-65.0	8.0	184.0	389.0	618.0	6.0	0.0	6782.0
5	725.0	430.0	1716.0	3211.0	0.0	-40.0	33.0	166.0	345.0	489.0	-40.0	0.0	7035.0
6	693.0	396.0	1705.0	3196.0	0.0	-29.0	37.0	169.0	327.0	437.0	-55.0	0.0	6876.0
7	637.0	390.0	1560.0	2970.0	0.0	-81.0	-12.0	183.0	412.0	686.0	31.0	0.0	6776.0
8	652.0	391.0	1544.0	2936.0	0.0	-75.0	-10.0	200.0	431.0	728.0	36.0	0.0	6833.0
9	671.0	397.0	1590.0	3026.0	0.0	-87.0	-19.0	203.0	416.0	670.0	8.0	0.0	6875.0
10	661.0	395.0	1564.0	2995.0	0.0	-85.0	-20.0	213.0	463.0	771.0	22.0	0.0	6979.0
11	657.0	396.0	1561.0	2988.0	0.0	-80.0	-9.0	205.0	412.0	662.0	8.0	0.0	6800.0
12	696.0	403.0	1697.0	3197.0	0.0	-46.0	24.0	174.0	349.0	474.0	-44.0	0.0	6924.0
13	664.0	383.0	1677.0	3153.0	0.0	-40.0	26.0	185.0	343.0	440.0	-67.0	0.0	6764.0
14	665.0	400.0	1588.0	3061.0	0.0	-96.0	-28.0	190.0	412.0	664.0	-2.0	0.0	6854.0
15	673.0	397.0	1572.0	3051.0	0.0	-103.0	-33.0	204.0	416.0	661.0	3.0	0.0	6841.0
16	642.0	377.0	1564.0	3011.0	0.0	-74.0	-7.0	196.0	435.0	740.0	36.0	0.0	6920.0
17	629.0	375.0	1527.0	2918.0	0.0	-66.0	4.0	190.0	430.0	709.0	29.0	0.0	6745.0
18	607.0	365.0	1544.0	2949.0	0.0	-66.0	1.0	180.0	395.0	630.0	20.0	0.0	6625.0
19	654.0	376.0	1663.0	3135.0	0.0	-47.0	25.0	140.0	324.0	465.0	-29.0	0.0	6706.0
20	644.0	380.0	1648.0	3105.0	0.0	-37.0	36.0	137.0	308.0	429.0	-41.0	0.0	6609.0
21	655.0	383.0	1639.0	3099.0	0.0	-49.0	15.0	153.0	352.0	533.0	-17.0	0.0	6763.0
22	677.0	409.0	1594.0	2991.0	0.0	-53.0	15.0	181.0	411.0	675.0	25.0	0.0	6925.0
23	660.0	393.0	1554.0	2924.0	0.0	-55.0	14.0	183.0	414.0	673.0	27.0	0.0	6787.0
24	667.0	401.0	1558.0	2976.0	0.0	-73.0	-5.0	175.0	410.0	680.0	30.0	0.0	6819.0
25	637.0	380.0	1539.0	2948.0	0.0	-81.0	-9.0	190.0	410.0	662.0	15.0	0.0	6691.0
26	689.0	399.0	1692.0	3191.0	0.0	-40.0	25.0	159.0	319.0	427.0	-50.0	0.0	6811.0
27	677.0	401.0	1703.0	3212.0	0.0	-38.0	31.0	171.0	319.0	408.0	-63.0	0.0	6821.0
28	673.0	404.0	1593.0	3021.0	0.0	-84.0	-18.0	194.0	401.0	637.0	12.0	0.0	6833.0
Monthly T...	18550.00	11010.00	44838.00	85036.00	0.00	-1837.00	64.00	5042.00	10752.00	16804.00	-95.00	0.00	190164.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/04/2022 03:26:49 AM

Report Date From: 01/03/2022 12:00:00 AM

To: 01/04/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	651.0	390.0	1563.0	2989.0	0.0	-75.0	-6.0	182.0	409.0	673.0	31.0	0.0	6807.0
2	671.0	403.0	1598.0	3054.0	0.0	-66.0	3.0	158.0	400.0	648.0	17.0	0.0	6886.0
3	699.0	423.0	1609.0	3064.0	0.0	-67.0	4.0	187.0	419.0	684.0	17.0	0.0	7039.0
4	680.0	411.0	1595.0	3038.0	0.0	-62.0	10.0	182.0	399.0	621.0	11.0	0.0	6885.0
5	704.0	407.0	1702.0	3231.0	0.0	-29.0	41.0	176.0	352.0	497.0	-43.0	0.0	7038.0
6	693.0	403.0	1716.0	3214.0	0.0	-29.0	36.0	174.0	336.0	441.0	-53.0	0.0	6931.0
7	664.0	403.0	1592.0	3002.0	0.0	-32.0	34.0	184.0	411.0	663.0	15.0	0.0	6936.0
8	683.0	405.0	1576.0	3009.0	0.0	-59.0	8.0	146.0	352.0	677.0	32.0	0.0	6829.0
9	664.0	397.0	1569.0	2998.0	0.0	-72.0	-5.0	189.0	419.0	678.0	21.0	0.0	6858.0
10	626.0	370.0	1545.0	2951.0	0.0	-66.0	-3.0	191.0	426.0	702.0	36.0	0.0	6778.0
11	659.0	398.0	1558.0	2979.0	0.0	-64.0	8.0	160.0	387.0	608.0	33.0	0.0	6726.0
12	663.0	390.0	1662.0	3125.0	0.0	-24.0	45.0	103.0	331.0	463.0	-35.0	0.0	6723.0
13	570.0	337.0	1554.0	2924.0	0.0	-7.0	54.0	90.0	290.0	411.0	-36.0	0.0	6187.0
14	609.0	377.0	1546.0	2952.0	0.0	-73.0	-10.0	179.0	413.0	647.0	18.0	0.0	6658.0
15	584.0	352.0	1492.0	2871.0	0.0	-76.0	-7.0	174.0	413.0	679.0	29.0	0.0	6511.0
16	595.0	363.0	1530.0	2935.0	0.0	-75.0	-7.0	182.0	415.0	700.0	37.0	0.0	6675.0
17	604.0	368.0	1532.0	2961.0	0.0	-74.0	-5.0	169.0	406.0	677.0	30.0	0.0	6668.0
18	579.0	358.0	1502.0	2890.0	0.0	-64.0	9.0	153.0	370.0	602.0	22.0	0.0	6421.0
19	659.0	390.0	1642.0	3134.0	0.0	-90.0	-17.0	214.0	344.0	431.0	-113.0	0.0	6594.0
20	639.0	363.0	1676.0	3196.0	0.0	-83.0	-14.0	281.0	355.0	342.0	-185.0	0.0	6570.0
21	631.0	376.0	1554.0	2933.0	0.0	-64.0	1.0	171.0	402.0	670.0	32.0	0.0	6706.0
22	622.0	375.0	1527.0	2899.0	0.0	-63.0	8.0	174.0	403.0	686.0	36.0	0.0	6667.0
23	609.0	364.0	1540.0	2905.0	0.0	-46.0	31.0	160.0	382.0	617.0	20.0	0.0	6582.0
24	619.0	371.0	1527.0	2888.0	0.0	-45.0	21.0	156.0	382.0	653.0	32.0	0.0	6604.0
25	595.0	362.0	1519.0	2887.0	0.0	-56.0	16.0	169.0	385.0	617.0	15.0	0.0	6509.0
26	618.0	363.0	1637.0	3070.0	0.0	-36.0	42.0	155.0	342.0	507.0	-20.0	0.0	6678.0
27	620.0	372.0	1674.0	3133.0	0.0	-28.0	48.0	169.0	334.0	448.0	-43.0	0.0	6727.0
28	645.0	388.0	1587.0	2994.0	0.0	-39.0	30.0	188.0	426.0	721.0	18.0	0.0	6958.0
29	682.0	395.0	1565.0	2969.0	0.0	-55.0	13.0	190.0	416.0	673.0	-1.0	0.0	6847.0
30	654.0	378.0	1533.0	2912.0	0.0	-46.0	20.0	198.0	427.0	702.0	22.0	0.0	6800.0
31	685.0	407.0	1575.0	2944.0	0.0	-23.0	42.0	158.0	412.0	704.0	38.0	0.0	6942.0
Monthly T...	19876.00	11859.00	48997.00	93051.00	0.00	-1688.00	450.00	5362.00	11958.00	18842.00	33.00	0.00	208740.00



Monthly Report
Meter Chamber
Net Flow Totals

Town of Tecumseh
Water System
Reports
M_FlowTotal_Net_MCx
06/01/2023 08:29:42 AM

Report Date From: 01/04/2022 12:00:00 AM
To: 01/05/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	635.0	382.0	1554.0	2936.0	0.0	-45.0	25.0	204.0	419.0	663.0	-11.0	0.0	6762.0
2	692.0	399.0	1680.0	3115.0	0.0	-27.0	36.0	172.0	348.0	462.0	-48.0	0.0	6829.0
3	678.0	384.0	1673.0	3111.0	0.0	-23.0	44.0	157.0	321.0	418.0	-61.0	0.0	6702.0
4	647.0	383.0	1547.0	2914.0	0.0	-72.0	-4.0	177.0	411.0	681.0	30.0	0.0	6714.0
5	650.0	380.0	1534.0	2933.0	0.0	-97.0	-23.0	199.0	417.0	692.0	18.0	0.0	6703.0
6	632.0	374.0	1527.0	2899.0	0.0	-76.0	-6.0	201.0	418.0	706.0	39.0	0.0	6714.0
7	628.0	380.0	1549.0	2912.0	0.0	-85.0	-11.0	182.0	429.0	743.0	44.0	0.0	6771.0
8	636.0	387.0	1550.0	2922.0	0.0	-96.0	-30.0	182.0	400.0	664.0	0.0	0.0	6615.0
9	676.0	395.0	1662.0	3101.0	0.0	-37.0	37.0	154.0	321.0	462.0	0.0	0.0	6771.0
10	711.0	414.0	1723.0	3208.0	0.0	-22.0	44.0	149.0	331.0	463.0	0.0	0.0	7021.0
11	714.0	426.0	1612.0	3024.0	0.0	-71.0	3.0	165.0	423.0	723.0	0.0	0.0	7019.0
12	740.0	444.0	1617.0	3105.0	0.0	-53.0	20.0	185.0	429.0	722.0	57.0	0.0	7266.0
13	656.0	408.0	1626.0	3029.0	0.0	-54.0	21.0	173.0	429.0	707.0	32.0	0.0	7027.0
14	678.0	421.0	1631.0	3037.0	0.0	-51.0	28.0	178.0	421.0	713.0	39.0	0.0	7095.0
15	731.0	427.0	1709.0	3172.0	0.0	-24.0	46.0	138.0	335.0	464.0	-46.0	0.0	6952.0
16	694.0	403.0	1687.0	3155.0	0.0	-28.0	42.0	157.0	335.0	466.0	-43.0	0.0	6868.0
17	689.0	394.0	1658.0	3114.0	0.0	-32.0	44.0	137.0	334.0	463.0	-51.0	0.0	6750.0
18	674.0	387.0	1585.0	2993.0	0.0	-44.0	29.0	187.0	418.0	686.0	26.0	0.0	6941.0
19	722.0	415.0	1603.0	3028.0	0.0	-63.0	7.0	163.0	411.0	704.0	49.0	0.0	7039.0
20	728.0	436.0	1614.0	3075.0	0.0	-72.0	-6.0	187.0	430.0	754.0	52.0	0.0	7198.0
21	740.0	433.0	1609.0	3053.0	0.0	-53.0	15.0	165.0	413.0	720.0	44.0	0.0	7139.0
22	719.0	432.0	1629.0	3039.0	0.0	-56.0	21.0	165.0	407.0	682.0	45.0	0.0	7083.0
23	846.0	497.0	1871.0	3453.0	0.0	-20.0	33.0	165.0	358.0	508.0	-38.0	0.0	7673.0
24	857.0	493.0	1874.0	3477.0	0.0	-10.0	20.0	155.0	340.0	455.0	-65.0	0.0	7596.0
25	747.0	449.0	1663.0	3103.0	0.0	-43.0	-13.0	154.0	410.0	678.0	18.0	0.0	7166.0
26	762.0	464.0	1674.0	3112.0	0.0	-53.0	-25.0	180.0	418.0	697.0	30.0	0.0	7259.0
27	704.0	418.0	1614.0	3044.0	0.0	-58.0	-31.0	175.0	424.0	706.0	25.0	0.0	7021.0
28	791.0	463.0	1692.0	3169.0	0.0	-65.0	-38.0	191.0	414.0	687.0	23.0	0.0	7327.0
29	831.0	493.0	1739.0	3254.0	0.0	-39.0	-15.0	171.0	415.0	722.0	38.0	0.0	7609.0
30	830.0	485.0	1821.0	3360.0	0.0	-13.0	8.0	133.0	333.0	493.0	-34.0	0.0	7416.0
Monthly T...	21438.00	12666.00	49527.00	92847.00	0.00	-1482.00	321.00	5101.00	11712.00	18704.00	212.00	0.00	211046.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/06/2022 03:26:00 AM

Report Date From: 01/05/2022 12:00:00 AM

To: 01/06/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	787.0	442.0	1761.0	3302.0	0.0	-39.0	2.0	168.0	334.0	406.0	-77.0	0.0	7086.0
2	757.0	446.0	1638.0	3071.0	0.0	-44.0	-18.0	166.0	390.0	647.0	23.0	0.0	7076.0
3	723.0	439.0	1622.0	3017.0	0.0	-42.0	-17.0	170.0	389.0	647.0	18.0	0.0	6966.0
4	801.0	487.0	1723.0	3196.0	0.0	-48.0	-24.0	203.0	435.0	738.0	27.0	0.0	7538.0
5	820.0	486.0	1693.0	3154.0	0.0	-57.0	-34.0	167.0	422.0	722.0	35.0	0.0	7408.0
6	776.0	468.0	1668.0	3113.0	0.0	-58.0	-27.0	165.0	385.0	632.0	25.0	0.0	7147.0
7	927.0	534.0	1941.0	3645.0	0.0	-17.0	9.0	177.0	357.0	519.0	-33.0	0.0	8059.0
8	919.0	521.0	1926.0	3536.0	0.0	-3.0	20.0	166.0	304.0	453.0	-59.0	0.0	7783.0
9	1002.0	594.0	1956.0	3599.0	0.0	-30.0	-22.0	215.0	34.0	760.0	34.0	0.0	8142.0
10	1098.0	667.0	2065.0	3777.0	0.0	-40.0	-21.0	228.0	272.0	844.0	36.0	0.0	8926.0
11	1221.0	738.0	2247.0	4067.0	0.0	6.0	19.0	229.0	0.0	871.0	42.0	0.0	9440.0
12	1204.0	713.0	2253.0	4103.0	0.0	-13.0	10.0	244.0	243.0	922.0	48.0	0.0	9727.0
13	985.0	725.0	2360.0	4265.0	0.0	3.0	24.0	228.0	0.0	908.0	17.0	0.0	9515.0
14	1101.0	762.0	2532.0	4516.0	0.0	20.0	30.0	237.0	1.0	608.0	-86.0	0.0	9721.0
15	1254.0	730.0	2513.0	4540.0	0.0	8.0	29.0	249.0	0.0	523.0	-106.0	0.0	9740.0
16	836.0	540.0	1923.0	3501.0	0.0	-51.0	-19.0	226.0	0.0	761.0	23.0	0.0	7740.0
17	776.0	604.0	2054.0	3801.0	0.0	-49.0	-19.0	269.0	3.0	850.0	36.0	0.0	8325.0
18	681.0	635.0	1997.0	3667.0	0.0	-46.0	-5.0	253.0	417.0	847.0	39.0	0.0	8485.0
19	691.0	597.0	2026.0	3805.0	0.0	-29.0	-4.0	221.0	474.0	823.0	31.0	0.0	8635.0
20	1044.0	631.0	2154.0	4025.0	0.0	-13.0	16.0	212.0	460.0	758.0	-4.0	0.0	9283.0
21	1075.0	642.0	2212.0	4128.0	0.0	-48.0	-8.0	223.0	397.0	486.0	-107.0	0.0	9000.0
22	207.0	565.0	1981.0	3645.0	0.0	-50.0	-3.0	174.0	329.0	437.0	-75.0	0.0	7210.0
23	444.0	587.0	2127.0	3960.0	0.0	-7.0	27.0	209.0	380.0	531.0	-66.0	0.0	8192.0
24	278.0	620.0	2108.0	3923.0	0.0	-43.0	-8.0	249.0	489.0	812.0	29.0	0.0	8457.0
25	557.0	628.0	2108.0	3913.0	0.0	-39.0	-30.0	223.0	461.0	790.0	26.0	0.0	8637.0
26	527.0	553.0	1909.0	3563.0	0.0	-74.0	-69.0	133.0	247.0	430.0	35.0	0.0	7254.0
27	841.0	628.0	2044.0	3850.0	0.0	-42.0	24.0	135.0	285.0	380.0	20.0	0.0	8165.0
28	1274.0	776.0	2468.0	4543.0	0.0	-7.0	15.0	85.0	121.0	222.0	-47.0	0.0	9450.0
29	1228.0	828.0	2636.0	4822.0	0.0	-1.0	32.0	0.0	0.0	0.0	-21.0	0.0	9524.0
30	959.0	887.0	2674.0	4933.0	0.0	-24.0	32.0	0.0	0.0	0.0	50.0	0.0	9511.0
31	991.0	899.0	2698.0	5046.0	0.0	-26.0	16.0	131.0	181.0	277.0	37.0	0.0	10250.0
Monthly T...	26784.00	19372.00	65017.00	120026.00	0.00	-903.00	-23.00	5755.00	7810.00	18604.00	-50.00	0.00	262392.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/07/2022 03:26:00 AM

Report Date From: 01/06/2022 12:00:00 AM

To: 01/07/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	726.0	823.0	2433.0	4509.0	0.0	-58.0	-31.0	217.0	473.0	814.0	20.0	0.0	9926.0
2	1285.0	774.0	2328.0	4247.0	0.0	-32.0	-5.0	310.0	584.0	1016.0	39.0	0.0	10546.0
3	1078.0	844.0	2606.0	4827.0	0.0	-24.0	18.0	352.0	668.0	1168.0	66.0	0.0	11603.0
4	205.0	136.0	432.0	826.0	0.0	-53.0	-39.0	104.0	119.0	166.0	-31.0	0.0	1865.0
5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
10	550.0	471.0	1616.0	2940.0	0.0	11.0	23.0	163.0	420.0	766.0	86.0	0.0	7046.0
11	994.0	608.0	2183.0	4073.0	0.0	-22.0	-2.0	274.0	489.0	769.0	3.0	0.0	9369.0
12	815.0	584.0	2335.0	4340.0	0.0	-28.0	11.0	273.0	470.0	669.0	-62.0	0.0	9407.0
13	540.0	670.0	2289.0	4238.0	0.0	-53.0	-35.0	318.0	614.0	1059.0	53.0	0.0	9693.0
14	350.0	603.0	2206.0	4097.0	0.0	-36.0	-7.0	284.0	565.0	968.0	51.0	0.0	9081.0
15	1033.0	774.0	2649.0	4905.0	0.0	-10.0	22.0	359.0	674.0	1115.0	37.0	0.0	11558.0
16	1416.0	797.0	2561.0	4790.0	0.0	-20.0	-5.0	325.0	620.0	990.0	-1.0	0.0	11473.0
17	1403.0	815.0	2713.0	5023.0	0.0	-11.0	6.0	345.0	664.0	1116.0	29.0	0.0	12103.0
18	1551.0	905.0	2848.0	5265.0	0.0	-3.0	27.0	342.0	531.0	718.0	-131.0	0.0	12053.0
19	1615.0	903.0	3009.0	5594.0	0.0	14.0	55.0	386.0	554.0	701.0	-170.0	0.0	12661.0
20	1339.0	796.0	2471.0	4521.0	0.0	-47.0	-17.0	346.0	599.0	949.0	-53.0	0.0	10904.0
21	1757.0	974.0	3044.0	5554.0	0.0	-108.0	-70.0	455.0	720.0	1114.0	-91.0	0.0	13349.0
22	1182.0	1126.0	3223.0	5928.0	0.0	-27.0	15.0	463.0	769.0	1204.0	-79.0	0.0	13804.0
23	1769.0	1030.0	3129.0	5758.0	0.0	-41.0	-16.0	482.0	729.0	1107.0	-135.0	0.0	13812.0
24	1823.0	1015.0	3226.0	5978.0	0.0	1.0	20.0	425.0	728.0	1152.0	-65.0	0.0	14303.0
25	1766.0	1018.0	3241.0	5981.0	0.0	23.0	46.0	440.0	674.0	963.0	-126.0	0.0	14026.0
26	1729.0	997.0	3076.0	5670.0	0.0	1.0	34.0	396.0	599.0	802.0	-168.0	0.0	13136.0
27	1828.0	1076.0	3127.0	5743.0	0.0	-37.0	-19.0	455.0	723.0	1141.0	-99.0	0.0	13938.0
28	1818.0	993.0	3169.0	5858.0	0.0	3.0	15.0	467.0	759.0	1203.0	-49.0	0.0	14236.0
29	1560.0	911.0	2828.0	5294.0	0.0	-93.0	-51.0	471.0	772.0	1226.0	-70.0	0.0	12848.0
30	1888.0	1102.0	3242.0	6064.0	0.0	-39.0	-2.0	485.0	794.0	1205.0	-93.0	0.0	14646.0
Monthly T...	32020.00	20745.00	65984.00	122023.00	0.00	-689.00	-7.00	8937.00	15311.00	24101.00	-1039.00	0.00	287386.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**
M_FlowTotal_Net_MCx
01/08/2022 03:26:00 AM

Report Date From: 01/07/2022 12:00:00 AM
To: 01/08/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1930.0	1107.0	3224.0	5925.0	0.0	-1.0	42.0	369.0	624.0	935.0	-166.0	0.0	13989.0
2	1712.0	995.0	3059.0	5642.0	0.0	-29.0	-3.0	413.0	625.0	927.0	-110.0	0.0	13231.0
3	1996.0	1128.0	3457.0	6388.0	0.0	26.0	56.0	407.0	652.0	934.0	-166.0	0.0	14878.0
4	1861.0	1089.0	3238.0	5971.0	0.0	-41.0	-7.0	478.0	759.0	1161.0	-118.0	0.0	14391.0
5	1398.0	763.0	2560.0	4810.0	0.0	-98.0	-72.0	398.0	661.0	1057.0	-19.0	0.0	11458.0
6	1185.0	685.0	2354.0	4432.0	0.0	-82.0	-58.0	319.0	589.0	984.0	25.0	0.0	10433.0
7	1511.0	882.0	2759.0	5111.0	0.0	-11.0	19.0	368.0	620.0	1004.0	15.0	0.0	12278.0
8	1780.0	1037.0	3018.0	5495.0	0.0	-24.0	23.0	385.0	646.0	1015.0	-46.0	0.0	13329.0
9	1864.0	1090.0	3246.0	5919.0	0.0	41.0	75.0	382.0	623.0	945.0	-46.0	0.0	14139.0
10	2089.0	1210.0	3584.0	6598.0	0.0	63.0	95.0	418.0	650.0	937.0	-101.0	0.0	15543.0
11	2052.0	1222.0	3374.0	6154.0	0.0	12.0	43.0	449.0	759.0	1225.0	-69.0	0.0	15221.0
12	1989.0	1111.0	3407.0	6218.0	0.0	14.0	52.0	450.0	754.0	1168.0	-77.0	0.0	15086.0
13	1792.0	1052.0	2977.0	5357.0	0.0	-42.0	-12.0	381.0	651.0	1032.0	-64.0	0.0	13124.0
14	1762.0	1037.0	3036.0	5550.0	0.0	-32.0	0.0	408.0	698.0	1100.0	-60.0	0.0	13499.0
15	1969.0	1145.0	3314.0	5978.0	0.0	2.0	31.0	386.0	670.0	1074.0	-41.0	0.0	14528.0
16	1652.0	964.0	2940.0	5369.0	0.0	1.0	33.0	350.0	560.0	792.0	-95.0	0.0	12566.0
17	1398.0	798.0	2699.0	4894.0	0.0	-40.0	0.0	325.0	490.0	632.0	-143.0	0.0	11053.0
18	1492.0	900.0	2732.0	4954.0	0.0	-88.0	-59.0	360.0	625.0	998.0	-57.0	0.0	11857.0
19	1897.0	1057.0	3260.0	6004.0	0.0	-208.0	-172.0	514.0	779.0	1144.0	-159.0	0.0	14116.0
20	1651.0	984.0	2910.0	5309.0	0.0	-145.0	-117.0	425.0	719.0	1150.0	-51.0	0.0	12835.0
21	1816.0	1071.0	3125.0	5730.0	0.0	-80.0	-79.0	451.0	783.0	1270.0	-5.0	0.0	14082.0
22	1966.0	1154.0	3357.0	6006.0	0.0	-33.0	7.0	380.0	687.0	1082.0	24.0	0.0	14630.0
23	1777.0	1029.0	3158.0	5601.0	0.0	-5.0	38.0	333.0	528.0	752.0	-132.0	0.0	13079.0
24	1407.0	833.0	2671.0	4837.0	0.0	-65.0	-25.0	318.0	495.0	646.0	-109.0	0.0	11008.0
25	1820.0	1083.0	3136.0	5697.0	0.0	-68.0	-45.0	392.0	678.0	1066.0	-58.0	0.0	13701.0
26	1877.0	1075.0	3194.0	5815.0	0.0	-20.0	-10.0	397.0	716.0	1152.0	-43.0	0.0	14153.0
27	1826.0	1110.0	3018.0	5508.0	0.0	-118.0	-82.0	420.0	685.0	1074.0	-102.0	0.0	13339.0
28	1668.0	1035.0	2894.0	5350.0	0.0	-105.0	-83.0	418.0	696.0	1091.0	-112.0	0.0	12852.0
29	1828.0	1105.0	3202.0	5949.0	0.0	-55.0	-27.0	467.0	732.0	1115.0	-147.0	0.0	14169.0
30	1967.0	397.0	3396.0	6248.0	0.0	40.0	50.0	405.0	623.0	913.0	-142.0	0.0	13897.0
31	1849.0	653.0	3305.0	6131.0	0.0	12.0	43.0	425.0	633.0	920.0	-146.0	0.0	13825.0
Monthly T...	54781.00	30801.00	95604.00	174950.00	0.00	-1179.00	-244.00	12391.00	20410.00	31295.00	-2520.00	0.00	416289.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/09/2022 03:26:00 AM

Report Date From: 01/08/2022 12:00:00 AM

To: 01/09/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1681.0	926.0	3108.0	5784.0	0.0	5.0	22.0	420.0	656.0	986.0	-162.0	0.0	13426.0
2	1781.0	998.0	3216.0	6012.0	0.0	-33.0	-22.0	456.0	763.0	1198.0	-82.0	0.0	14287.0
3	1865.0	1135.0	3103.0	5655.0	0.0	-73.0	-37.0	427.0	754.0	1224.0	-59.0	0.0	13994.0
4	1551.0	942.0	2635.0	4726.0	0.0	-45.0	-22.0	308.0	569.0	943.0	-10.0	0.0	11597.0
5	1642.0	962.0	2817.0	5062.0	0.0	-52.0	-8.0	324.0	577.0	916.0	-32.0	0.0	12208.0
6	1816.0	1080.0	3127.0	5583.0	0.0	20.0	54.0	318.0	540.0	784.0	-83.0	0.0	13239.0
7	1924.0	1113.0	3291.0	5872.0	0.0	10.0	48.0	346.0	543.0	711.0	-149.0	0.0	13709.0
8	1606.0	905.0	2725.0	4932.0	0.0	-118.0	-75.0	291.0	597.0	988.0	-27.0	0.0	11824.0
9	1658.0	960.0	2804.0	5121.0	0.0	-123.0	-84.0	371.0	147.0	1072.0	-31.0	0.0	11895.0
10	1902.0	1156.0	3091.0	5719.0	0.0	-103.0	-59.0	397.0	0.0	1174.0	-41.0	0.0	13236.0
11	2010.0	1213.0	3186.0	5843.0	0.0	-79.0	-31.0	407.0	0.0	1143.0	-37.0	0.0	13655.0
12	2232.0	1313.0	3526.0	6451.0	0.0	-41.0	25.0	410.0	0.0	1136.0	-58.0	0.0	14994.0
13	2123.0	1255.0	3374.0	6020.0	0.0	-14.0	32.0	383.0	0.0	832.0	-143.0	0.0	13862.0
14	2161.0	1250.0	3493.0	6267.0	0.0	3.0	57.0	363.0	0.0	703.0	-175.0	0.0	14122.0
15	2126.0	1225.0	3434.0	5928.0	0.0	-37.0	0.0	434.0	497.0	1217.0	-47.0	0.0	14777.0
16	2174.0	1272.0	3512.0	6356.0	0.0	-41.0	-6.0	430.0	745.0	1171.0	-52.0	0.0	15561.0
17	2199.0	1338.0	3506.0	6398.0	0.0	-57.0	-13.0	448.0	760.0	1186.0	-104.0	0.0	15661.0
18	2161.0	1313.0	3400.0	6195.0	0.0	-83.0	-44.0	459.0	732.0	1149.0	-70.0	0.0	15212.0
19	676.0	355.0	1122.0	2057.0	0.0	-55.0	-31.0	187.0	252.0	354.0	-75.0	0.0	4842.0
20	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
21	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
22	1229.0	707.0	2364.0	4314.0	0.0	-23.0	-19.0	316.0	345.0	610.0	0.0	0.0	9843.0
23	1709.0	1017.0	2802.0	5017.0	0.0	-38.0	-2.0	337.0	646.0	1050.0	-14.0	0.0	12524.0
24	1914.0	1193.0	3101.0	5455.0	0.0	-24.0	10.0	359.0	680.0	1097.0	-8.0	0.0	13777.0
25	1852.0	1137.0	3019.0	5380.0	0.0	-10.0	12.0	361.0	696.0	1164.0	26.0	0.0	13637.0
26	1774.0	1050.0	2958.0	5322.0	0.0	-1.0	32.0	329.0	648.0	1085.0	-2.0	0.0	13195.0
27	1864.0	1129.0	3166.0	5708.0	0.0	26.0	54.0	362.0	574.0	833.0	-87.0	0.0	13629.0
28	1861.0	1102.0	3240.0	5872.0	0.0	15.0	53.0	357.0	584.0	797.0	-118.0	0.0	13763.0
29	1837.0	1094.0	2984.0	5290.0	0.0	-28.0	1.0	325.0	664.0	1119.0	3.0	0.0	13289.0
30	1857.0	1143.0	2920.0	5062.0	0.0	-17.0	12.0	274.0	563.0	925.0	4.0	0.0	12743.0
31	2004.0	1247.0	3118.0	5469.0	0.0	-5.0	27.0	330.0	82.0	1134.0	50.0	0.0	13456.0
Monthly T...	53189.00	31530.00	88142.00	158870.00	0.00	-1021.00	-14.00	10529.00	13614.00	28701.00	-1583.00	0.00	381957.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/10/2022 03:26:00 AM

Report Date From: 01/09/2022 12:00:00 AM

To: 01/10/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1972.0	1209.0	3135.0	5605.0	0.0	-41.0	-14.0	397.0	0.0	1211.0	37.0	0.0	13511.0
2	2141.0	1307.0	3433.0	6146.0	0.0	14.0	54.0	421.0	0.0	1231.0	-6.0	0.0	14741.0
3	2139.0	1298.0	3448.0	6139.0	0.0	23.0	56.0	371.0	0.0	819.0	-120.0	0.0	14173.0
4	1691.0	1050.0	2824.0	4970.0	0.0	18.0	52.0	250.0	0.0	655.0	-86.0	0.0	11424.0
5	1889.0	1130.0	3110.0	5409.0	0.0	16.0	18.0	288.0	0.0	678.0	-125.0	0.0	12413.0
6	1840.0	1121.0	2970.0	5260.0	0.0	-47.0	-28.0	362.0	0.0	1074.0	-29.0	0.0	12523.0
7	1977.0	1245.0	3149.0	5629.0	0.0	-57.0	-41.0	377.0	0.0	1075.0	-64.0	0.0	13290.0
8	1967.0	1218.0	3189.0	5674.0	0.0	-23.0	-4.0	368.0	133.0	1029.0	-39.0	0.0	13512.0
9	2121.0	1287.0	3371.0	6014.0	0.0	-6.0	30.0	381.0	291.0	1042.0	-20.0	0.0	14511.0
10	2266.0	1403.0	3560.0	6343.0	0.0	9.0	43.0	398.0	270.0	779.0	-130.0	0.0	14941.0
11	2001.0	1237.0	3306.0	5836.0	0.0	4.0	44.0	319.0	237.0	701.0	-119.0	0.0	13566.0
12	1822.0	1112.0	2879.0	5040.0	0.0	-28.0	4.0	293.0	256.0	958.0	-24.0	0.0	12312.0
13	1810.0	1118.0	2849.0	4929.0	0.0	-18.0	9.0	315.0	256.0	952.0	-13.0	0.0	12207.0
14	1870.0	1191.0	2985.0	5252.0	0.0	-7.0	26.0	331.0	271.0	1001.0	-56.0	0.0	12864.0
15	1894.0	1166.0	3029.0	5317.0	0.0	-20.0	6.0	369.0	279.0	1014.0	-74.0	0.0	12980.0
16	2039.0	1245.0	3239.0	5690.0	0.0	5.0	28.0	337.0	274.0	974.0	-50.0	0.0	13781.0
17	1981.0	1219.0	3249.0	5752.0	0.0	30.0	41.0	338.0	233.0	735.0	-138.0	0.0	13440.0
18	1774.0	1075.0	3088.0	5427.0	0.0	-9.0	26.0	313.0	223.0	676.0	-144.0	0.0	12449.0
19	1698.0	989.0	2832.0	5004.0	0.0	-71.0	-41.0	366.0	282.0	1015.0	-53.0	0.0	12021.0
20	1719.0	1019.0	2810.0	4977.0	0.0	-101.0	-74.0	410.0	289.0	943.0	-114.0	0.0	11878.0
21	1696.0	1064.0	2733.0	4735.0	0.0	-26.0	4.0	244.0	248.0	933.0	-31.0	0.0	11600.0
22	1740.0	1075.0	2735.0	4751.0	0.0	-51.0	-28.0	334.0	264.0	964.0	-4.0	0.0	11780.0
23	1720.0	1032.0	2772.0	4850.0	0.0	-25.0	12.0	304.0	259.0	1016.0	19.0	0.0	11959.0
24	1746.0	1060.0	2828.0	4892.0	0.0	6.0	36.0	223.0	208.0	699.0	-49.0	0.0	11649.0
25	1676.0	1013.0	2792.0	4779.0	0.0	13.0	54.0	214.0	180.0	577.0	-63.0	0.0	11235.0
26	1581.0	945.0	2620.0	4499.0	0.0	-27.0	0.0	262.0	233.0	893.0	35.0	0.0	11041.0
27	1674.0	1001.0	2655.0	4533.0	0.0	-24.0	4.0	271.0	230.0	893.0	23.0	0.0	11260.0
28	1664.0	1036.0	2631.0	4586.0	0.0	-13.0	10.0	271.0	226.0	821.0	10.0	0.0	11242.0
29	1783.0	1087.0	2725.0	4765.0	0.0	-15.0	8.0	273.0	231.0	848.0	10.0	0.0	11715.0
30	1846.0	1100.0	2890.0	5179.0	0.0	63.0	95.0	236.0	227.0	811.0	-20.0	0.0	12427.0
Monthly T...	55737.00	34052.00	89836.00	157982.00	0.00	-408.00	430.00	9636.00	5600.00	27017.00	-1437.00	0.00	378445.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/11/2022 03:26:00 AM

Report Date From: 01/10/2022 12:00:00 AM

To: 01/11/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1871.0	1133.0	2925.0	5073.0	0.0	3.0	34.0	285.0	209.0	674.0	-63.0	0.0	12144.0
2	1777.0	1066.0	2879.0	4968.0	0.0	6.0	32.0	268.0	189.0	540.0	-128.0	0.0	11597.0
3	1608.0	922.0	2645.0	4621.0	0.0	-51.0	-22.0	348.0	253.0	902.0	-32.0	0.0	11194.0
4	1658.0	989.0	2686.0	4713.0	0.0	-41.0	-7.0	300.0	259.0	984.0	13.0	0.0	11554.0
5	1653.0	1025.0	2661.0	4710.0	0.0	-49.0	-34.0	366.0	268.0	991.0	-47.0	0.0	11544.0
6	1622.0	998.0	2645.0	4643.0	0.0	-44.0	-14.0	312.0	249.0	918.0	-41.0	0.0	11288.0
7	1561.0	934.0	2549.0	4431.0	0.0	-3.0	21.0	271.0	214.0	760.0	-19.0	0.0	10719.0
8	1529.0	935.0	2580.0	4532.0	0.0	5.0	32.0	242.0	185.0	577.0	-63.0	0.0	10554.0
9	1504.0	909.0	2560.0	4551.0	0.0	-6.0	18.0	253.0	183.0	514.0	-117.0	0.0	10369.0
10	1785.0	1050.0	2898.0	5026.0	0.0	32.0	52.0	218.0	199.0	601.0	-103.0	0.0	11758.0
11	1499.0	894.0	2453.0	4332.0	0.0	11.0	23.0	309.0	263.0	935.0	28.0	0.0	10747.0
12	1437.0	898.0	2366.0	4167.0	0.0	-48.0	-31.0	263.0	427.0	805.0	-16.0	0.0	10268.0
13	1405.0	884.0	2349.0	4191.0	0.0	-40.0	-10.0	263.0	517.0	798.0	-3.0	0.0	10354.0
14	1396.0	890.0	2373.0	4167.0	0.0	-18.0	6.0	201.0	506.0	805.0	23.0	0.0	10349.0
15	1550.0	956.0	2562.0	4501.0	0.0	-6.0	17.0	239.0	430.0	551.0	-89.0	0.0	10711.0
16	1495.0	928.0	2552.0	4493.0	0.0	8.0	32.0	215.0	399.0	474.0	-114.0	0.0	10482.0
17	1415.0	888.0	2331.0	4088.0	0.0	-52.0	-13.0	241.0	492.0	751.0	-32.0	0.0	10109.0
18	1319.0	824.0	2227.0	3958.0	0.0	-39.0	27.0	192.0	468.0	716.0	5.0	0.0	9697.0
19	1309.0	829.0	2212.0	3889.0	0.0	-39.0	24.0	209.0	477.0	738.0	14.0	0.0	9662.0
20	1238.0	770.0	2136.0	3749.0	0.0	-27.0	36.0	160.0	473.0	755.0	41.0	0.0	9331.0
21	1218.0	760.0	2120.0	3766.0	0.0	-42.0	23.0	205.0	484.0	741.0	14.0	0.0	9289.0
22	1226.0	759.0	2256.0	3994.0	0.0	-53.0	15.0	213.0	438.0	612.0	-62.0	0.0	9398.0
23	1056.0	670.0	2203.0	3888.0	0.0	-22.0	39.0	208.0	418.0	553.0	-58.0	0.0	8955.0
24	1020.0	644.0	2016.0	3635.0	0.0	-82.0	-6.0	245.0	537.0	857.0	7.0	0.0	8873.0
25	988.0	628.0	1953.0	3504.0	0.0	-68.0	0.0	230.0	499.0	772.0	11.0	0.0	8517.0
26	1083.0	685.0	2036.0	3581.0	0.0	-29.0	34.0	190.0	451.0	709.0	11.0	0.0	8751.0
27	1086.0	691.0	2040.0	3614.0	0.0	-29.0	32.0	199.0	437.0	687.0	19.0	0.0	8776.0
28	1155.0	732.0	2124.0	3742.0	0.0	-24.0	40.0	200.0	451.0	719.0	22.0	0.0	9161.0
29	1182.0	736.0	2230.0	3930.0	0.0	1.0	63.0	159.0	362.0	511.0	-34.0	0.0	9140.0
30	1189.0	736.0	2262.0	3985.0	0.0	4.0	66.0	175.0	350.0	423.0	-71.0	0.0	9119.0
31	1116.0	709.0	2042.0	3599.0	0.0	-6.0	52.0	164.0	412.0	660.0	19.0	0.0	8767.0
Monthly T...	42950.00	26472.00	73871.00	130041.00	0.00	-748.00	581.00	7343.00	11499.00	22033.00	-865.00	0.00	313177.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/12/2022 03:26:00 AM

Report Date From: 01/11/2022 12:00:00 AM

To: 01/12/2022 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1118.0	705.0	2054.0	3639.0	0.0	-39.0	29.0	191.0	455.0	725.0	25.0	0.0	8902.0
2	1018.0	646.0	1995.0	3574.0	0.0	-32.0	30.0	201.0	457.0	733.0	29.0	0.0	8651.0
3	1040.0	674.0	2038.0	3587.0	0.0	-24.0	36.0	206.0	449.0	722.0	31.0	0.0	8759.0
4	1129.0	719.0	2094.0	3669.0	0.0	-18.0	35.0	183.0	456.0	752.0	41.0	0.0	9060.0
5	1184.0	739.0	2201.0	3848.0	0.0	-5.0	57.0	153.0	352.0	482.0	-34.0	0.0	8977.0
6	1587.0	1019.0	3051.0	5460.0	0.0	-158.0	-62.0	417.0	570.0	538.0	-205.0	0.0	12217.0
7	1004.0	639.0	1961.0	3522.0	0.0	-46.0	22.0	203.0	449.0	735.0	32.0	0.0	8521.0
8	1129.0	713.0	2065.0	3650.0	0.0	-31.0	38.0	209.0	476.0	774.0	35.0	0.0	9058.0
9	1142.0	720.0	2090.0	3321.0	0.0	-17.0	26.0	198.0	461.0	728.0	22.0	0.0	8691.0
10	1021.0	648.0	1984.0	3518.0	0.0	-33.0	29.0	182.0	459.0	719.0	18.0	0.0	8545.0
11	986.0	624.0	1944.0	3459.0	0.0	-21.0	39.0	191.0	434.0	667.0	3.0	0.0	8326.0
12	1019.0	650.0	2071.0	3658.0	0.0	-7.0	52.0	177.0	359.0	451.0	-64.0	0.0	8366.0
13	1076.0	673.0	2140.0	3755.0	0.0	-3.0	58.0	161.0	353.0	436.0	-74.0	0.0	8575.0
14	1009.0	646.0	1971.0	3527.0	0.0	-32.0	27.0	202.0	460.0	749.0	43.0	0.0	8602.0
15	957.0	608.0	1913.0	3422.0	0.0	-42.0	16.0	174.0	448.0	723.0	29.0	0.0	8248.0
16	979.0	618.0	1933.0	3474.0	0.0	-61.0	0.0	202.0	436.0	662.0	3.0	0.0	8246.0
17	1019.0	642.0	1950.0	3462.0	0.0	-33.0	29.0	168.0	441.0	724.0	49.0	0.0	8451.0
18	976.0	620.0	1936.0	3458.0	0.0	-42.0	18.0	179.0	412.0	621.0	8.0	0.0	8186.0
19	1055.0	651.0	2102.0	3703.0	0.0	-22.0	38.0	164.0	356.0	481.0	-41.0	0.0	8487.0
20	1019.0	633.0	2085.0	3665.0	0.0	-7.0	56.0	163.0	334.0	406.0	-75.0	0.0	8279.0
21	994.0	623.0	2046.0	3632.0	0.0	-36.0	23.0	195.0	437.0	683.0	23.0	0.0	8620.0
22	958.0	609.0	2048.0	3632.0	0.0	-23.0	32.0	214.0	469.0	745.0	35.0	0.0	8719.0
23	1029.0	634.0	1973.0	3474.0	0.0	0.0	58.0	194.0	438.0	671.0	19.0	0.0	8490.0
24	1181.0	729.0	2129.0	3741.0	0.0	-50.0	11.0	212.0	454.0	708.0	5.0	0.0	9120.0
25	1047.0	661.0	2029.0	3574.0	0.0	-55.0	8.0	215.0	456.0	680.0	0.0	0.0	8615.0
26	1120.0	690.0	2158.0	3789.0	0.0	-43.0	12.0	191.0	373.0	483.0	-66.0	0.0	8707.0
27	1037.0	650.0	2120.0	3710.0	0.0	-27.0	36.0	181.0	363.0	419.0	-93.0	0.0	8396.0
28	981.0	614.0	1962.0	3465.0	0.0	-57.0	6.0	191.0	431.0	643.0	3.0	0.0	8239.0
29	966.0	608.0	1942.0	3437.0	0.0	-63.0	1.0	212.0	449.0	687.0	9.0	0.0	8248.0
30	906.0	568.0	1888.0	3369.0	0.0	-69.0	-1.0	226.0	459.0	691.0	7.0	0.0	8044.0
Monthly T...	31686.00	19973.00	61873.00	109194.00	0.00	-1096.00	759.00	5955.00	12946.00	19238.00	-183.00	0.00	260345.00



**Monthly Report
Meter Chamber
Net Flow Totals**

**Town of Tecumseh
Water System
Reports**

M_FlowTotal_Net_MCx
01/01/2023 03:26:00 AM

Report Date From: 01/12/2022 12:00:00 AM

To: 01/01/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	937.0	583.0	1913.0	3404.0	0.0	-78.0	-5.0	199.0	459.0	725.0	31.0	0.0	8168.0
2	1043.0	652.0	2009.0	3583.0	0.0	-77.0	-2.0	221.0	457.0	672.0	0.0	0.0	8558.0
3	1003.0	617.0	2085.0	3609.0	0.0	-16.0	43.0	186.0	388.0	517.0	-45.0	0.0	8387.0
4	997.0	617.0	2089.0	3679.0	0.0	-41.0	25.0	216.0	387.0	435.0	-101.0	0.0	8303.0
5	895.0	561.0	1880.0	3331.0	0.0	-44.0	18.0	178.0	439.0	703.0	24.0	0.0	7985.0
6	996.0	619.0	1949.0	3468.0	0.0	-64.0	-1.0	255.0	490.0	721.0	-1.0	0.0	8432.0
7	943.0	587.0	1900.0	3404.0	0.0	-56.0	26.0	210.0	461.0	698.0	24.0	0.0	8197.0
8	910.0	572.0	1873.0	3371.0	0.0	-78.0	-12.0	245.0	473.0	697.0	-2.0	0.0	8049.0
9	958.0	592.0	1922.0	3414.0	0.0	-61.0	4.0	207.0	432.0	652.0	-1.0	0.0	8119.0
10	1056.0	657.0	2104.0	3685.0	0.0	-14.0	48.0	180.0	354.0	460.0	-63.0	0.0	8467.0
11	1036.0	647.0	2113.0	3721.0	0.0	-24.0	41.0	181.0	368.0	438.0	-90.0	0.0	8431.0
12	952.0	600.0	1946.0	3475.0	0.0	-59.0	3.0	221.0	427.0	639.0	-14.0	0.0	8190.0
13	827.0	561.0	2004.0	3533.0	0.0	-27.0	30.0	237.0	446.0	670.0	-7.0	0.0	8274.0
14	929.0	608.0	1983.0	3516.0	0.0	-36.0	23.0	217.0	456.0	707.0	9.0	0.0	8412.0
15	953.0	621.0	2013.0	3587.0	0.0	-50.0	12.0	215.0	435.0	655.0	-19.0	0.0	8422.0
16	753.0	501.0	1839.0	3335.0	0.0	-65.0	1.0	225.0	452.0	693.0	-7.0	0.0	7727.0
17	705.0	472.0	1906.0	3459.0	0.0	-36.0	28.0	203.0	385.0	519.0	-49.0	0.0	7592.0
18	740.0	485.0	1936.0	3486.0	0.0	-29.0	37.0	205.0	368.0	460.0	-76.0	0.0	7612.0
19	696.0	463.0	1770.0	3266.0	0.0	-85.0	-9.0	231.0	455.0	702.0	0.0	0.0	7489.0
20	622.0	418.0	1706.0	3180.0	0.0	-58.0	6.0	238.0	483.0	764.0	30.0	0.0	7389.0
21	592.0	389.0	1666.0	3116.0	0.0	-84.0	-17.0	217.0	449.0	699.0	21.0	0.0	7048.0
22	616.0	386.0	1657.0	3127.0	0.0	-55.0	11.0	187.0	424.0	681.0	38.0	0.0	7072.0
23	685.0	421.0	1754.0	3242.0	0.0	-20.0	42.0	164.0	386.0	550.0	-15.0	0.0	7209.0
24	806.0	482.0	1917.0	3552.0	0.0	3.0	61.0	173.0	355.0	428.0	-71.0	0.0	7706.0
25	749.0	457.0	1786.0	3464.0	0.0	-30.0	-12.0	150.0	356.0	451.0	-62.0	0.0	7309.0
26	721.0	438.0	1757.0	3382.0	0.0	-55.0	-33.0	154.0	346.0	471.0	-30.0	0.0	7151.0
27	642.0	405.0	1770.0	3347.0	0.0	-81.0	-44.0	195.0	384.0	511.0	-55.0	0.0	7074.0
28	622.0	404.0	1785.0	3385.0	0.0	-64.0	-26.0	187.0	407.0	618.0	3.0	0.0	7321.0
29	598.0	398.0	1761.0	3378.0	0.0	-68.0	-33.0	197.0	404.0	583.0	-34.0	0.0	7184.0
30	565.0	366.0	1728.0	3291.0	0.0	-66.0	-30.0	182.0	385.0	529.0	-50.0	0.0	6900.0
31	642.0	401.0	1831.0	3441.0	0.0	-50.0	-13.0	192.0	360.0	448.0	-84.0	0.0	7168.0
Monthly T...	25189.00	15980.00	58352.00	106231.00	0.00	-1568.00	222.00	6268.00	12871.00	18496.00	-696.00	0.00	241345.00