

# SUMMARY REPORT

For the

## TECUMSEH DISTRIBUTION SYSTEM

(260004969)

For the year

2023

Prepared for the Town of Tecumseh

By Brad Dupuis, C.Tech.  
Manager Water Services O.R.O.

## Table of Contents

<b>Section 1: Overview .....</b>	<b>3</b>
<b>Section 2: Non-compliance Issues .....</b>	<b>4</b>
<b>Section 3: System Capability.....</b>	<b>4</b>

## Section 1: Overview

This report has been prepared and submitted in accordance with Schedule 22 of O. Reg. 170/03 under the *Safe Drinking Water Act*. Schedule 22 requires:

The owner of a drinking-water system shall ensure that, not later than March 31 of each year after 2003, a report is prepared in accordance with subsections (1) and (2) for the preceding calendar year and is given to the members of the municipal council.

Schedule 22 also states that:

- 1) The report must:
  - a) list the requirements of the *Act*, the regulations, the system's approval and any order that the system failed to meet at any time during the period covered by the report and specify the duration of the failure; and
  - b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.
  
- 2) The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system. A summary of the quantities of the water supplied during the period covered by the report, including monthly flows.

In June 2003, the provincial *Safe Drinking Water Act* came into effect. The Drinking-Water Systems Regulation (O.Reg. 170/03) defines how various drinking-water systems are to be operated.

According to this Regulation, the Tecumseh Distribution System is classified as a Large Municipal Residential System (LMR).

## Section 2: Non-Compliance Issues

1. During the year of 2023 there was one **(2) reportable issue**.
  - a) Precautionary Boil Water (for private property) issued under section 16-4 of O.Reg. 170/03.
  - b) Lead exceedance (distribution system) issued under section 15.1 of O.Reg. 170/03.

## Section 3: System Capability – 2023 Water Consumption

In accordance with the Agreement between the Town of Tecumseh and the City of Windsor for the provision of water services to the Town of Tecumseh, executed under By-Law No. 2004-71, the Maximum Daily Flow shall not exceed **87 Million Litres** ( 87 MLD) or 87,000 cubic meters.

The **Maximum Daily Flow** for 2023 was 16,242,000 **Litres** ( 16,242 Cubic Meters) on June 2, 2023.

Monthly average and daily flows for 2023 are attached for reference.

A summary of the **monthly** total volume supplied by the City of Windsor to the Town of Tecumseh is provided below:

<b>2023 Water Consumption</b>	
<b>Month</b>	<b>Total Volume (cubic meters)</b>
January	211,155
February	187,537
March	199,295
April	214,084
May	316,340
June	374,024
July	355,253
August	326,215
September	295,313
October	304,687
November	258,727
December	237,487
<b>Total</b>	<b>3,280,117</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**

M\_FlowTotal\_Net\_MCx  
01/02/2023 03:26:00 AM

Report Date From: 01/01/2023 12:00:00 AM

To: 01/02/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	567.0	357.0	1673.0	3153.0	0.0	-77.0	-29.0	172.0	338.0	396.0	-104.0	0.0	6446.0
2	585.0	373.0	1683.0	3170.0	0.0	-57.0	-23.0	199.0	385.0	527.0	-55.0	0.0	6787.0
3	561.0	371.0	1619.0	3048.0	0.0	-50.0	-13.0	181.0	424.0	670.0	22.0	0.0	6833.0
4	555.0	353.0	1611.0	3046.0	0.0	-57.0	-21.0	189.0	423.0	632.0	7.0	0.0	6738.0
5	562.0	357.0	1606.0	3031.0	0.0	-70.0	-18.0	196.0	432.0	684.0	29.0	0.0	6809.0
6	583.0	371.0	1618.0	3068.0	0.0	-75.0	-9.0	194.0	409.0	647.0	4.0	0.0	6810.0
7	638.0	401.0	1742.0	3244.0	0.0	-34.0	31.0	167.0	347.0	469.0	-48.0	0.0	6957.0
8	631.0	387.0	1753.0	3264.0	0.0	-16.0	49.0	157.0	348.0	447.0	-65.0	0.0	6955.0
9	627.0	387.0	1626.0	3082.0	0.0	-60.0	-1.0	191.0	421.0	634.0	9.0	0.0	6916.0
10	619.0	382.0	1591.0	3031.0	0.0	-84.0	-17.0	204.0	440.0	706.0	26.0	0.0	6898.0
11	568.0	361.0	1585.0	3017.0	0.0	-78.0	-14.0	224.0	462.0	716.0	22.0	0.0	6863.0
12	533.0	339.0	1531.0	2905.0	0.0	-89.0	-23.0	227.0	483.0	790.0	47.0	0.0	6743.0
13	559.0	357.0	1545.0	2927.0	0.0	-72.0	-6.0	187.0	444.0	728.0	45.0	0.0	6714.0
14	609.0	372.0	1708.0	3202.0	0.0	-52.0	16.0	178.0	380.0	549.0	-25.0	0.0	6937.0
15	642.0	390.0	1742.0	3238.0	0.0	-39.0	28.0	197.0	375.0	491.0	-69.0	0.0	6995.0
16	575.0	364.0	1566.0	2975.0	0.0	-78.0	-14.0	192.0	469.0	770.0	53.0	0.0	6872.0
17	571.0	356.0	1553.0	2958.0	0.0	-79.0	-14.0	205.0	471.0	742.0	35.0	0.0	6798.0
18	563.0	352.0	1555.0	2959.0	0.0	-88.0	-21.0	202.0	476.0	795.0	59.0	0.0	6852.0
19	546.0	346.0	1544.0	2932.0	0.0	-62.0	0.0	203.0	479.0	797.0	57.0	0.0	6842.0
20	572.0	369.0	1577.0	2991.0	0.0	-90.0	-23.0	238.0	476.0	704.0	11.0	0.0	6825.0
21	606.0	376.0	1698.0	3166.0	0.0	-43.0	20.0	183.0	376.0	486.0	-49.0	0.0	6819.0
22	604.0	371.0	1683.0	3148.0	0.0	-35.0	34.0	174.0	350.0	424.0	-80.0	0.0	6673.0
23	574.0	363.0	1557.0	2971.0	0.0	-76.0	-9.0	192.0	439.0	684.0	22.0	0.0	6717.0
24	568.0	362.0	1555.0	2960.0	0.0	-68.0	0.0	199.0	450.0	708.0	32.0	0.0	6766.0
25	551.0	351.0	1534.0	2925.0	0.0	-83.0	23.0	202.0	439.0	690.0	16.0	0.0	6648.0
26	575.0	365.0	1575.0	3025.0	0.0	-77.0	30.0	183.0	434.0	703.0	39.0	0.0	6852.0
27	551.0	355.0	1561.0	3009.0	0.0	-63.0	15.0	182.0	431.0	678.0	33.0	0.0	6752.0
28	598.0	370.0	1707.0	3299.0	0.0	-43.0	28.0	155.0	353.0	491.0	-21.0	0.0	6937.0
29	603.0	374.0	1695.0	3234.0	0.0	-38.0	32.0	171.0	349.0	446.0	-57.0	0.0	6809.0
30	556.0	356.0	1568.0	2941.0	0.0	-49.0	13.0	178.0	448.0	705.0	28.0	0.0	6744.0
31	568.0	364.0	1578.0	2997.0	0.0	-59.0	2.0	191.0	451.0	721.0	35.0	0.0	6848.0
<b>Monthly T...</b>	<b>18020.00</b>	<b>11352.00</b>	<b>50139.00</b>	<b>94916.00</b>	<b>0.00</b>	<b>-1941.00</b>	<b>66.00</b>	<b>5913.00</b>	<b>13002.00</b>	<b>19630.00</b>	<b>58.00</b>	<b>0.00</b>	<b>211155.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/03/2023 03:26:00 AM

Report Date From: 01/02/2023 12:00:00 AM

To: 01/03/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	562.0	355.0	1590.0	3016.0	0.0	-63.0	2.0	190.0	438.0	669.0	4.0	0.0	6763.0
2	554.0	360.0	1578.0	2958.0	0.0	-56.0	5.0	200.0	446.0	700.0	14.0	0.0	6759.0
3	560.0	363.0	1577.0	3002.0	0.0	-76.0	-8.0	203.0	435.0	675.0	9.0	0.0	6740.0
4	583.0	368.0	1691.0	3175.0	0.0	-39.0	29.0	187.0	365.0	512.0	-42.0	0.0	6829.0
5	671.0	397.0	1760.0	3275.0	0.0	-41.0	25.0	201.0	368.0	470.0	-76.0	0.0	7050.0
6	696.0	435.0	1656.0	3087.0	0.0	-64.0	1.0	168.0	427.0	687.0	37.0	0.0	7130.0
7	634.0	409.0	1643.0	3082.0	0.0	-69.0	3.0	185.0	437.0	702.0	38.0	0.0	7064.0
8	600.0	375.0	1592.0	3020.0	0.0	-81.0	-12.0	188.0	425.0	677.0	22.0	0.0	6806.0
9	536.0	350.0	1541.0	2914.0	0.0	-52.0	12.0	157.0	418.0	681.0	48.0	0.0	6605.0
10	540.0	354.0	1571.0	2959.0	0.0	-80.0	-11.0	195.0	454.0	704.0	34.0	0.0	6720.0
11	604.0	382.0	1722.0	3176.0	0.0	-18.0	45.0	156.0	357.0	499.0	-32.0	0.0	6891.0
12	621.0	379.0	1718.0	3181.0	0.0	-35.0	32.0	170.0	360.0	451.0	-69.0	0.0	6808.0
13	574.0	361.0	1570.0	2952.0	0.0	-60.0	7.0	194.0	448.0	687.0	21.0	0.0	6754.0
14	541.0	347.0	1547.0	2912.0	0.0	-59.0	5.0	193.0	439.0	676.0	29.0	0.0	6630.0
15	517.0	338.0	1555.0	2935.0	0.0	-47.0	15.0	190.0	437.0	656.0	13.0	0.0	6609.0
16	521.0	345.0	1557.0	2937.0	0.0	-46.0	20.0	188.0	422.0	641.0	13.0	0.0	6598.0
17	539.0	339.0	1567.0	2936.0	0.0	-57.0	16.0	181.0	420.0	660.0	30.0	0.0	6631.0
18	587.0	362.0	1693.0	3136.0	0.0	-26.0	41.0	166.0	352.0	508.0	-39.0	0.0	6780.0
19	564.0	348.0	1613.0	3047.0	0.0	-39.0	29.0	163.0	331.0	419.0	-70.0	0.0	6405.0
20	556.0	346.0	1623.0	3045.0	0.0	-56.0	5.0	164.0	369.0	532.0	-56.0	0.0	6528.0
21	563.0	360.0	1545.0	2904.0	0.0	-81.0	-12.0	194.0	431.0	671.0	24.0	0.0	6599.0
22	550.0	344.0	1518.0	2863.0	0.0	-66.0	0.0	140.0	324.0	541.0	29.0	0.0	6243.0
23	565.0	362.0	1578.0	2973.0	0.0	-56.0	10.0	80.0	163.0	246.0	60.0	0.0	5981.0
24	598.0	379.0	1584.0	2988.0	0.0	-69.0	-6.0	170.0	373.0	589.0	29.0	0.0	6635.0
25	606.0	383.0	1684.0	3137.0	0.0	-42.0	25.0	168.0	363.0	481.0	-29.0	0.0	6776.0
26	624.0	395.0	1729.0	3235.0	0.0	-46.0	26.0	180.0	349.0	413.0	-88.0	0.0	6817.0
27	585.0	373.0	1562.0	2942.0	0.0	-66.0	-2.0	190.0	427.0	654.0	5.0	0.0	6670.0
28	574.0	368.0	1562.0	2919.0	0.0	-87.0	-21.0	207.0	454.0	722.0	18.0	0.0	6716.0
<b>Monthly T...</b>	<b>16225.00</b>	<b>10277.00</b>	<b>45126.00</b>	<b>84706.00</b>	<b>0.00</b>	<b>-1577.00</b>	<b>281.00</b>	<b>4968.00</b>	<b>11032.00</b>	<b>16523.00</b>	<b>-24.00</b>	<b>0.00</b>	<b>187537.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/04/2023 03:26:00 AM

Report Date From: 01/03/2023 12:00:00 AM

To: 01/04/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	588.0	377.0	1596.0	3041.0	0.0	-56.0	5.0	227.0	463.0	708.0	13.0	0.0	6962.0
2	583.0	381.0	1590.0	3044.0	0.0	-26.0	30.0	181.0	428.0	683.0	28.0	0.0	6922.0
3	563.0	362.0	1556.0	2877.0	0.0	-57.0	10.0	85.0	149.0	201.0	-14.0	0.0	5732.0
4	597.0	381.0	1722.0	3173.0	0.0	-27.0	34.0	0.0	0.0	0.0	0.0	0.0	5880.0
5	623.0	395.0	1733.0	3175.0	0.0	-32.0	40.0	0.0	0.0	0.0	0.0	0.0	5934.0
6	574.0	364.0	1570.0	2915.0	0.0	-65.0	1.0	79.0	255.0	406.0	37.0	0.0	6136.0
7	600.0	380.0	1574.0	2907.0	0.0	-44.0	18.0	172.0	431.0	663.0	26.0	0.0	6727.0
8	695.0	432.0	1682.0	3376.0	0.0	48.0	110.0	191.0	450.0	687.0	18.0	0.0	7689.0
9	576.0	374.0	1565.0	2929.0	0.0	-55.0	14.0	174.0	432.0	689.0	43.0	0.0	6741.0
10	592.0	366.0	1574.0	2897.0	0.0	-37.0	31.0	146.0	387.0	586.0	18.0	0.0	6560.0
11	621.0	377.0	1694.0	3133.0	0.0	-40.0	30.0	170.0	355.0	468.0	-41.0	0.0	6767.0
12	552.0	336.0	1570.0	2876.0	0.0	-29.0	35.0	157.0	328.0	398.0	-59.0	0.0	6164.0
13	572.0	360.0	1554.0	2957.0	0.0	-27.0	39.0	154.0	404.0	621.0	25.0	0.0	6659.0
14	597.0	373.0	1556.0	2893.0	0.0	-48.0	18.0	172.0	427.0	672.0	29.0	0.0	6689.0
15	556.0	359.0	1536.0	2854.0	0.0	-70.0	-1.0	189.0	430.0	670.0	27.0	0.0	6550.0
16	536.0	345.0	1512.0	2825.0	0.0	-57.0	11.0	189.0	436.0	671.0	21.0	0.0	6489.0
17	540.0	352.0	1537.0	2854.0	0.0	-50.0	17.0	173.0	416.0	644.0	31.0	0.0	6514.0
18	597.0	372.0	1655.0	3033.0	0.0	-34.0	32.0	160.0	359.0	481.0	-36.0	0.0	6619.0
19	650.0	388.0	1702.0	3120.0	0.0	-5.0	62.0	139.0	346.0	428.0	-58.0	0.0	6772.0
20	580.0	362.0	1559.0	2918.0	0.0	-68.0	0.0	168.0	433.0	678.0	36.0	0.0	6666.0
21	597.0	369.0	1566.0	2918.0	0.0	-75.0	-3.0	161.0	441.0	687.0	38.0	0.0	6699.0
22	598.0	370.0	1555.0	2792.0	0.0	-54.0	12.0	167.0	438.0	695.0	42.0	0.0	6615.0
23	606.0	374.0	1549.0	2862.0	0.0	-75.0	-5.0	37.0	434.0	678.0	25.0	0.0	6485.0
24	621.0	384.0	1586.0	2907.0	0.0	-59.0	9.0	0.0	132.0	662.0	33.0	0.0	6275.0
25	312.0	188.0	957.0	1762.0	0.0	-29.0	16.0	0.0	0.0	320.0	-14.0	0.0	3512.0
26	934.0	378.0	1701.0	3087.0	0.0	-27.0	39.0	0.0	0.0	464.0	-46.0	0.0	6530.0
27	579.0	366.0	1551.0	2859.0	0.0	-79.0	-10.0	0.0	270.0	658.0	19.0	0.0	6213.0
28	583.0	361.0	1538.0	2798.0	0.0	-29.0	35.0	0.0	450.0	731.0	67.0	0.0	6534.0
29	588.0	363.0	1557.0	2888.0	0.0	-74.0	-4.0	0.0	443.0	668.0	17.0	0.0	6446.0
30	566.0	362.0	1550.0	2868.0	0.0	-72.0	-4.0	0.0	433.0	704.0	47.0	0.0	6454.0
31	570.0	363.0	1542.0	2889.0	0.0	-71.0	-2.0	0.0	394.0	629.0	46.0	0.0	6360.0
<b>Monthly T...</b>	<b>18346.00</b>	<b>11314.00</b>	<b>48689.00</b>	<b>90427.00</b>	<b>0.00</b>	<b>-1423.00</b>	<b>619.00</b>	<b>3291.00</b>	<b>10364.00</b>	<b>17250.00</b>	<b>418.00</b>	<b>0.00</b>	<b>199295.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/05/2023 03:26:00 AM

Report Date From: 01/04/2023 12:00:00 AM

To: 01/05/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	618.0	383.0	1718.0	3122.0	0.0	-34.0	34.0	0.0	344.0	472.0	-15.0	0.0	6642.0
2	620.0	390.0	1731.0	3164.0	0.0	-40.0	38.0	0.0	327.0	421.0	-24.0	0.0	6627.0
3	594.0	383.0	607.0	2914.0	0.0	-61.0	1.0	0.0	416.0	679.0	68.0	0.0	5601.0
4	578.0	371.0	0.0	2904.0	0.0	-80.0	-9.0	0.0	455.0	712.0	59.0	0.0	4990.0
5	584.0	376.0	1569.0	2917.0	0.0	-74.0	-3.0	0.0	435.0	718.0	70.0	0.0	6592.0
6	597.0	380.0	1585.0	2904.0	0.0	-72.0	-2.0	0.0	412.0	693.0	70.0	0.0	6567.0
7	659.0	409.0	1740.0	3159.0	0.0	-25.0	41.0	0.0	337.0	468.0	-21.0	0.0	6767.0
8	668.0	411.0	1755.0	3185.0	0.0	-29.0	37.0	0.0	324.0	445.0	-19.0	0.0	6777.0
9	668.0	401.0	1745.0	3152.0	0.0	-28.0	45.0	0.0	326.0	424.0	-33.0	0.0	6700.0
10	703.0	432.0	1754.0	3221.0	0.0	-47.0	23.0	0.0	455.0	725.0	39.0	0.0	7305.0
11	708.0	441.0	1705.0	3127.0	0.0	-84.0	-14.0	0.0	503.0	824.0	55.0	0.0	7265.0
12	719.0	445.0	1737.0	3140.0	0.0	-73.0	-5.0	109.0	528.0	862.0	46.0	0.0	7508.0
13	750.0	467.0	1791.0	3289.0	0.0	-75.0	3.0	0.0	531.0	866.0	47.0	0.0	7669.0
14	752.0	467.0	1763.0	3284.0	0.0	-97.0	-8.0	0.0	523.0	834.0	34.0	0.0	7552.0
15	848.0	508.0	1978.0	3600.0	0.0	-45.0	30.0	0.0	442.0	629.0	-24.0	0.0	7966.0
16	730.0	447.0	1833.0	3313.0	0.0	-26.0	51.0	0.0	383.0	515.0	-58.0	0.0	7188.0
17	673.0	434.0	1660.0	3051.0	0.0	-64.0	5.0	0.0	478.0	751.0	37.0	0.0	7025.0
18	684.0	433.0	1649.0	3031.0	0.0	-67.0	2.0	0.0	451.0	734.0	44.0	0.0	6961.0
19	738.0	463.0	1730.0	3179.0	0.0	-59.0	15.0	214.0	487.0	777.0	35.0	0.0	7579.0
20	736.0	452.0	1713.0	3172.0	0.0	-54.0	22.0	201.0	486.0	798.0	55.0	0.0	7581.0
21	730.0	445.0	1679.0	3089.0	0.0	-62.0	14.0	191.0	446.0	685.0	24.0	0.0	7241.0
22	715.0	440.0	1805.0	3304.0	0.0	-34.0	37.0	190.0	397.0	592.0	-31.0	0.0	7415.0
23	770.0	472.0	1844.0	3375.0	0.0	-19.0	51.0	181.0	375.0	547.0	-48.0	0.0	7548.0
24	828.0	526.0	1770.0	3241.0	0.0	-53.0	19.0	191.0	455.0	745.0	38.0	0.0	7760.0
25	779.0	492.0	1723.0	3164.0	0.0	-74.0	0.0	217.0	473.0	748.0	20.0	0.0	7542.0
26	815.0	508.0	1774.0	3259.0	0.0	-61.0	-10.0	201.0	480.0	787.0	41.0	0.0	7794.0
27	811.0	508.0	1790.0	3359.0	0.0	0.0	0.0	207.0	474.0	787.0	55.0	0.0	7991.0
28	736.0	463.0	1732.0	3151.0	0.0	1.0	20.0	184.0	442.0	693.0	28.0	0.0	7450.0
29	680.0	418.0	1776.0	3221.0	0.0	-21.0	46.0	147.0	386.0	571.0	-2.0	0.0	7222.0
30	735.0	457.0	1829.0	3304.0	0.0	-44.0	34.0	141.0	386.0	479.0	-62.0	0.0	7259.0
<b>Monthly T...</b>	<b>21226.00</b>	<b>13222.00</b>	<b>49485.00</b>	<b>95295.00</b>	<b>0.00</b>	<b>-1501.00</b>	<b>517.00</b>	<b>2374.00</b>	<b>12957.00</b>	<b>19981.00</b>	<b>528.00</b>	<b>0.00</b>	<b>214084.00</b>





**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/06/2023 03:26:00 AM

**Report Date From:** 01/05/2023 12:00:00 AM  
**To:** 01/06/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	834.0	527.0	1772.0	3233.0	0.0	-43.0	30.0	136.0	451.0	728.0	15.0	0.0	7683.0
2	674.0	432.0	1659.0	3063.0	0.0	-72.0	6.0	196.0	471.0	777.0	27.0	0.0	7233.0
3	725.0	462.0	1750.0	3196.0	0.0	-58.0	23.0	215.0	476.0	736.0	13.0	0.0	7538.0
4	800.0	502.0	1795.0	3342.0	0.0	-87.0	-7.0	239.0	492.0	733.0	-10.0	0.0	7799.0
5	830.0	512.0	1858.0	3451.0	0.0	-56.0	23.0	194.0	493.0	798.0	52.0	0.0	8155.0
6	946.0	572.0	2041.0	3761.0	0.0	-49.0	21.0	196.0	418.0	570.0	-47.0	0.0	8429.0
7	910.0	557.0	2077.0	3821.0	0.0	-13.0	65.0	194.0	400.0	508.0	-59.0	0.0	8460.0
8	913.0	577.0	1965.0	3683.0	0.0	-43.0	34.0	249.0	537.0	873.0	54.0	0.0	8842.0
9	1014.0	632.0	2064.0	3825.0	0.0	-49.0	19.0	242.0	569.0	974.0	85.0	0.0	9375.0
10	1097.0	683.0	2174.0	3986.0	0.0	-43.0	27.0	266.0	592.0	1001.0	77.0	0.0	9860.0
11	1168.0	717.0	2241.0	4149.0	0.0	-54.0	20.0	300.0	629.0	1061.0	79.0	0.0	10310.0
12	1080.0	679.0	2221.0	4081.0	0.0	-17.0	52.0	258.0	570.0	954.0	58.0	0.0	9936.0
13	1153.0	718.0	2361.0	4299.0	0.0	1.0	74.0	207.0	427.0	583.0	-51.0	0.0	9772.0
14	1123.0	692.0	2318.0	4284.0	0.0	-5.0	82.0	243.0	427.0	528.0	-90.0	0.0	9602.0
15	1178.0	721.0	2334.0	4325.0	0.0	-48.0	15.0	309.0	623.0	1034.0	38.0	0.0	10529.0
16	1163.0	708.0	2263.0	4240.0	0.0	-69.0	68.0	328.0	663.0	1102.0	41.0	0.0	10507.0
17	1083.0	671.0	2210.0	4121.0	0.0	-68.0	31.0	289.0	628.0	1074.0	60.0	0.0	10099.0
18	1048.0	652.0	2212.0	4102.0	0.0	-55.0	20.0	292.0	638.0	1086.0	57.0	0.0	10052.0
19	1041.0	647.0	2198.0	4029.0	0.0	-34.0	44.0	274.0	591.0	955.0	34.0	0.0	9779.0
20	924.0	565.0	2110.0	3870.0	0.0	-20.0	59.0	210.0	421.0	561.0	-52.0	0.0	8648.0
21	1053.0	642.0	2307.0	4311.0	0.0	-8.0	65.0	233.0	441.0	546.0	-84.0	0.0	9506.0
22	1107.0	666.0	2459.0	4602.0	0.0	-16.0	55.0	282.0	532.0	691.0	-97.0	0.0	10281.0
23	1229.0	746.0	2413.0	4453.0	0.0	-67.0	6.0	417.0	847.0	1499.0	148.0	0.0	11691.0
24	1194.0	738.0	2386.0	4426.0	0.0	-73.0	2.0	374.0	770.0	1385.0	115.0	0.0	11317.0
25	1073.0	661.0	2334.0	4379.0	0.0	-73.0	-8.0	379.0	762.0	1365.0	101.0	0.0	10973.0
26	1316.0	811.0	2625.0	4961.0	0.0	-44.0	26.0	399.0	727.0	1156.0	-43.0	0.0	11934.0
27	1526.0	880.0	2940.0	5522.0	0.0	15.0	91.0	367.0	633.0	877.0	-89.0	0.0	12762.0
28	1482.0	889.0	3006.0	5678.0	0.0	8.0	86.0	405.0	627.0	733.0	-203.0	0.0	12711.0
29	1533.0	916.0	3006.0	5657.0	0.0	-14.0	20.0	434.0	787.0	1183.0	-36.0	0.0	13486.0
30	1582.0	912.0	3101.0	5832.0	0.0	-14.0	2.0	450.0	811.0	1264.0	-56.0	0.0	13884.0
31	1833.0	1065.0	3356.0	6365.0	0.0	-5.0	8.0	470.0	852.0	1308.0	-65.0	0.0	15187.0
<b>Monthly T...</b>	<b>34632.00</b>	<b>21152.00</b>	<b>71556.00</b>	<b>133047.00</b>	<b>0.00</b>	<b>-1173.00</b>	<b>1059.00</b>	<b>9047.00</b>	<b>18305.00</b>	<b>28643.00</b>	<b>72.00</b>	<b>0.00</b>	<b>316340.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/07/2023 03:26:00 AM

**Report Date From:** 01/06/2023 12:00:00 AM

**To:** 01/07/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	2037.0	1179.0	3528.0	6615.0	0.0	-20.0	-1.0	515.0	875.0	1302.0	-98.0	0.0	15932.0
2	2048.0	1167.0	3536.0	6585.0	0.0	21.0	34.0	512.0	935.0	1461.0	-57.0	0.0	16242.0
3	2042.0	1175.0	3696.0	6889.0	0.0	52.0	78.0	440.0	749.0	1016.0	-174.0	0.0	15963.0
4	1933.0	1113.0	3608.0	6689.0	0.0	80.0	113.0	421.0	679.0	850.0	-194.0	0.0	15292.0
5	1739.0	1042.0	3263.0	6049.0	0.0	-61.0	-25.0	517.0	915.0	1451.0	-50.0	0.0	14840.0
6	1586.0	898.0	2985.0	5631.0	0.0	-106.0	-56.0	492.0	850.0	1348.0	-50.0	0.0	13578.0
7	1603.0	931.0	3035.0	5787.0	0.0	-66.0	-30.0	474.0	845.0	1347.0	-53.0	0.0	13873.0
8	1570.0	881.0	2958.0	5572.0	0.0	-51.0	-24.0	467.0	838.0	1384.0	1.0	0.0	13596.0
9	1739.0	1004.0	3225.0	6086.0	0.0	-26.0	-2.0	486.0	822.0	1267.0	-61.0	0.0	14540.0
10	1694.0	967.0	3241.0	6099.0	0.0	5.0	4.0	406.0	678.0	887.0	-172.0	0.0	13809.0
11	1304.0	723.0	2622.0	4850.0	0.0	-24.0	16.0	305.0	534.0	705.0	-127.0	0.0	10908.0
12	1029.0	602.0	2180.0	4060.0	0.0	-58.0	-42.0	273.0	583.0	989.0	42.0	0.0	9658.0
13	960.0	513.0	2099.0	3905.0	0.0	-120.0	-90.0	285.0	583.0	980.0	45.0	0.0	9160.0
14	989.0	576.0	2109.0	3998.0	0.0	-105.0	-71.0	334.0	636.0	1049.0	44.0	0.0	9559.0
15	1043.0	600.0	2095.0	4007.0	0.0	-189.0	-145.0	305.0	627.0	1051.0	51.0	0.0	9445.0
16	1056.0	615.0	2202.0	4126.0	0.0	-62.0	-23.0	296.0	593.0	958.0	28.0	0.0	9789.0
17	1300.0	730.0	2649.0	4959.0	0.0	-40.0	-20.0	359.0	631.0	924.0	-48.0	0.0	11444.0
18	1468.0	830.0	2891.0	5388.0	0.0	-27.0	17.0	384.0	597.0	752.0	-173.0	0.0	12127.0
19	1635.0	972.0	3012.0	5607.0	0.0	-133.0	-99.0	493.0	852.0	1354.0	-38.0	0.0	13655.0
20	1743.0	987.0	2867.0	5916.0	0.0	-64.0	-35.0	486.0	849.0	1378.0	33.0	0.0	14160.0
21	1872.0	1122.0	3270.0	6024.0	0.0	-35.0	9.0	473.0	866.0	1395.0	15.0	0.0	15011.0
22	1815.0	1087.0	3070.0	5613.0	0.0	-31.0	-7.0	421.0	794.0	1299.0	5.0	0.0	14066.0
23	1415.0	859.0	2598.0	4675.0	0.0	-46.0	-2.0	282.0	602.0	964.0	-23.0	0.0	11324.0
24	1418.0	842.0	2725.0	4948.0	0.0	-13.0	18.0	281.0	557.0	822.0	-55.0	0.0	11543.0
25	1487.0	875.0	2781.0	5036.0	0.0	-23.0	12.0	256.0	539.0	770.0	-69.0	0.0	11664.0
26	1240.0	759.0	2325.0	4181.0	0.0	-61.0	-28.0	205.0	561.0	966.0	63.0	0.0	10211.0
27	1175.0	674.0	2267.0	4095.0	0.0	-56.0	-33.0	263.0	584.0	1001.0	48.0	0.0	10018.0
28	941.0	807.0	1704.0	4417.0	0.0	-36.0	-2.0	264.0	619.0	1000.0	28.0	0.0	9742.0
29	1311.0	787.0	2457.0	4464.0	0.0	-39.0	3.0	257.0	649.0	1054.0	43.0	0.0	10986.0
30	1426.0	863.0	2716.0	4978.0	0.0	6.0	39.0	248.0	642.0	978.0	-7.0	0.0	11889.0
<b>Monthly T...</b>	<b>44618.00</b>	<b>26180.00</b>	<b>83714.00</b>	<b>157249.00</b>	<b>0.00</b>	<b>-1328.00</b>	<b>-392.00</b>	<b>11200.00</b>	<b>21084.00</b>	<b>32702.00</b>	<b>-1003.00</b>	<b>0.00</b>	<b>374024.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/08/2023 03:26:00 AM

**Report Date From:** 01/07/2023 12:00:00 AM  
**To:** 01/08/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1390.0	832.0	2710.0	4923.0	0.0	-3.0	25.0	231.0	571.0	790.0	-79.0	0.0	11390.0
2	1285.0	780.0	2445.0	4377.0	0.0	-33.0	10.0	150.0	471.0	666.0	-73.0	0.0	10078.0
3	1213.0	744.0	2365.0	4344.0	0.0	-45.0	-9.0	203.0	517.0	740.0	-68.0	0.0	10004.0
4	1195.0	687.0	2404.0	4452.0	0.0	-60.0	-38.0	284.0	706.0	1166.0	63.0	0.0	10859.0
5	1485.0	903.0	2756.0	5082.0	0.0	-51.0	-34.0	331.0	763.0	1231.0	18.0	0.0	12484.0
6	1676.0	1019.0	2819.0	5245.0	0.0	-292.0	-249.0	378.0	734.0	1150.0	-33.0	0.0	12447.0
7	1590.0	950.0	2879.0	5232.0	0.0	-38.0	7.0	355.0	753.0	1210.0	5.0	0.0	12943.0
8	1452.0	848.0	2631.0	4760.0	0.0	-33.0	15.0	240.0	563.0	823.0	-88.0	0.0	11211.0
9	1286.0	745.0	2467.0	4491.0	0.0	-27.0	26.0	219.0	510.0	695.0	-80.0	0.0	10332.0
10	1327.0	796.0	2598.0	4791.0	0.0	-59.0	-27.0	323.0	743.0	1206.0	44.0	0.0	11742.0
11	1566.0	902.0	2734.0	4975.0	0.0	-109.0	-71.0	341.0	719.0	1166.0	11.0	0.0	12234.0
12	1365.0	831.0	2447.0	4457.0	0.0	-61.0	-27.0	258.0	666.0	1102.0	38.0	0.0	11076.0
13	1367.0	838.0	2432.0	4380.0	0.0	-31.0	-5.0	228.0	594.0	951.0	16.0	0.0	10770.0
14	1499.0	906.0	2613.0	4698.0	0.0	-33.0	-5.0	259.0	633.0	1015.0	21.0	0.0	11606.0
15	1321.0	782.0	2414.0	4369.0	0.0	-16.0	17.0	198.0	495.0	740.0	-33.0	0.0	10287.0
16	1377.0	813.0	2509.0	4829.0	0.0	0.0	45.0	196.0	471.0	647.0	-66.0	0.0	10821.0
17	1509.0	914.0	2658.0	5392.0	0.0	25.0	47.0	256.0	611.0	975.0	23.0	0.0	12410.0
18	1661.0	961.0	2758.0	5826.0	0.0	-250.0	-213.0	423.0	701.0	1055.0	-71.0	0.0	12851.0
19	1490.0	893.0	2688.0	5604.0	0.0	-33.0	-2.0	347.0	761.0	1230.0	41.0	0.0	13019.0
20	1285.0	761.0	2400.0	5205.0	0.0	-22.0	14.0	271.0	666.0	1096.0	26.0	0.0	11702.0
21	1546.0	939.0	2667.0	5203.0	0.0	45.0	74.0	238.0	601.0	970.0	28.0	0.0	12311.0
22	1353.0	787.0	2600.0	5161.0	0.0	20.0	56.0	235.0	558.0	833.0	-35.0	0.0	11568.0
23	1493.0	870.0	2653.0	5034.0	0.0	45.0	76.0	195.0	483.0	668.0	-76.0	0.0	11441.0
24	1568.0	956.0	2605.0	4995.0	0.0	23.0	49.0	203.0	628.0	1060.0	71.0	0.0	12158.0
25	1536.0	892.0	2586.0	5021.0	0.0	34.0	61.0	243.0	641.0	1054.0	62.0	0.0	12130.0
26	1531.0	920.0	2561.0	4744.0	0.0	7.0	40.0	240.0	632.0	1037.0	44.0	0.0	11756.0
27	1415.0	855.0	2414.0	4370.0	0.0	-44.0	-7.0	203.0	607.0	1017.0	82.0	0.0	10912.0
28	1433.0	882.0	2501.0	4565.0	0.0	-66.0	-23.0	208.0	578.0	913.0	42.0	0.0	11033.0
29	1228.0	737.0	2350.0	4263.0	0.0	-40.0	-1.0	169.0	492.0	726.0	-11.0	0.0	9913.0
30	1327.0	793.0	2500.0	4568.0	0.0	-20.0	15.0	195.0	478.0	648.0	-64.0	0.0	10440.0
31	1390.0	861.0	2512.0	4625.0	0.0	-21.0	15.0	245.0	630.0	1030.0	38.0	0.0	11325.0
<b>Monthly T...</b>	<b>44159.00</b>	<b>26397.00</b>	<b>79676.00</b>	<b>149981.00</b>	<b>0.00</b>	<b>-1188.00</b>	<b>-119.00</b>	<b>7865.00</b>	<b>18976.00</b>	<b>29610.00</b>	<b>-104.00</b>	<b>0.00</b>	<b>355253.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/09/2023 03:26:00 AM

Report Date From: 01/08/2023 12:00:00 AM

To: 01/09/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1329.0	780.0	2424.0	4391.0	0.0	-43.0	-6.0	253.0	615.0	985.0	16.0	0.0	10744.0
2	1483.0	908.0	2608.0	4832.0	0.0	-37.0	-15.0	312.0	688.0	1081.0	11.0	0.0	11871.0
3	1396.0	835.0	2570.0	4850.0	0.0	-36.0	-10.0	345.0	731.0	1149.0	32.0	0.0	11862.0
4	1403.0	845.0	2602.0	4863.0	0.0	-22.0	6.0	308.0	698.0	1111.0	17.0	0.0	11831.0
5	1491.0	896.0	2737.0	5022.0	0.0	2.0	28.0	286.0	587.0	804.0	-88.0	0.0	11765.0
6	1335.0	800.0	2423.0	4378.0	0.0	-30.0	7.0	236.0	504.0	676.0	-84.0	0.0	10245.0
7	1366.0	836.0	2449.0	4406.0	0.0	-31.0	-1.0	201.0	526.0	778.0	-34.0	0.0	10496.0
8	1494.0	882.0	2570.0	4660.0	0.0	-44.0	-2.0	284.0	706.0	1155.0	67.0	0.0	11772.0
9	1811.0	1112.0	2952.0	5279.0	0.0	-2.0	28.0	302.0	744.0	1223.0	75.0	0.0	13524.0
10	1633.0	1001.0	2781.0	4978.0	0.0	-2.0	46.0	282.0	712.0	1212.0	87.0	0.0	12730.0
11	1714.0	1064.0	2880.0	5070.0	0.0	24.0	57.0	243.0	633.0	1044.0	67.0	0.0	12796.0
12	1572.0	966.0	2707.0	4793.0	0.0	12.0	49.0	203.0	529.0	793.0	12.0	0.0	11636.0
13	1482.0	906.0	2691.0	4744.0	0.0	17.0	61.0	219.0	500.0	687.0	-39.0	0.0	11268.0
14	1326.0	816.0	2432.0	4338.0	0.0	-29.0	9.0	245.0	611.0	1014.0	55.0	0.0	10817.0
15	1218.0	746.0	2280.0	3987.0	0.0	-46.0	-4.0	223.0	590.0	991.0	72.0	0.0	10057.0
16	1359.0	848.0	2441.0	4452.0	0.0	-20.0	19.0	255.0	623.0	1016.0	38.0	0.0	11031.0
17	1322.0	812.0	2329.0	4178.0	0.0	-36.0	5.0	203.0	578.0	985.0	65.0	0.0	10441.0
18	1486.0	900.0	2444.0	4354.0	0.0	-14.0	29.0	189.0	571.0	964.0	61.0	0.0	10984.0
19	1765.0	1055.0	2848.0	5050.0	0.0	34.0	70.0	197.0	524.0	759.0	-43.0	0.0	12259.0
20	1631.0	983.0	2681.0	5107.0	0.0	35.0	82.0	214.0	510.0	687.0	-87.0	0.0	11843.0
21	1716.0	1052.0	2843.0	5110.0	0.0	16.0	26.0	255.0	655.0	1030.0	14.0	0.0	12717.0
22	1696.0	1022.0	2791.0	4942.0	0.0	19.0	30.0	270.0	646.0	1029.0	12.0	0.0	12457.0
23	1651.0	1047.0	2686.0	4703.0	0.0	4.0	34.0	223.0	591.0	943.0	1.0	0.0	11883.0
24	1513.0	904.0	2502.0	4134.0	0.0	-20.0	-2.0	195.0	568.0	894.0	-14.0	0.0	10674.0
25	1653.0	1035.0	2648.0	754.0	0.0	13.0	56.0	156.0	547.0	880.0	33.0	0.0	7775.0
26	1452.0	889.0	2480.0	0.0	0.0	3.0	40.0	169.0	479.0	694.0	-28.0	0.0	6178.0
27	1455.0	885.0	2512.0	0.0	0.0	-1.0	44.0	171.0	454.0	618.0	-71.0	0.0	6067.0
28	1554.0	959.0	2564.0	0.0	0.0	-21.0	18.0	209.0	598.0	965.0	33.0	0.0	6879.0
29	1661.0	1009.0	2649.0	0.0	0.0	-17.0	24.0	216.0	609.0	984.0	33.0	0.0	7168.0
30	1526.0	963.0	2497.0	0.0	0.0	23.0	54.0	199.0	574.0	913.0	24.0	0.0	6773.0
31	1794.0	1099.0	2798.0	0.0	0.0	14.0	45.0	247.0	629.0	1025.0	21.0	0.0	7672.0
<b>Monthly T...</b>	<b>47287.00</b>	<b>28855.00</b>	<b>80819.00</b>	<b>113375.00</b>	<b>0.00</b>	<b>-235.00</b>	<b>827.00</b>	<b>7310.00</b>	<b>18530.00</b>	<b>29089.00</b>	<b>358.00</b>	<b>0.00</b>	<b>326215.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/10/2023 03:26:00 AM

Report Date From: 01/09/2023 12:00:00 AM

To: 01/10/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1859.0	1155.0	2966.0	0.0	0.0	58.0	94.0	263.0	630.0	1018.0	0.0	0.0	8043.0
2	1920.0	1179.0	3083.0	0.0	0.0	63.0	101.0	234.0	531.0	741.0	0.0	0.0	7852.0
3	1850.0	1131.0	3025.0	0.0	0.0	69.0	108.0	211.0	505.0	671.0	0.0	0.0	7570.0
4	1948.0	1177.0	3290.0	0.0	0.0	82.0	120.0	274.0	571.0	698.0	0.0	0.0	8160.0
5	1922.0	1171.0	3084.0	0.0	0.0	14.0	38.0	287.0	680.0	1062.0	33.0	0.0	8291.0
6	1801.0	1134.0	2881.0	0.0	0.0	-10.0	27.0	251.0	656.0	1061.0	6.0	0.0	7807.0
7	1659.0	1023.0	2691.0	0.0	0.0	-9.0	18.0	232.0	590.0	936.0	3.0	0.0	7143.0
8	1745.0	1079.0	2817.0	0.0	0.0	29.0	57.0	226.0	591.0	933.0	12.0	0.0	7489.0
9	1039.0	648.0	1786.0	0.0	0.0	14.0	36.0	165.0	346.0	497.0	-42.0	0.0	4489.0
10	750.0	453.0	1175.0	0.0	0.0	68.0	47.0	82.0	512.0	666.0	-47.0	0.0	3706.0
11	1805.0	1123.0	2842.0	0.0	0.0	27.0	51.0	266.0	647.0	1056.0	39.0	0.0	7856.0
12	1667.0	1018.0	2618.0	0.0	0.0	7.0	19.0	241.0	625.0	1054.0	69.0	0.0	7318.0
13	1643.0	1041.0	2626.0	2617.0	0.0	15.0	30.0	251.0	596.0	982.0	31.0	0.0	9832.0
14	1559.0	951.0	2567.0	4435.0	0.0	14.0	40.0	223.0	602.0	1003.0	45.0	0.0	11439.0
15	1702.0	1056.0	2755.0	4778.0	0.0	26.0	53.0	240.0	616.0	996.0	35.0	0.0	12257.0
16	1744.0	1060.0	2871.0	4916.0	0.0	33.0	67.0	240.0	521.0	731.0	-49.0	0.0	12134.0
17	1771.0	1091.0	2895.0	4931.0	0.0	47.0	83.0	225.0	461.0	591.0	-103.0	0.0	11992.0
18	1672.0	1030.0	2750.0	4757.0	0.0	47.0	74.0	227.0	575.0	935.0	39.0	0.0	12106.0
19	1704.0	1045.0	2750.0	4727.0	0.0	23.0	53.0	258.0	607.0	989.0	45.0	0.0	12201.0
20	1772.0	1119.0	2852.0	4899.0	0.0	43.0	67.0	250.0	609.0	988.0	38.0	0.0	12637.0
21	1759.0	1082.0	2844.0	4917.0	0.0	43.0	71.0	298.0	619.0	975.0	17.0	0.0	12625.0
22	1713.0	1062.0	2867.0	5019.0	0.0	37.0	69.0	285.0	641.0	1009.0	28.0	0.0	12730.0
23	1677.0	1030.0	2912.0	5100.0	0.0	62.0	95.0	286.0	564.0	805.0	-46.0	0.0	12485.0
24	1675.0	1019.0	2896.0	5030.0	0.0	50.0	98.0	236.0	511.0	692.0	-93.0	0.0	12114.0
25	1534.0	953.0	2611.0	4548.0	0.0	21.0	55.0	267.0	615.0	991.0	16.0	0.0	11611.0
26	1603.0	987.0	2637.0	4469.0	0.0	23.0	58.0	241.0	584.0	945.0	22.0	0.0	11569.0
27	1645.0	1039.0	2637.0	4534.0	0.0	18.0	52.0	241.0	576.0	934.0	15.0	0.0	11691.0
28	1273.0	783.0	2249.0	3891.0	0.0	-10.0	26.0	230.0	551.0	888.0	19.0	0.0	9900.0
29	1269.0	781.0	2288.0	3979.0	0.0	-12.0	17.0	220.0	524.0	804.0	-5.0	0.0	9865.0
30	1367.0	830.0	2505.0	4313.0	0.0	26.0	58.0	224.0	482.0	664.0	-68.0	0.0	10401.0
<b>Monthly T...</b>	<b>49047.00</b>	<b>30250.00</b>	<b>80770.00</b>	<b>81860.00</b>	<b>0.00</b>	<b>918.00</b>	<b>1782.00</b>	<b>7174.00</b>	<b>17138.00</b>	<b>26315.00</b>	<b>59.00</b>	<b>0.00</b>	<b>295313.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/11/2023 03:26:00 AM

**Report Date From:** 01/10/2023 12:00:00 AM

**To:** 01/11/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1483.0	899.0	2627.0	4518.0	0.0	31.0	66.0	211.0	453.0	572.0	-104.0	0.0	10756.0
2	1450.0	888.0	2525.0	4400.0	0.0	-1.0	26.0	255.0	590.0	902.0	-16.0	0.0	11019.0
3	1543.0	943.0	2595.0	4490.0	0.0	10.0	38.0	244.0	610.0	966.0	18.0	0.0	11457.0
4	1702.0	1078.0	2741.0	4578.0	0.0	3.0	35.0	246.0	585.0	900.0	-25.0	0.0	11843.0
5	1598.0	988.0	2570.0	4355.0	0.0	-3.0	31.0	191.0	538.0	797.0	4.0	0.0	11069.0
6	1592.0	986.0	2567.0	4375.0	0.0	20.0	52.0	148.0	486.0	747.0	-1.0	0.0	10972.0
7	1443.0	883.0	2512.0	4280.0	0.0	36.0	68.0	166.0	412.0	560.0	-70.0	0.0	10290.0
8	1489.0	906.0	2508.0	4293.0	0.0	34.0	68.0	178.0	413.0	551.0	-72.0	0.0	10368.0
9	1436.0	879.0	2519.0	4354.0	0.0	46.0	81.0	169.0	438.0	593.0	-76.0	0.0	10439.0
10	1262.0	766.0	2235.0	3852.0	0.0	3.0	30.0	233.0	548.0	888.0	29.0	0.0	9846.0
11	1361.0	858.0	2302.0	3962.0	0.0	23.0	46.0	260.0	516.0	840.0	38.0	0.0	10206.0
12	1403.0	887.0	2341.0	4087.0	0.0	35.0	64.0	228.0	514.0	854.0	52.0	0.0	10465.0
13	1467.0	927.0	2388.0	4041.0	0.0	21.0	53.0	218.0	485.0	766.0	25.0	0.0	10391.0
14	1530.0	970.0	2529.0	4222.0	0.0	50.0	81.0	185.0	424.0	585.0	-39.0	0.0	10537.0
15	1544.0	970.0	2584.0	4322.0	0.0	46.0	71.0	179.0	399.0	486.0	-83.0	0.0	10518.0
16	1415.0	890.0	2352.0	3952.0	0.0	10.0	37.0	223.0	505.0	763.0	-2.0	0.0	10145.0
17	1337.0	855.0	2288.0	3836.0	0.0	4.0	34.0	192.0	504.0	789.0	15.0	0.0	9854.0
18	1315.0	832.0	2268.0	3858.0	0.0	3.0	38.0	233.0	224.0	784.0	17.0	0.0	9572.0
19	1261.0	795.0	2198.0	3778.0	0.0	26.0	53.0	206.0	0.0	808.0	25.0	0.0	9150.0
20	1257.0	792.0	2212.0	3999.0	0.0	67.0	98.0	203.0	0.0	759.0	6.0	0.0	9393.0
21	1337.0	838.0	2387.0	4316.0	0.0	91.0	126.0	186.0	0.0	574.0	-48.0	0.0	9807.0
22	1218.0	758.0	2292.0	4107.0	0.0	62.0	99.0	182.0	0.0	494.0	-81.0	0.0	9131.0
23	1166.0	729.0	2115.0	3682.0	0.0	1.0	31.0	209.0	0.0	746.0	5.0	0.0	8684.0
24	1166.0	725.0	2108.0	3743.0	0.0	5.0	38.0	220.0	0.0	796.0	3.0	0.0	8804.0
25	1084.0	673.0	2021.0	3551.0	0.0	-23.0	19.0	205.0	504.0	764.0	-11.0	0.0	8787.0
26	935.0	584.0	1867.0	3238.0	0.0	-28.0	3.0	199.0	505.0	778.0	2.0	0.0	8083.0
27	1124.0	703.0	2080.0	3564.0	0.0	-5.0	21.0	171.0	481.0	728.0	-4.0	0.0	8863.0
28	1064.0	661.0	2094.0	3577.0	0.0	-7.0	27.0	190.0	404.0	516.0	-73.0	0.0	8453.0
29	920.0	618.0	2135.0	3763.0	0.0	3.0	41.0	196.0	378.0	438.0	-99.0	0.0	8393.0
30	918.0	647.0	2091.0	3534.0	0.0	8.0	64.0	215.0	530.0	849.0	30.0	0.0	8886.0
31	1048.0	652.0	1953.0	3352.0	0.0	-28.0	54.0	209.0	496.0	764.0	6.0	0.0	8506.0
<b>Monthly T...</b>	<b>40868.00</b>	<b>25580.00</b>	<b>72004.00</b>	<b>123979.00</b>	<b>0.00</b>	<b>543.00</b>	<b>1593.00</b>	<b>6350.00</b>	<b>11942.00</b>	<b>22357.00</b>	<b>-529.00</b>	<b>0.00</b>	<b>304687.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/12/2023 03:26:00 AM

**Report Date From:** 01/11/2023 12:00:00 AM  
**To:** 01/12/2023 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1071.0	669.0	2019.0	3473.0	0.0	-50.0	31.0	233.0	523.0	810.0	2.0	0.0	8781.0
2	1072.0	673.0	1989.0	3471.0	0.0	-26.0	55.0	237.0	536.0	854.0	22.0	0.0	8883.0
3	732.0	663.0	2011.0	3433.0	0.0	0.0	75.0	201.0	494.0	773.0	30.0	0.0	8412.0
4	0.0	664.0	2110.0	3596.0	0.0	7.0	70.0	199.0	425.0	558.0	-62.0	0.0	7567.0
5	0.0	1178.0	3396.0	5815.0	0.0	-95.0	-16.0	435.0	653.0	717.0	-198.0	0.0	11885.0
6	1080.0	637.0	1962.0	3359.0	0.0	-12.0	61.0	188.0	489.0	753.0	7.0	0.0	8524.0
7	1082.0	673.0	2004.0	3439.0	0.0	-27.0	48.0	326.0	546.0	711.0	-54.0	0.0	8748.0
8	942.0	589.0	1884.0	3244.0	0.0	-26.0	53.0	228.0	510.0	764.0	2.0	0.0	8190.0
9	1031.0	641.0	1957.0	3374.0	0.0	-22.0	53.0	224.0	512.0	780.0	17.0	0.0	8567.0
10	1023.0	640.0	1962.0	3391.0	0.0	-48.0	36.0	256.0	532.0	790.0	-12.0	0.0	8570.0
11	1093.0	675.0	2122.0	3625.0	0.0	-2.0	78.0	212.0	482.0	694.0	-19.0	0.0	8960.0
12	991.0	618.0	2066.0	3483.0	0.0	48.0	133.0	103.0	429.0	641.0	14.0	0.0	8526.0
13	1049.0	655.0	1986.0	3363.0	0.0	-9.0	69.0	218.0	507.0	782.0	21.0	0.0	8641.0
14	973.0	617.0	1957.0	3418.0	0.0	9.0	86.0	165.0	455.0	719.0	7.0	0.0	8406.0
15	918.0	559.0	1857.0	3203.0	0.0	-21.0	39.0	226.0	495.0	720.0	-23.0	0.0	7973.0
16	955.0	590.0	1862.0	3215.0	0.0	-45.0	8.0	215.0	492.0	713.0	-29.0	0.0	7976.0
17	985.0	616.0	1909.0	3300.0	0.0	-49.0	-1.0	229.0	468.0	678.0	-23.0	0.0	8112.0
18	971.0	597.0	1983.0	3444.0	0.0	-48.0	-12.0	275.0	418.0	497.0	-96.0	0.0	8029.0
19	1028.0	649.0	2082.0	3486.0	0.0	85.0	111.0	59.0	365.0	545.0	-13.0	0.0	8397.0
20	1053.0	660.0	2001.0	3397.0	0.0	16.0	36.0	221.0	494.0	737.0	-12.0	0.0	8603.0
21	1463.0	926.0	2380.0	3897.0	0.0	60.0	81.0	172.0	451.0	710.0	3.0	0.0	10143.0
22	1069.0	670.0	1998.0	3385.0	0.0	8.0	32.0	199.0	492.0	786.0	20.0	0.0	8659.0
23	1016.0	633.0	1929.0	3304.0	0.0	4.0	30.0	186.0	483.0	771.0	26.0	0.0	8382.0
24	1116.0	684.0	2006.0	3419.0	0.0	18.0	47.0	179.0	472.0	776.0	34.0	0.0	8751.0
25	1063.0	654.0	2081.0	3583.0	0.0	-37.0	-2.0	244.0	429.0	567.0	-74.0	0.0	8508.0
26	1074.0	663.0	2146.0	3648.0	0.0	-16.0	9.0	198.0	427.0	584.0	-63.0	0.0	8670.0
27	1036.0	643.0	1981.0	3535.0	0.0	-7.0	5.0	179.0	476.0	777.0	35.0	0.0	8660.0
28	910.0	570.0	1870.0	3251.0	0.0	0.0	-4.0	203.0	487.0	769.0	7.0	0.0	8063.0
29	1021.0	635.0	1949.0	3374.0	0.0	5.0	9.0	163.0	469.0	758.0	31.0	0.0	8414.0
30	1062.0	665.0	2017.0	3457.0	0.0	15.0	13.0	177.0	486.0	794.0	41.0	0.0	8727.0
<b>Monthly T...</b>	<b>28879.00</b>	<b>20006.00</b>	<b>61476.00</b>	<b>105382.00</b>	<b>0.00</b>	<b>-265.00</b>	<b>1233.00</b>	<b>6350.00</b>	<b>14497.00</b>	<b>21528.00</b>	<b>-359.00</b>	<b>0.00</b>	<b>258727.00</b>



**Monthly Report  
Meter Chamber  
Net Flow Totals**

**Town of Tecumseh  
Water System  
Reports**  
M\_FlowTotal\_Net\_MCx  
01/01/2024 03:26:00 AM

Report Date From: 01/12/2023 12:00:00 AM

To: 01/01/2024 12:00:00 AM

Day of the Month	MCT01 (m3)	MCT02 (m3)	MCT03 (m3)	MCT04 (m3)	MCT05 (m3)	MCT06 (m3)	MCT07 (m3)	MCT08 (m3)	MCT09 (m3)	MCT10 (m3)	MCT11 (m3)	MCT12 (m3)	System Total (m3)
1	1112.0	695.0	2058.0	3733.0	0.0	38.0	28.0	178.0	434.0	658.0	2.0	0.0	8936.0
2	1158.0	710.0	2186.0	3806.0	0.0	-84.0	-70.0	304.0	437.0	430.0	-139.0	0.0	8738.0
3	1107.0	683.0	2170.0	3759.0	0.0	-61.0	-53.0	325.0	432.0	384.0	-170.0	0.0	8576.0
4	1109.0	691.0	2064.0	3515.0	0.0	39.0	37.0	145.0	472.0	756.0	33.0	0.0	8861.0
5	994.0	618.0	1943.0	3369.0	0.0	-17.0	-18.0	217.0	509.0	759.0	1.0	0.0	8375.0
6	1021.0	628.0	1967.0	3419.0	0.0	-5.0	-2.0	205.0	496.0	738.0	-3.0	0.0	8464.0
7	1029.0	635.0	1977.0	3400.0	0.0	-14.0	-13.0	237.0	500.0	735.0	-4.0	0.0	8482.0
8	1027.0	631.0	1961.0	3384.0	0.0	-9.0	-7.0	212.0	501.0	757.0	24.0	0.0	8481.0
9	997.0	611.0	2045.0	3518.0	0.0	9.0	14.0	200.0	423.0	547.0	-52.0	0.0	8312.0
10	1023.0	629.0	2089.0	3588.0	0.0	13.0	21.0	196.0	402.0	468.0	-85.0	0.0	8344.0
11	1122.0	694.0	2060.0	3567.0	0.0	30.0	29.0	204.0	494.0	741.0	14.0	0.0	8955.0
12	1114.0	690.0	2040.0	3484.0	0.0	8.0	6.0	214.0	495.0	737.0	9.0	0.0	8797.0
13	1105.0	689.0	2042.0	3489.0	0.0	13.0	20.0	215.0	496.0	731.0	-1.0	0.0	8799.0
14	990.0	607.0	1939.0	3343.0	0.0	5.0	33.0	220.0	501.0	742.0	1.0	0.0	8381.0
15	976.0	606.0	1924.0	3344.0	0.0	4.0	34.0	216.0	490.0	726.0	5.0	0.0	8325.0
16	801.0	492.0	1884.0	3283.0	0.0	8.0	41.0	196.0	417.0	557.0	-55.0	0.0	7624.0
17	669.0	409.0	1734.0	3044.0	0.0	3.0	41.0	191.0	407.0	507.0	-78.0	0.0	6927.0
18	638.0	394.0	1624.0	2890.0	0.0	-13.0	16.0	250.0	798.0	789.0	49.0	0.0	7435.0
19	649.0	395.0	1624.0	2909.0	0.0	-14.0	14.0	219.0	484.0	725.0	4.0	0.0	7009.0
20	638.0	386.0	1627.0	2919.0	0.0	-23.0	11.0	211.0	484.0	725.0	0.0	0.0	6978.0
21	606.0	374.0	1627.0	2906.0	0.0	-22.0	10.0	206.0	490.0	731.0	13.0	0.0	6941.0
22	629.0	391.0	1647.0	3108.0	0.0	-21.0	13.0	190.0	455.0	655.0	-15.0	0.0	7052.0
23	649.0	397.0	1765.0	3248.0	0.0	-3.0	26.0	184.0	405.0	510.0	-75.0	0.0	7106.0
24	654.0	393.0	1733.0	3118.0	0.0	-4.0	43.0	185.0	388.0	446.0	-96.0	0.0	6860.0
25	595.0	348.0	1608.0	2920.0	0.0	15.0	65.0	120.0	358.0	434.0	-71.0	0.0	6392.0
26	602.0	357.0	1614.0	2914.0	0.0	1.0	28.0	137.0	366.0	452.0	-67.0	0.0	6404.0
27	551.0	340.0	1581.0	2848.0	0.0	-3.0	26.0	152.0	411.0	561.0	-35.0	0.0	6432.0
28	554.0	344.0	1570.0	2817.0	0.0	-15.0	12.0	166.0	424.0	563.0	-36.0	0.0	6399.0
29	545.0	342.0	1583.0	2843.0	0.0	-23.0	8.0	176.0	404.0	512.0	-57.0	0.0	6333.0
30	558.0	341.0	1657.0	2954.0	0.0	-6.0	30.0	149.0	382.0	467.0	-70.0	0.0	6462.0
31	552.0	325.0	1630.0	2922.0	0.0	-31.0	8.0	183.0	388.0	434.0	-104.0	0.0	6307.0
<b>Monthly T...</b>	<b>25774.00</b>	<b>15845.00</b>	<b>56973.00</b>	<b>100361.00</b>	<b>0.00</b>	<b>-182.00</b>	<b>451.00</b>	<b>6203.00</b>	<b>14143.00</b>	<b>18977.00</b>	<b>-1058.00</b>	<b>0.00</b>	<b>237487.00</b>