


Ontario Drinking-Water Systems Regulation O. Reg. 170/03
OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	260004969
Drinking-Water System Name:	Town of Tecumseh Distribution System
Drinking-Water System Owner:	The Corporation of The Town of Tecumseh
Drinking-Water System Category:	Large Municipal Residential
Period being reported:	01- January -2024 to 31- December – 2024

Complete if your Category is Large Municipal Residential or Small Municipal Residential

Does your Drinking-Water System serve more than 10,000 people? Yes [X] No []

Is your annual report available to the public at no charge on a web site on the Internet?

Yes [X] No []

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.

Town of Tecumseh Municipal Office
917 Lesperance Road
Tecumseh, Ontario
N8N 1W9

Complete for all other Categories.

Number of Designated Facilities served:

N/A

Did you provide a copy of your annual report to all Designated Facilities you serve?

Yes [] No []

Number of Interested Authorities you report to:

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?

2

Yes [X] No []

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
Lakeshore Dist. System	260004982

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes [X] No []

Indicate how you notified system users that your annual report is available and is free of charge.

- [X] Public access/notice via the web
 [] Public access/notice via Government Office
 [] Public access/notice via a newspaper



Public access/notice via Public Request

Public access/notice via a Public Library

Public access/notice via other method _____

Describe your Drinking-Water System

Water Distribution System

The Town of Tecumseh, City of Windsor and the Windsor Utilities Commission (WUC) entered into a 50-year Service Agreement in November 2004. The Service Agreement was implemented on March 31, 2006 when four boundary metering chambers were installed and maintained by the Town of Tecumseh. Tecumseh’s drinking water system also includes a water tower located on Tecumseh Road, with no re-chlorination stations within the distribution system

Prior to August 1, 2008, WUC provided water to 2,400 residents in the former Township of Sandwich South, south of Highway 401 (“South Water Area”). The Town installed eight additional boundary meter chambers and assumed the responsibility for the operations and maintenance of the water distribution system from WUC in this South Water Area effective August 1, 2008.

The Town of Tecumseh and the Town of Lakeshore entered into an agreement on May 13, 2003 whereby the Tecumseh distribution system supplies drinking water to the Lakeshore distribution system. This agreement expired on December 31, 2007 and is currently being renegotiated; the status quo is maintained until a new agreement is signed.

List all water treatment chemicals used over this reporting period

N/A

Were any significant expenses incurred to?

No Yes Install required equipment

No Yes Repair required equipment

No Yes Replace required equipment- PWES-2024-07

Please provide a brief description and a breakdown of monetary expenses incurred:

The PWES Capital works plan encompassed several key projects in 2024:

1. Southfield Park - Addition of 220m of 200mm diameter new PVC watermain
 - Scope: Extension of 200mm PVC watermain (via directional drilling and open cut) from the existing 200mm main located at the end of the Arbour Street cul-de-sac, westerly through Southfield Park, and tying into the existing 200mm main along Southfield Drive. A total of approximately 220m of new watermain.
 - Location: Southfield Drive and Arbour Street Cul-de-sac (Southfield Park)
 - Construction: Directionally drilled and open cut 200mm diameter PVC watermain
 - Total Project Costs: \$268,000 (including 1.76% HST)

2. County Road 42 and County Road 43 Improvements, Phase 2
 - Scope: Replacement of approximately 230m of existing 200mm cast iron diameter watermain with 200mm diameter PVC watermain along Banwell Road from County Road 42 northerly, including abandonment of existing watermain.
In addition to approximately 1250m extension of 600mm diameter PVC trunk watermain along Banwell Road and County Road 43 from County Road 42 to Canadian Pacific Railway. Components: watermains, and restoration
 - Purpose: Facilitating utility relocations for road improvements and serving for County Road 43 Diversion
 - Estimated Project Costs (Tecumseh's portion): \$2,463,000 (including 1.76% HST)
3. Meter Chamber MCT-06 (10005 County Rd 42) Inline Pressure Transmitter Replacement:
 - Total Cost: \$22,840.66 (excluding HST)
4. Replacement of 6 Auto Flushing Stations
 - Total Cost: \$45,000 (excluding HST)

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
None					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw	N/A				
Treated	N/A				
Distribution	530	0 to 0	0 to 0	159	0 to 180

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity	N/A	
Chlorine <i>Tecumseh Water Tower</i>	8760	Max 1.21 Min 0.74
Chlorine <i>Distribution Free Chlorine Residuals</i>	1669	Max 1.66 Min 0.37
Fluoride (If the DWS provides fluoridation)	N/A	

NOTE: For continuous monitors use 8760 as the number of samples.



*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
N/A				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
*Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

*Only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type Distribution	Number of Samples	Alkalinity Result (range 30-500)	Lead Result (range 0-0.01)	Unit of Measure	Field pH (range 0-14)	Number of Exceedances
Winter Session – Collection Date: March 28, 2024						
1620 Shawnee	1	95	0.00008	Mg/L	7.13	None
307 Arlington	1	92	0.00035	Mg/L	7.18	
12325 Meconi	1	94	<0.00002	Mg/L	7.17	
5125 Hennin	1	92	0.00007	Mg/L	7.29	
Summer Session – Collection Date: September 17, 2024						
307 Arlington	1	75	0.00011	Mg/L	7.19	None
1620 Shawnee	1	76	0.00006	Mg/L	7.17	
12325 Meconi	1	75	0.00006	Mg/L	7.22	
5125 Hennin	1	78	0.00006	Mg/L	7.37	



Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2-4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Haloacetic Acids (HAAs) (NOTE: show latest running annual average)	quarterly	5.0	µg/L	None
Heptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				

Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				
Simazine				
THM (NOTE: show latest running annual average)	quarterly	22.56	µg/L	None
Temephos				
Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

Summary table for Running Annual Averages of Organic Parameters sampled during this reporting period.

Parameter	Sample Date	Result	Running Annual Average	Unit of Measure	Number of Exceedances
HAA	Jan.8, 2024	4.2	5.0	µg/L	None
	Apr.8, 2024	<5.3		µg/L	
	Jul. 8, 2024	<5.3		µg/L	
	Oct.7, 2024	<5.3		µg/L	
Parameter	Sample Date	Average Result	Running Annual Average	Unit of Measure	Number of Exceedances
THM	Jan.8, 2024	18.0	22.56	µg/L	None
	Apr.8, 2024	22.0		µg/L	
	Jul. 8, 2024	26.8		µg/L	
	Oct.7, 2024	23.5		µg/L	

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
N/A			