

ANNUAL SUMMARY REPORT  
For the  
TECUMSEH DISTRIBUTION SYSTEM  
(260004969)  
For the year  
2018

Prepared for the Town of Tecumseh

By Denis Berthiaume, ORO  
Manager Water & Wastewater Services

## Table of Contents

<b>Section 1: Overview .....</b>	<b>3</b>
<b>Section 2: Non-compliance Issues .....</b>	<b>4</b>
<b>Section 3: System Capability.....</b>	<b>4</b>

## Section 1: Overview

This report has been prepared and submitted in accordance with Schedule 22 of O. Reg. 170/03 under the *Safe Drinking Water Act*. Schedule 22 requires:

The owner of a drinking-water system shall ensure that, not later than March 31 of each year after 2003, a report is prepared in accordance with subsections (1) and (2) for the preceding calendar year and is given to the members of the municipal council.

Schedule 22 also states that:

- 1) The report must:
  - a) list the requirements of the *Act*, the regulations, the system's approval and any order that the system failed to meet at any time during the period covered by the report and specify the duration of the failure; and
  - b) for each failure referred to in clause (a), describe the measures that were taken to correct the failure.
- 2) The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system. A summary of the quantities of the water supplied during the period covered by the report, including monthly flows.

In June 2003, the provincial *Safe Drinking Water Act* came into effect. The Drinking-Water Systems Regulation (O.Reg. 170/03) defines how various drinking-water systems are to be operated.

According to this Regulation, the Tecumseh Distribution System is classified as a Large Municipal Residential System (LMR).

## Section 2: Non-Compliance Issues

1. During the year of 2018 there was 1 **reportable issue** on Feb 21/18 at the auto flusher located on Manning/County Rd #34 in the Tecumseh Distribution System. (see full attachment with this Council Report)

## Section 3: System Capability – 2018 Water Consumption

In accordance with the Agreement between the Town of Tecumseh and the City of Windsor for the provision of water services to the Town of Tecumseh, executed under By-Law No. 2004-71, the Maximum Daily Flow shall not exceed **87 Million Litres** (87 MLD) or 87,000 cubic meters.

The **Maximum Daily Flow** for 2018 was **33,447,000 Litres** (33,447 cubic meters) on May 29, 2018.

Monthly average and daily flows for 2018 are attached for reference.

A summary of the **monthly** total volume supplied by the City of Windsor to the Town of Tecumseh is provided below:

<b>2018 Water Consumption</b>	
<b>Month</b>	<b>Total Volume (cubic meters)</b>
January	240,923
February	217,118
March	224,111
April	235,065
May	276,175
June	367,900
July	366,153
August	326,624
September	311,522
October	274,300
November	240,671
December	235,178
<b>Total</b>	<b>3,315,740</b>